

ESSEX & SUFFOLK
WATER *living water*

Final Water Resources Management Plan 2019

August 2019



Exclusions on the Grounds of National Security

Northumbrian Water Limited has not excluded any information from this plan on the grounds that the information would be contrary to the interests of national security.

Under Section 37B(10)(b) of the Water Industry Act 1991, as amended by the Water Act 2003 ("the Act"), the Secretary of State can direct the Company to exclude any information from the published Plan on the grounds that it appears to him that its publication would be contrary to the interests of national security.



DOCUMENT CONTROL SHEET

Report Title	Final Water Resources Management Plan 2019
Authors	Will Robinson, Liz Wright, Katherine Fuller, Sarah Newbury, Harriet Robson, Alan Gosling, Thomas Andrewartha, Claire Lorenc, Hazel Leah, Simon Welsh, Martin Lunn
Previous Issue	Draft Final Water Resources Management Plan 2019
Distribution List	Internal: Applicable Management & Affected Depts External: As per Water Resources Planning Guideline Web: www.eswater.co.uk/wrmp

DOCUMENT CHANGE RECORD

Release Date	Version	Report Status	Change Details
30 Nov 2017	1	Draft	N/A - first draft
1 Sept 2018	2	Draft Final	As per Statement of Response
20 Aug 2019	3	Final	As per Draft Final, in accordance with direction to publish

DOCUMENT SIGNOFF

Nature of Signoff	Person	Signature	Date	Role
Reviewed by	Martin Lunn		31/08/18	Head of Technical Strategy & Support
Approved by	Heidi Mottram		31/08/18	Chief Executive Officer

Disclaimer : This report is intended as confidential to the individuals and or companies listed on the distribution list. Essex & Suffolk Water accepts no responsibility of any nature to any third party to whom this report or any part there of is made known.



Northumbrian Water is a trading division of Northumbrian Water Limited which is a group Company of Northumbrian Water Group

Registered in England & Wales No. 2366703
Registered Office:
Northumbria House, Abbey Road
Pity Me,
Durham DH1 5FJ

Board Assurance Statement

Having reviewed the draft final WRMPs, the Northumbrian Water Limited Board made the following statement:

- The Board is satisfied the plan represents the most cost effective and sustainable long term solution;
- The Board believes it has sufficiently collaborated with customers, partners and regulators to develop a strong understanding of future needs, explore every option, and build consensus on delivery plans;
- The Board confirms the integrity of the risk assessment process put in place for all of our water supplies; and
- The Board is satisfied that the WRMPs take account of all statutory drinking water quality obligations, and plans to meet all drinking water quality legislation in full including the Drinking Water Directive.

The Board confirms that Northumbrian Water complies with its duties on drinking water quality matters in its broader resilience and resource planning arrangements.

Date: 30 July 2018

Signed for and on Behalf of the Board:

A handwritten signature in blue ink, appearing to read 'Ceri Jones', is written over a light blue horizontal line.

Ceri Jones
Assets & Assurance Director

Technical Summary

Introduction

Water Resources Management Plan Purpose

This document is our draft final Water Resources Management Plan 2019 (WRMP19). It demonstrates that we have an efficient, sustainable secure supply of water over our chosen planning period. For this WRMP, we have prepared water demand and supply forecasts for a 40 year planning period from 1 April 2020 to 31 March 2060.

The WRMP covers our entire customer supply area (see Figure 1 in Appendix 1). For the purposes of our demand forecasts and supply demand balance calculations, the supply area has been split into the following Water Resource Zones (WRZ) (see Figures 2 and 3 in Appendix 1):

Table 0.1: ESW Water Resource Zones

Supply Area	Water Resource Zone
Essex	Essex WRZ
Suffolk	Blyth WRZ
	Hartismere WRZ
	Northern Central WRZ

The WRMP has been prepared following the Water Resources Management Plan (England) Direction 2017 (Defra, 2017), Defra’s Guiding Principles for Water Resources Planning (Defra, 2016) and the Environment Agency’s Water Resources Planning Guideline (the WRPg) (Environment Agency, 2017a).

Water Resources Background

Our Essex and Suffolk supply areas are located within some of the driest areas of the country and as such face particular challenges including growing demand, uncertainty from climate change and a general lack of new intrinsic water resources. We have always fully embraced the concept of the ‘twin track approach’ to maintaining water supplies through a combination of demand management and water supply schemes and initiatives.

We pride ourselves on our track record of demand management and in delivering innovative water supply solutions such as the “Langford Effluent Recycling Scheme” and the “Abberton Scheme”, both of which are described within this Plan. We have amongst the lowest levels of leakage in the UK and are an acknowledged industry leader in water efficiency and water conservation. Additionally we are fully committed to achieving the maximum possible level of domestic meter penetration within an appropriate timescale and with our customers’ support.

Despite all the rigorous work on demand management, our PR09 WRMP recognised that a major water resource scheme was required in the Essex WRZ to meet the growing demand for water. The Abberton Scheme was identified as being the appropriate option for us to pursue during AMP5. The Abberton Scheme comprised three major elements, namely:

- i. The upgrade of the Ely Ouse to Essex Transfer Scheme (EOETS) by way of two new pipelines and an upgrade to the pumping facilities;
- ii. A variation to the abstraction licence at Denver in Norfolk from where water is transferred by the EOETS; and
- iii. The enlargement of Abberton Reservoir.

All works were completed in 2012 providing the Essex WRZ with a PR14 supply surplus throughout the planning period.

Periodic Review 2019 (PR19) Supply and Demand Forecasts

In this WRMP, all components of the supply and demand forecasts have been reviewed using the appropriate methods recommended in the Agency's WRPG (Environment Agency, 2017a).

The chosen planning scenario remains the Dry Year Annual Average (DYAA) as no WRZ demonstrates a critical period where peak demands are driving investment within the WRZ.

Water Supply Forecasts

Future water supplies are forecast by calculating Water Available for Use (WAFU). WAFU is calculated by quantifying the Deployable Output (DO) of our raw water sources and treatment works within each water resource zone. Outage (for example when a treatment works is out of supply due to planned maintenance), process losses (for example the water used to back wash treatment works filters) and sustainability reductions (for example where our abstraction licence has been reduced to ensure they are sustainable) are then subtracted from the DO to give WAFU.

The Suffolk WRZ WAFU remains similar to PR14 but the Essex WRZ DO has increased by more than 65 Ml/d since PR09 as a result of the completion of the Abberton scheme and due to a recent reassessment of river flows from 1915 to 2015.

Effect of Climate Change on Future Water Supplies

Climate change was assessed in our PR14 WRMP using the CP09 Climate Projections. As these remain the latest projections, our PR14 groundwater climate change assessment remains valid. It concluded that climate change has a low impact in the Suffolk groundwater dominated WRZs.

We have reassessed the effect of climate change on the DO of our river abstractions using the latest methods. In the Essex WRZ, there is a slight positive enhancement to supplies in the pumped storage reservoir dominated system.

Our assessments conclude that after considering the effects of climate change, all four WRZs remain in surplus across the whole planning horizon, with no water resource development being driven by climate change assumptions.

Environmental Improvements

Each time we update our WRMP (every five years), we agree with our regulators a list of schemes collectively known as the Water Industry National Environment Programme (WINEP). The WINEP is an integrated list of requirements for water resources, water quality and fisheries, biodiversity and geomorphology. It consists of investigations, options appraisals and actions to protect (prevent deterioration) and improve the water environment. Actions to protect or improve the environment include changes to our abstraction licences, also known as sustainability changes, and non-licence change actions, such as river restoration. The WINEP does not just consider the direct effect of abstraction. It also considers, among other aspects, catchment measures to improve the quality of water at abstraction intakes, invasive non-native species risk, fish passage and discharges to the environment.

The current PR14 AMP6 WINEP (2015 to 2020) includes the following:

- Three Review of Consents Implementation schemes, namely:
 - Trinity Broads Special Area of Conservation (SAC): Sediment removal via mud pumping;
 - Geldeston Meadows SAC: Provision of a river support discharge; and
 - Alde Ore Estuary Special Protection Area (SPA): Provision of a river support discharge.
- Two Water Framework Directive (WFD) implementation schemes, both also with an Eel Regulations driver, namely:
 - River Blackwater: Provision of a River Blackwater Sluice Fish Pass; and
 - Fritton Decoy: Provision of a sluice eel pass.
- One Restoring Sustainable Abstraction (RSA) implementation scheme, namely:
 - River Stour at Cattawade: Raise abstraction cessation level from 1.5mAOD to 1.65mAOD; and install variable speed abstraction pumps to pump to a level to reduce daily fluctuation in water level. This will prevent the exposure and re-wetting of river bank which might be responsible for the release of toxins that cause fish stress. Additionally it will help facilitate eel passage.
- Eel Regulations:
 - 16 Eel Regulations Implementation Schemes, of which ten were to improve intake screening and six to install or improve eel passes; and
 - Six Eel Regulations Investigations to investigate opportunities to facilitate eel passage.
- Water Quality / Drinking Water Protected Areas (DrWPA):

- A programme of work under the DrWPA driver, implementing catchment schemes to protect raw water quality.

We have made excellent progress in delivering all of the above schemes. All of the improvements will have been delivered by 31st March 2020.

We have agreed a new WINEP with our regulators for AMP7 (2020 to 2025). The third iteration of the PR19 WINEP for AMP7, issued by the Agency in March 2018, includes the following schemes:

- Investigations to confirm the sustainability of our Suffolk groundwater abstractions;
- One sustainability change scheme in relation to our Langham boreholes abstraction;
- Investigations to establish whether our raw water transfers increase potential Invasive Non-native Species (INNS) transfer;
- Schemes to reduce the transfer of INNS;
- Investigations relating to facilitating eel passage at two reservoir sites;
- Two improvement schemes relating to the upgrade of eel screens at intakes;
- Five catchment management schemes to protect water quality in our main surface water catchments; and
- Two schemes and an investigation to improve priority habitats on our land and in the catchments we operate in.

All of the above schemes have been included in our PR19 Business Plan.

Household Demand Forecast

The base building block for demand forecasting is the base year population served and the projected growth in population annually over the WRMP. In line with the WRPG requirement, we have used local authority Plan housing growth evidence from all local authorities and has selected the Plan-based scenario.

In the case of our Essex and Suffolk supply areas, the population forecasts for PR19 using the Plan-based scenario shows a growth in population over the planning horizon. This has resulted in a 34% increase in Essex population over the 40 year planning horizon and a 29% increase in Suffolk population. The population is now forecast to be 2.56M by 2059/60. Overall occupancy in the demand forecast reduces from 2.64 to 2.49 in Essex and reduces from 2.29 to 2.22 in Suffolk.

The average annual number of new homes is forecast at 7,255 in Essex for AMP7 and 1,189 in Suffolk.

The per capita consumption (PCC) in Essex and Suffolk is forecast to reduce annually across the planning horizon as a result of our metering policy and water efficiency initiatives. In Essex, unmeasured PCC is forecast to reduce to 133.97 litres per head per day (l/h/d) by 2059/60, with measured properties reducing to 111.98

l/h/d. In Suffolk, unmeasured PCC is forecast to reduce to 128.15 l/h/d by 2059/60, with measured properties reducing to 106.41 l/h/d.

The normal year forecasts have been used as the basis for dry year forecasts, and adjusted to provide figures for two climate change scenarios.

Non-household Demand Forecast

Overall non-household forecasted demand to 2060 is relatively flat, with a gradual increase over time to account for growth of non-household property numbers. This is due to the assumption built into the forecast methodology that individual customer demand will trend to a flat line over time.

Customer Metering

Current AMP6 (2015 to 2020) Metering Strategy

In Essex and Suffolk, separate metering strategies have been run since 2003/04. In Suffolk, we have been “optant” only metering, as required by legislation since 2000. Optant metering is where a customer requests a meter from the company and, assuming the meter can be installed at reasonable cost, the company is required to install a meter free of charge. The customer then pays for their water and sewage on a measured basis. They also have a choice of reverting back to an unmeasured charge for two years after the meter has been installed. A meter means a customer only pays for the volume of water used, which in low occupancy high rateable value properties, usually reduces their annual water bill. All unmetered customers continue to be charged according to the rateable value of their property. All new properties, and properties that have had significant alteration or installed large water using apparatus e.g. a swimming pool, are metered.

In Essex, exactly the same optant, new property and high water users’ strategy has been in place. However, in the early 2000s it was obvious that opting for a meter was far more popular in Suffolk than it was in Essex. The exact reason for this is unknown but the greater proportion of second homes in Suffolk, which are therefore only partially occupied, could account for it as they generally will have a low annual consumption. Historically, there has also been a higher cost of water in Suffolk than Essex, which may have made having a meter more financially attractive. Whatever the reason, the outcome was that the more water stressed area of Essex, compared to Suffolk, had a significantly lower meter penetration level. Looking at the declining trend in the annual number of optants in Essex, meter penetration was unlikely to increase sufficiently to support our demand management aspirations if only optant metering was available.

From 2003, initially in a pilot area, metering on change of property occupier (selective) metering was introduced in Essex. Selective metering is allowed under current legislation where, if the occupier of a property has never received an unmeasured bill for water to that property, then the company is allowed to install a water meter and charge the customer on a measured basis. In reality this means that

we can meter a property when it changes hands by either being purchased or having a new tenant. This additional form of metering being added to the Essex strategy has meant that by 2019/20, 64% of domestic properties will be metered. In Suffolk this figure will be 69%.

However, we now believe that selective metering in Essex has probably achieved as much as it can. Whilst we recognised that as more properties became measured the chance of a new occupier moving in to an unmeasured property decreased, after the first two years the numbers decreased markedly.

Initially, selective metering in Essex started in 2005 and we saw a peak of 14,235 selectively metered properties in 2006/7. However, the financial crash in 2007 saw house-moving plummet from 2008 onwards, with the number of selective meters falling to an average of 5,500 for the next five years. As house moves picked up, we did not see the expected increase in selective meters coming through and have actually seen a steady decline in numbers from 5,300 in 2011/12 to 3100 in 2016/17 against the 6,000 forecast at PR14. These numbers are far below that forecast and far below the numbers expected if approximately 10% of properties change occupier per annum. What we have now come to understand is that even when the number of house moves returns to normal, a high proportion of the houses coming on to the market are those that have been sold within the previous ten years. This reduces the opportunity to selectively meter dramatically as most properties have been selectively metered previously. Equally in the rented sector tenancies tend to be of fairly short duration meaning most of these properties will already have been selectively metered on their first change of occupier. However, because we want to meter above the “natural” optant rate in Essex, we are going to introduce area metering as described below.

Changes to ESW’s Draft WRMP Metering Strategy for 2020 to 2025

In Essex, we will continue with the current strategy of optant metering but will no longer continue with selective metering on change of occupier of a domestic property. Instead, we are going to introduce Area Metering which we predict should add a further 5,000 meter optants per annum to the forecast number of “natural” optants expected.

Area Metering is the name we are giving to a new programme of installing meters in to existing empty meter chambers, our customers will remain unmeasured but over a two year period we will send them a “water bill” showing what they would have paid had they opted for a meter.

As a result of our mains renewal programmes over the last 30 years, including a significant replacement of mains during the 1990s for quality reasons (Section 19 Quality Programme), we have a large number of empty meter chambers. This has arisen because when we have renewed water mains, we have also taken the opportunity to renew the communication pipe (the pipe between one of our mains and the customer’s curtilage) and install a meter chamber. We estimate that there

are currently approximately 70,000 empty chambers and we continue to add to this number as we renew mains.

Our proposal is to drop meters into these chambers at a rate of 10,000 per annum, and inform the customer that whilst they remain an unmeasured customer we will send them “dummy bills” over a two year period showing what their water bill would be if they were metered. From our customer research, we forecast that over the two year period, 5,000 of these customers will opt to go on to a measured bill - some very early on and others when they see that financial savings are sustainable and not a single aberration. Once they opt for a meter they have a further two years in which to revert, potentially giving customers up to four years of measured bills before they become permanently metered. Equally, any change of occupier to these properties at any time will automatically become metered. Even for those properties that chose not to become measured, or changed ownership, we believe knowing that the property has a meter will have a ‘Hawthorn’ effect on their use, certainly reducing wasteful use.

Moving to this area metering at the start of AMP7 (April 2020) would mean far less than 5,000 new optants from Area Metering in the first year of installing the 10,000 meters per annum (pa), as we expect the 5,000 optants over the two years. Therefore we propose to begin the 10,000 meters pa from April 2018, meaning that by the first year of AMP7, the first 10,000 customers will be at their two years of “dummy” bills and a further 10,000 reaching one year of “dummy” bills. We intend stopping selective metering at the end of March 2018 as the number of optants from Area Metering in the last two years of this AMP is likely to exceed the number of new measured properties from continuing with selective metering.

With our planned level of mains renewal for the remainder of AMP7 and during AMP7, we forecast that there will be sufficient empty meter chambers to continue Area Metering through AMP8. At the end of each AMP the Essex meter penetration is forecast to be as below:

Table 0.2: Essex meter penetration forecast

AMP6	AMP7	AMP8	AMP9	AMP10	AMP11
63.99%	72.56%	78.74%	81.24%	82.98%	84.59%

We assume an average saving from an optant metered customer having a meter installed is 5% of the unmeasured consumption or 13.54 litres per property per day (l/p/d). Installing 46,875 optants in AMP7 will save 634,696 litres water per day. The total AMP7 cost for our Essex metering strategy is £8,331,554.

In Suffolk, we are to continue with the current strategy of optant metering. With approximately 69% of properties being metered by 2020, the number of new optants coming forward will decline to a lower level than experienced in AMP6. At the end of each AMP, the Suffolk meter penetration is forecast to be as below:

Table 0.3: Suffolk meter penetration forecast

AMP6	AMP7	AMP8	AMP9	AMP10	AMP11
69.00%	73.34%	75.60%	76.66%	77.60%	78.45%

We assume an average saving from a customer having a meter installed of 4% of the unmeasured consumption from an optant or 9.53 l/p/d. This gives an AMP7 total of water saved in Suffolk from optant metering of 35,434 litres per day. The total cost of our Suffolk optant metering strategy for AMP7 = £1,153,925

The overall impact of our metering strategy is that we will install a total of 75,594 meters during AMP7 at a total cost of £9.49m. This will result in water demand savings of 0.67 MI/d.

Demand Management Strategies

Leakage Strategy

Our current regulatory leakage performance commitment for 2019/20 is 66 MI/d. Beyond 2020, a new method has been proposed by the regulator Ofwat to ensure all water companies report leakage consistently. Using the new leakage calculation method, we estimate that the most probable value for leakage in 2019/20 would reduce from 66 MI/d to 62.6 MI/d. For AMP7 (2020 to 2025), we plan to reduce leakage by 17.5% by 2024/25 to 51.6 MI/d. Beyond 2025, we plan to further reduce leakage by 10% over each subsequent five year period. By 2044/45, the end of the regulatory minimum planning period, this would reduce leakage to 33.9 MI/d or 54% of current leakage).

Water Efficiency Strategy

We are able to demonstrate our commitment to encouraging our customers to use water wisely through a long history of delivering effective water efficiency strategies and programmes. The drivers (regulatory and other) detailed above add further emphasis to the importance of water efficiency for varying reasons.

In turn, and in conjunction with smart metering, we will commit to

- Deliver a programme of water efficiency activities that will reduce PCC from 145.2 litres per person per day in 2019/20 to 136.0 by 2024/25, representing a 6.3% reduction and equating to 9.2 litres per person per day;
- Reduce PCC to 119.0 in our ESW operating area by 2040, representing an 18% reduction.

We will achieve the ambitious demand reductions stated above through a continuation of the range of activities currently delivered although at a far greater scale. Central to the water efficiency strategy in AMP7 will be the Every Drop Counts programme, taking a community-focused and wide-reaching approach to saving water through the delivery of all of our activities in one town at one time. The whole-town approach ensures that we are able to maximise our effectiveness in terms of

participation and water savings in target areas. Home water efficiency retrofits will remain a cornerstone to the strategy as a means of ensuring the existing housing stock is as water efficient as possible whilst delivering behaviour change. The Super Splash Heroes programme forms an effective means by which we are able to engage with future generations. We will continue to focus on housing associations, develop stronger links with their affordability strategy, and focus on identifying and repairing internal plumbing losses. Each of the activities discussed previously will be delivered in AMP7 at a greater scale. In addition, we will install smart meters and deliver two further programmes that were selected through the options appraisal:

- Work with developers to require new properties to be built to the Building Regulations Part G Optional Requirement, where possible and appropriate.
- Introduce a high efficiency toilet rebate scheme.

It is important to highlight that the water efficiency scene is changing, which in turn will influence the strategy as time progresses through AMP7. There will be three key priorities for water efficiency in the coming decade.

- There will be a transition whereby the importance of behaviour change grows exponentially.
- The delivery of home retrofits will need to become more targeted towards only those homes that will truly benefit from the programme. Our research and statistical analysis tells a story suggesting a limited lifespan of the home retrofit project as the stock of existing inefficient water using appliances is replaced with those that are more efficient. We are able to demonstrate that product installation rates associated with the home retrofit programmes are declining on an annual basis, in turn diminishing the cost-effectiveness of the projects.
- The use of smart metering/technologies will be deemed beneficial to water companies and an expectation of customers.

In response, we will implement an innovative digital engagement platform that will underpin and assist in the delivery of these priorities whilst further supporting its drive to deliver unrivalled customer service. Linked to the digital engagement platform will be two additional themes. An innovative incentive scheme, building on the behavioural economics research we undertook in conjunction with Oxford University and the University of Chicago, will be implemented to intelligently incentivise customers. We will also deploy a series of smart technologies allowing more frequent and circular customer conversations around water efficiency.

Distribution Input Forecast

The overall effect on the forecast of Distribution Input (DI) is that in 2059/60, Essex will have a demand of around 8 Ml/d less than today, with a population increase of 563,530 people. The Suffolk Northern Central WRZ demand is forecast to increase by a modest 1 Ml/d, with the smaller Blyth WRZ and Hartismere WRZ seeing a very small decline in demand.

Target Headroom Forecast

Target headroom can be thought of as a security margin or an allowance that takes account of any uncertainty in the WAFU and DI forecasts.

Target headroom should be considered in the context of actual headroom. This is the difference between the WAFU and DI forecasts. WAFU should be greater than the DI forecast to allow for uncertainty and ensure it can meet demand. The 'ideal' amount of actual headroom that a prudent water company should retain is called target headroom.

Once calculated, this target headroom allowance is added to the distribution input forecast. Providing the WAFU forecast remains above the DI plus target headroom forecast, then the water resource zone is considered to have a sufficient supply surplus.

Target headroom is summarised in the table below, and is illustrated in Figures 0.1 to 0.4. The target headroom as a percentage of DI is lower in all WRZs in 2059/60 than in 2018/19.

Table 0.4: Target headroom as a percentage of DI

WRZ	2018/19 approximate target headroom as a percentage of DI	2059/60 approximate target headroom as a percentage of DI
Essex	9%	5%
Blyth	14%	8%
Hartismere	11%	6%
Northern Central	10%	8%

Supply Demand Balance Forecast

A supply demand balance is best illustrated as a graph showing supply (known as Water Available For Use or WAFU) and demand (known as Distribution Input plus Target Headroom). Providing the supply line is above the demand plus target headroom line, there is a supply surplus. This means there is sufficient water to meet demand during a severe drought and so there is not a need to develop new water resources.

We have re-assessed our supply and demand forecasts for this WRMP. These assessments have confirmed that all four of our water resource zones have a supply surplus across the full planning period to 2060. Consequently, no new water resource schemes are required in this period.

This is illustrated in the final planning supply demand balance graphs below.

Essex Water Resource Zone
Draft WRMP Final Planning Supply Demand Balance




Figure 0.1: Final Planning Supply Demand Balance – Essex WRZ

Suffolk Blyth Water Resource Zone
Draft WRMP Final Planning Supply Demand Balance




Figure 0.2: Final Planning Supply Demand Balance – Suffolk Blyth WRZ




Figure 0.3: Final Planning Supply Demand Balance – Suffolk Hartismere WRZ




Figure 0.4: Final Planning Supply Demand Balance – Suffolk Northern Central WRZ

The supply surplus in the Suffolk WRZs is not sufficient to offer a supply to a neighbouring water company. The Essex WRZ supply surplus is less than that

presented in our PR14 WRMP. This is because of a recent (2015) trade of 20 MI/d of raw water with Thames Water Utilities. Consequently, we can only offer 5 MI/d for trading until 2035 and then 25 MI/d from 2035 onwards.

Sensitivity Testing

We consider our Plan is already resilient to freeze / thaw events and to flooding and so we have not undertaken any further sensitivity testing for these hazards. However, using scenario testing, we have assessed the sensitivity of our supply surplus to:

- i. Sustainability reductions to our abstraction licences; and
- ii. New non-household demand

Sensitivity to Sustainability Reductions

Sustainability reductions are applied to abstraction licences and reduce the licensed quantities of water that can be abstracted. They are applied if investigations and modelling conclude that abstraction is unsustainable.

All of our groundwater abstraction licences in the Blyth and Hartismere WRZs are included in our part of the WINEP, and so the sustainability of these abstractions will be investigated in AMP7 (2020 to 2025). We have assessed the sensitivity of our supply surplus in the Blyth and Hartismere Water Resource Zones and have prepared a supply demand balance where our WAFU forecast is based on all of our abstraction licence annual licensed quantities being capped at a recent actual (the maximum annual abstraction between 2005 and 2015) utilisation rate.

In the Blyth WRZ, a supply surplus would be maintained without allowing for target headroom. However, there would be a supply deficit when including target headroom. This would be -0.32 MI/d at the start of AMP7, reducing to -0.06 MI/d at the end of AMP7, primarily due to demand savings resulting from leakage reduction. Further reductions in leakage and PCC would mean that there would then be a small supply surplus across the remainder of the planning period.

The Hartismere WRZ graph shows that a supply surplus would be maintained across the planning period both with and without an allowance for target headroom.

Sensitivity to Unconfirmed Non-household Demand

EDF Energy is promoting a new nuclear power station at Bradwell-on-Sea in Essex. It is currently forecasting construction will commence in 2027 with a construction and operational water demand of 2 MI/d. We do not believe that there is a sufficient level of certainty regarding the proposed construction start date. Consequently, the potential demand for Bradwell B power station has not been included in the Essex WRZ final plan Distribution Input forecast. Instead, we have presented it as a sensitivity scenario in Section 8.7 of the WRMP. This concludes that an additional

power station demand of 2 MI/d can easily be met without the need for additional supply and / or demand schemes.

EDF Energy is also promoting a new nuclear power station at Sizewell in Suffolk known as Sizewell C. It is currently forecasting construction will commence in 2022 with a maximum additional demand of 2 MI/d. We do not believe that there is a sufficient level of certainty regarding the proposed construction start date and so this potential demand has not been included in the baseline Distribution Input forecast. Instead, we have presented the potential demand in a sensitivity scenario in Section 8.7 of the WRMP. As the sustainability of the groundwater abstractions in this supply area will be investigated in 2020, we have agreed with the Environment Agency that for this scenario, water supply (Water Available for Use) should be based on recent actual abstraction (i.e. the maximum annual abstraction between 2005 and 2015). The scenario testing shows that there would be a supply deficit and so a new supply would be required. Our view is that there is still significant uncertainty regarding the Sizewell C construction start date and as such it would be wrong to include it in our final plan now. Once there is greater certainty regarding the Sizewell C construction start date, this would count as a material change to our WRMP. We will then include it in our final plan Distribution Input forecast and work with EDF Energy to develop a new supply albeit that the capital cost of the scheme would be funded by EDF Energy.

Drought Resilience

We have tested the resilience of our water supply systems to a very severe drought which is calculated to occur once in every 200 years on average. We have used models to simulate the effects of such a drought on DO. Our modelling confirms that all four of our water resource zones are resilient as a supply surplus would still be maintained during such an extreme drought.

CONTENTS

Contents

BOARD ASSURANCE STATEMENT	4
TECHNICAL SUMMARY	5
1. INTRODUCTION	25
1.1 OVERVIEW	25
1.2 REGULATORY FRAMEWORK	26
1.3 CONSULTATION	27
1.3.1 <i>Pre-draft Water Resources Management Plan Consultation</i>	27
1.3.2 <i>Engaging our Water Forum in the development of our WRMP</i>	28
1.3.3 <i>Engaging our customers in the development of our WRMP</i>	28
1.3.4 <i>Draft Water Resources Management Plan Consultation</i>	31
1.4 RELIABLE AND RESILIENCE SUPPLIES	32
1.5 INNOVATION.....	34
1.6 OUR APPROACH TO ASSURANCE.....	34
1.7 WATER RESOURCES PLAN STRUCTURE	35
2. BACKGROUND INFORMATION	37
2.1 WATER RESOURCE ZONES	37
2.1.1 <i>Background</i>	37
2.1.2 <i>The Essex Water Resource Zone</i>	38
2.1.3 <i>Suffolk Blyth Water Resource Zone</i>	39
2.1.4 <i>Suffolk Hartismere Resource Zone</i>	39
2.1.5 <i>Suffolk Northern Central Water Resource Zone</i>	40
2.2 WATER RESOURCE ZONE INTEGRITY	40
2.3 PROGRESS WITH IMPLEMENTING THE 2015 WATER RESOURCES MANAGEMENT PLAN	41
2.4 SHARING SURPLUS WATER RESOURCES	41
2.4.1 <i>Background</i>	41
2.5 WATER UK WATER RESOURCES LONG-TERM PLANNING FRAMEWORK	42
2.6 REGIONAL WATER RESOURCES	43
2.6.1 <i>Regional Overview</i>	43
2.6.2 <i>Water Resources East</i>	44
2.6.3 <i>Water Resources South East</i>	45
2.7 PLANNING PERIOD AND BASE YEAR.....	45
2.8 PLANNING SCENARIOS.....	46
2.9 PROBLEM CHARACTERISATION AND RISK COMPOSITION	48
2.9.1 <i>Drought Analysis</i>	48
2.9.2 <i>Problem Characterisation</i>	53
2.9.3 <i>Risk Composition</i>	54
2.10 RESILIENCE TO DROUGHTS MORE SEVERE THAN THOSE USED TO TEST THIS WRMP	56
2.11 RESILIENCE TO NON-DROUGHT HAZARDS.....	59
2.11.1 <i>Overview</i>	59
2.11.2 <i>Flooding</i>	60
2.11.3 <i>Freeze / Thaw</i>	60
2.12 RECONCILIATION OF DATA	61
2.13 SENSITIVITY TESTING	61

2.14	COMPANY POLICIES INCLUDING LEVEL OF SERVICE	62
2.14.1	<i>Customer Consultation</i>	62
2.14.2	<i>PR19 WRMP Planned Levels of Service</i>	62
2.14.3	<i>PR19 Actual Levels of Service Assessment</i>	66
2.15	THIRD PARTY PROVISION OF SUPPLY AND DEMAND OPTIONS	68
2.16	DETAILS OF COMPETITORS IN EACH RESOURCE ZONE.....	68
2.17	LINKS TO OTHER PLANS	69
2.17.1	<i>Links to Northumbrian Water Limited Business Plan</i>	69
2.17.2	<i>Links with Essex & Suffolk Water Drought Plan</i>	69
2.17.3	<i>Links with Environment Agency Drought Plan</i>	70
2.17.4	<i>Links to Defra's 25 Year Plan</i>	70
2.17.5	<i>Links with River Basin Management Plans</i>	71
2.17.6	<i>Links with Flood Risk Management Plans</i>	71
2.17.7	<i>Links with Plans Produced by Local Authorities</i>	71
2.18	WATER INDUSTRY STRATEGIC ENVIRONMENTAL REQUIREMENTS (WISER) .	72
2.19	BIODIVERSITY 2020.....	74
2.20	NATURAL CAPITALS.....	75
2.21	HABITATS REGULATION ASSESSMENT.....	76
2.22	STRATEGIC ENVIRONMENTAL ASSESSMENT	76
2.23	OPTIMISATION OF EXISTING OPERATIONS	78
2.23.1	<i>Business as Usual Optimisation</i>	78
2.23.2	<i>Abstraction Incentive Mechanism (AIM)</i>	78
3.	WATER SUPPLY.....	80
3.1	DEPLOYABLE OUTPUT (DO) OVERVIEW	80
3.2	ESSEX RESOURCE ZONE DEPLOYABLE OUTPUT ASSESSMENT.....	81
3.2.1	<i>Overview</i>	81
3.2.2	<i>Essex System Deployable Output Assessment Approach</i>	82
3.2.3	<i>Model updates since PR14</i>	82
3.2.4	<i>Deployable output modelling assumptions and set-up</i>	86
3.2.5	<i>Results</i>	88
3.3	ESSEX SYSTEM SENSITIVITY TESTING AGAINST A 1 IN 200 YEAR DROUGHT ..	90
3.4	SUFFOLK SURFACE WATER SOURCE DEPLOYABLE OUTPUT ASSESSMENT ..	92
3.4.1	<i>River Bure and Ormesby Broad</i>	92
3.4.2	<i>River Waveney DO Assessment</i>	100
3.4.3	<i>Lound and Fritton Lake DO Assessment</i>	101
3.5	RIVER WAVENEY AND RIVER BURE DO SENSITIVITY TESTING AGAINST A 1 IN 200 YEAR DROUGHT	106
3.5.1	<i>River Waveney</i>	106
3.5.2	<i>River Bure</i>	106
3.6	ESSEX AND SUFFOLK GROUNDWATER SOURCE DEPLOYABLE OUTPUT ASSESSMENT 107	
3.6.1	<i>Methodology</i>	107
3.6.2	<i>Confidence Labelling</i>	108
3.6.3	<i>Essex Groundwater Source Deployable Output</i>	109
3.6.4	<i>Suffolk Resources Zones Deployable Output</i>	110
3.7	GROUNDWATER DEPLOYABLE OUTPUT SENSITIVITY TESTING AGAINST A 1 IN 200 YEAR DROUGHT.....	111
3.8	WATER INDUSTRY NATIONAL ENVIRONMENT PROGRAMME & EFFECT ON DEPLOYABLE OUTPUT	113
3.8.1	<i>Background</i>	113
3.8.2	<i>AMP6 National Environment Programme (NEP)</i>	114
3.8.3	<i>AMP7 Water Industry National Environment Programme (WINEP3)</i> 120	

3.9	ABSTRACTION REFORM	122
3.9.1	<i>Allowances for Abstraction Reform</i>	122
3.9.2	<i>Emergency Abstraction Licences</i>	122
3.10	CLIMATE CHANGE	123
3.11	PROTECTION OF DRINKING WATER PROTECTED AREAS	123
3.12	INVASIVE NON-NATIVE SPECIES (INNS)	126
3.13	OUTAGE	128
3.13.1	<i>Background</i>	128
3.13.2	<i>ESW's Adapted Methodology</i>	129
3.13.3	<i>Data Analysis Results</i>	132
3.13.4	<i>Monte Carlo Simulation Results</i>	137
3.13.5	<i>Return Period Evaluation</i>	138
3.13.6	<i>Opportunities to reduce outage</i>	139
3.14	RAW AND POTABLE WATER TRANSFERS AND BULK SUPPLIES	140
3.14.1	<i>Essex Raw Water Imports - Chigwell Bulk Supply</i>	140
3.14.2	<i>Essex Raw Water Exports</i>	141
3.14.3	<i>Essex Water Resource Zone Potable Water Imports</i>	141
3.14.4	<i>Essex Water Resource Zone Potable Water Exports</i>	141
3.15	PROCESS LOSSES.....	142
3.16	ZONAL SUMMARY OF DEPLOYABLE OUTPUT AND WAFU.....	143
4.	WATER DEMAND FORECASTS.....	145
4.1	INTRODUCTION.....	145
4.2	BASE YEAR DEMAND	146
4.2.1	<i>Normalised PCC</i>	146
4.2.2	<i>Unmeasured Household Water Delivered</i>	148
4.2.3	<i>Measured Household Water Delivered</i>	148
4.2.4	<i>Non-Household Water Delivered</i>	149
4.2.5	<i>Supply Pipe Leakage</i>	149
4.2.6	<i>Meter Under-Registration</i>	150
4.2.7	<i>Void Properties</i>	150
4.2.8	<i>Operational Use and Water Taken Unbilled</i>	151
4.2.9	<i>Bulk Supplies</i>	152
4.2.10	<i>Re-basing the 2016/17 Figures</i>	152
4.3	POPULATION AND PROPERTIES	153
4.3.1	<i>Population</i>	155
4.3.2	<i>Occupancy</i>	160
4.3.3	<i>Properties</i>	163
4.4	HOUSEHOLD DEMAND FORECAST.....	163
4.4.1	<i>PCC</i>	164
4.4.2	<i>Water Use Survey</i>	164
4.4.3	<i>Integration of Behavioural Change</i>	165
4.4.4	<i>Micro-component Model</i>	166
4.4.5	<i>Overall Household Demand</i>	168
4.5	NON-HOUSEHOLD DEMAND FORECAST.....	168
4.5.1	<i>Methodology</i>	168
4.5.2	<i>Non-Household Forecasting</i>	171
4.5.3	<i>Potable Water Demand by Sector</i>	173
4.5.4	<i>Essex Demand</i>	176
4.5.5	<i>Suffolk Demand</i>	180
4.6	DRY YEAR FORECAST.....	185
4.6.1	<i>Introduction</i>	185
4.6.2	<i>Dry Year Data Analysis</i>	186

4.6.3	Dry Year Baseline Forecasts	188
5.	BASELINE WATER EFFICIENCY, METERING & LEAKAGE CONTROL	190
5.1	WATER EFFICIENCY.....	190
5.1.1	Water Efficiency Overview	190
5.1.2	Progress in AMP6 and Current Strategy	191
5.1.3	Every Drop Counts.....	191
5.1.4	Behaviour Change and Education.....	193
5.1.5	Water Saving Kits and Products.....	195
5.1.6	Affordability and Vulnerability.....	196
5.1.7	Research	196
5.1.8	Collaborating with Trusted Third Parties	198
5.1.9	Customer-side Leakage.....	198
5.1.10	Industry Sharing, Involvement and Recognition	199
5.1.11	Water Efficiency Strategy for the remainder of AMP6	200
5.1.12	Water Efficiency Strategy for AMP7	201
5.1.13	Drivers for Water Efficiency.....	201
5.1.14	What Customers Have Told Us.....	202
5.1.15	Our Commitment.....	202
5.1.16	Options Appraisal.....	203
5.1.17	Other Considerations for Water Efficiency in AMP7	204
5.2	METERING	205
5.2.1	Current Strategy	205
5.2.2	Customer Consultation.....	207
5.2.3	Overall acceptability.....	208
5.2.4	Vulnerability and meters.....	208
5.2.5	Reversion	209
5.2.6	Meter location	210
5.2.7	Reading and billing	211
5.2.8	Meter capability desired.....	211
5.2.9	Impact of meters on consumption	211
5.2.10	Limitations of metering for reducing consumption	212
5.2.11	Attitudes to compulsory metering.....	212
5.2.12	Changes to Draft WRMP metering strategy for 2020 – 2025.....	214
5.2.13	Overall impact of metering strategy on ESW Error! Bookmark not defined.	
5.3	LEAKAGE FORECAST	225
5.3.1	Background.....	225
5.3.2	Summary of Approach	225
5.3.3	Adoption of Consistency of Reporting Measures.....	225
5.3.4	SELL Review	227
5.3.5	Future Profiles of Annual Leakage	233
5.3.6	Innovations for Leakage Management	235
5.3.7	Benchmarking.....	236
5.3.8	Co-ordination of Mains Renewal and Burst Repair.....	236
6.	CLIMATE CHANGE.....	237
6.1	INTRODUCTION.....	237
6.2	VULNERABILITY TO CLIMATE CHANGE & METHOD SELECTION	238
6.2.1	Climate Change Vulnerability Assessment.....	238
6.2.2	Magnitude versus Sensitivity Plot.....	238
6.3	PR19 CLIMATE CHANGE ASSESSMENT METHOD	240
6.3.1	General Approach.....	240
6.3.2	Essex WRZ Surface Water Climate Change Assessment Method	241

6.3.3	<i>Suffolk Northern Central WRZ Surface Water Climate Change Assessment Method</i>	243
6.3.4	<i>Groundwater Climate Change Assessment</i>	244
6.4	PRESENTATION OF CLIMATE CHANGE ASSESSMENT RESULTS (SCENARIOS)	250
6.4.1	<i>Essex WRZ Surface Water Climate Change Assessment</i>	250
6.4.2	<i>Suffolk Northern Central WRZ Surface Water Climate Change Assessment</i>	252
6.4.3	<i>Suffolk Blyth and Hartismere WRZ Climate Change Assessment</i>	254
6.5	SCALING METHOD USED TO FACTOR IN ANY CLIMATE CHANGE THAT HAS ALREADY HAPPENED	254
6.6	ALLOWANCE FOR CLIMATE CHANGE IN THE HEADROOM ASSESSMENT	255
6.7	EFFECT OF CLIMATE CHANGE ON WATER RESOURCE ZONE SUPPLY	255
6.7.1	<i>Essex WRZ</i>	255
6.7.2	<i>Blyth WRZ</i>	256
6.7.3	<i>Hartismere WRZ</i>	256
6.7.4	<i>Northern Central WRZ</i>	257
6.8	EFFECT OF CLIMATE CHANGE ON DEMAND	257
6.8.1	<i>Background</i>	257
6.8.2	<i>Methodology</i>	258
6.9	IMPACT ON SUPPLY DEMAND BALANCE	259
6.10	CARBON EMISSIONS FROM CURRENT OPERATIONS	260
6.11	THE IMPACT OF OUR PLANNED ACTIONS ON CARBON EMISSIONS	261
7.	TARGET HEADROOM	267
7.1	BACKGROUND	267
7.2	METHODOLOGY	268
7.3	FORM OF OUTPUT – TREND CHARTS AND SENSITIVITY ANALYSIS	273
7.3.1	<i>Trend Charts</i>	273
7.3.2	<i>Sensitivity Analysis</i>	274
7.4	HEADROOM UNCERTAINTY RESULTS	275
7.4.1	<i>Headroom Uncertainty Results – Essex Resource Zone</i>	276
7.4.2	<i>Headroom Uncertainty Results – Suffolk Blyth Resource Zone</i>	278
7.4.3	<i>Headroom Uncertainty Results – Suffolk Hartismere Resource Zone</i>	280
7.4.4	<i>Headroom Uncertainty Results – Suffolk Northern Central Resource Zone</i>	282
7.5	SENSITIVITY ANALYSIS OF CLIMATE CHANGE	284
7.6	COMPARISON WITH 2009 PERIODIC REVIEW (PR09)	285
7.7	OPTIONS FOR REDUCING UNCERTAINTY IN PLANNING PERIOD	285
8.	BASELINE SUPPLY-DEMAND BALANCE	286
8.1	BACKGROUND	286
8.2	ESSEX RESOURCE ZONE	287
8.3	SUFFOLK BLYTH RESOURCE ZONE	288
8.4	SUFFOLK HARTISMERE RESOURCE ZONE	290
8.5	SUFFOLK NORTHERN CENTRAL RESOURCE ZONE	291
8.6	IMPACT OF CLIMATE CHANGE ON THE OVERALL SUPPLY DEMAND BALANCE	292
8.6.1	<i>Background</i>	292
8.6.2	<i>Essex Resource Zone</i>	293
8.6.3	<i>Suffolk Blyth Resource Zone</i>	294
8.6.4	<i>Suffolk Hartismere Resource Zone</i>	295
8.6.5	<i>Suffolk Northern Central Resource Zone</i>	296
8.6.6	<i>Summary</i>	297
9.	OPTION APPRAISAL	298

10. FINAL WATER RESOURCES STRATEGY	299
10.1 FINAL PLANNING SUPPLY DEMAND BALANCE	299
10.1.1 <i>Overview</i>	299
10.1.2 <i>Essex WRZ</i>	300
10.1.3 <i>Blyth WRZ</i>	302
10.1.4 <i>Hartismere WRZ</i>	303
10.1.5 <i>Northern Central WRZ</i>	304
10.2 WATER FRAMEWORK DIRECTIVE WATER BODY DETERIORATION RISK.....	305
10.2.1 <i>Background</i>	305
10.2.2 <i>Essex WRZ</i>	305
10.2.3 <i>Suffolk Blyth WRZ</i>	305
10.2.4 <i>Suffolk Hartismere WRZ</i>	306
10.2.5 <i>Suffolk Northern Central WRZ</i>	306
11. SENSITIVITY TESTING	308
11.1 OVERVIEW	308
11.2 SENSITIVITY TO SUSTAINABILITY REDUCTIONS	308
11.3 SENSITIVITY TO UNCONFIRMED NON-HOUSEHOLD DEMAND	310
11.3.1 <i>Essex Water Resource Zone</i>	310
11.3.2 <i>Blyth Water Resource Zone</i>	311
12. SUMMARY.....	314
12.1 SUMMARY.....	314
12.2 ANNUAL REVIEW OF THIS WATER RESOURCES MANAGEMENT PLAN.....	315
13. REFERENCES.....	316
APPENDICES.....	320
APPENDIX 1: FIGURES.....	320
APPENDIX 2: WATER RESOURCES PLANNING TABLES.....	323
APPENDIX 3: SECURITY INFORMATION.....	324
APPENDIX 4: ACRONYMS AND ABBREVIATIONS	325
APPENDIX 5: DEMAND MANAGEMENT OPTIONS APPRAISAL	326
APPENDIX 6: DEFINING DRY YEAR FACTORS TECHNICAL REPORT	327
APPENDIX 7: MICRO-COMPONENTS TECHNICAL REPORT	328
APPENDIX 8: POPULATION, HOUSEHOLD & PROPERTY FORECASTS	329
APPENDIX 9: STUDY OF WATER USE	330

1.0 INTRODUCTION



1.1 Overview

This document is our draft Water Resources Management Plan (WRMP). It has been prepared following the Water Resources Management Plan (England) Direction 2017 (Defra, 2017), Defra's Guiding Principles for Water Resources Planning (Defra, 2016) and the Environment Agency's Water Resources Planning Guideline (the WRPG) (Environment Agency, 2017a).

The WRPG requires the WRMP to demonstrate that we have an efficient, sustainable and secure supply of water over our chosen planning period which must be a minimum of 25 years. For this WRMP, we have prepared water demand and supply forecasts for a 40 year planning period from 1 April 2020 to 31 March 2060.

Our WRMP covers the entire Essex & Suffolk Water (ESW) customer supply area which includes parts of Norfolk (including the borough of Great Yarmouth), Suffolk, Essex and Greater London. Our supply area is illustrated in Figure 1 in Appendix 1. For the purposes of preparing our demand forecasts and supply demand balance calculations, we have split the supply area into the following Water Resource Zones (WRZ) which are also illustrated in Figures 2 and 3 in Appendix 1.

Table 1.1: ESW Water Resource Zones

Supply Area	Water Resource Zone
Essex	Essex WRZ
Suffolk	Blyth WRZ
	Hartismere WRZ
	Northern Central WRZ

Our supply areas are located within some of the driest areas of the country and as such face particular challenges including growing demand, uncertainty from climate change and a general lack of new intrinsic water resources. We have always fully embraced the concept of the ‘twin track approach’ to maintaining water supplies through a combination of demand management and water supply schemes and initiatives.

We pride ourselves on our track record of demand management and in delivering innovative water supply solutions such as the Langford Effluent Recycling Scheme and the Abberton Scheme, both of which are described within this WRMP. We have amongst the lowest levels of leakage in the UK and are an acknowledged industry leader in water efficiency and water conservation. Additionally, we are fully committed to achieving the maximum possible level of domestic meter penetration within an appropriate timescale and with our customer’s support.

Despite all the rigorous work on demand management, our PR09 WRMP recognised that a major water resource scheme was required in the Essex WRZ to meet the growing demand for water. We identified the Abberton Scheme as being the appropriate option for us to pursue during AMP5. The Abberton Scheme comprised three major elements, namely:

- iv. the upgrade of the Ely Ouse to Essex Transfer Scheme (EOETS) by way of two new pipelines and an upgrade to the pumping facilities;
- v. a variation to the abstraction licence at Denver in Norfolk from where water is transferred by the EOETS; and
- vi. the enlargement of Abberton Reservoir.

All works were completed in 2012 providing the Essex WRZ with a PR14 supply surplus through the planning period.

In this draft WRMP, all components of the supply and demand forecasts have been reviewed using the appropriate methods recommended in the Environment Agency’s (WRPG).

1.2 Regulatory Framework

This WRMP has been produced as part of a statutory process, as reflected in the Water Resources Management Plan Regulations 2007 and the Water Resources

Management Plan Direction 2017. Additionally, it has been produced with reference to the following guidance:

- Guiding Principles for Water Resources Planning, Defra, May 2016
- Water Resources Planning Guideline, Environment Agency, 2017

Additional detailed guidance and methodologies on specific aspects of the plan are referenced in relevant sections of this document.

This draft WRMP is supported by our Drought Plan (www.eswater.co.uk/droughtplan), which shows how droughts will be managed, what trigger levels will be used to identify when action is required, and what measures are available to support supplies when Levels of Service (LoS) are compromised.

As all four of our WRZs have a surplus of water across the full planning horizon to 2045, no new water resource options are required, negating the need for a Strategic Environmental Assessment.

1.3 Consultation

1.3.1 Pre-draft Water Resources Management Plan Consultation

We recognised the value of early communication with the many stakeholders potentially affected by and involved in the water resources planning process. We sent pre-consultation letters to statutory consultees and have:

- Written to all neighbouring water companies seeking their views on what should be included in our draft WRMP. Pre-draft WRMP consultation has also taken place through the Water Resources East (WRE) project and through the Ouse Working Group which are both attended by the East Anglian water companies;
- Held regular liaison meetings with the Environment Agency and Natural England, where different elements of the draft WRMP have been discussed;
- Presented to our Customer Challenge Group (known as the Water Forum) on different elements of the draft WRMP including leakage, metering, water efficiency, catchment management and drought management; and
- Presented to Ofwat and to the Consumer Council for Water.

Output from the above engagement has been taken into consideration in the development of this WRMP. As we were forecasting all of our WRZs to be in surplus, the key areas of feedback from the Environment Agency, Natural England and our Water Forum were in relation to development of our part of the Water Industry National Environment Programme (this was successfully agreed) and with regard to the level of our ambition for demand management options including metering, leakage reduction and water efficiency (see Section 5).

Direction from the Secretary of State was in the form of the Water Resources Management Plan Direction 2017.

1.3.2 Engaging our Water Forum in the development of our WRMP

When we started developing the draft WRMP, we presented sections and gave details to the ESW Water Forum.

The Forum then reviewed and discussed the draft WRMP and provided a number of challenges in their formal consultation response. At the Forum's Water Quality subgroup meeting on 28 June 2018, they discussed our response to the WRMP consultation responses made by the Environment Agency, Ofwat and the Water Forum and concluded that they were happy with what had been done.

1.3.3 Engaging our customers in the development of our WRMP

Our customers are at the heart of everything we do and every decision we make. We carry out an ongoing and comprehensive programme of bespoke activity around short-term, medium-term, and long-term strategic aspects of service, including operational service, inclusivity, charges and the future.

This section provides more information about the research, participation and engagement activities that have shaped our WRMP plan. Our plan is shaped upon insight derived from several of our qualitative and quantitative customer research and engagement projects into areas which influence water resource management and water efficiency. Our rationale for this approach is founded in our 'Defining the Conversation' and 'Communicating Risk' research projects, which took place in late 2016 and early 2017.

Defining the Conversation (2016 and 2017) explored what matters most to our customers about the services we provide and which areas of service they most want to influence. Our customers told us that we should engage with them to understand their views on customer service, value for money and trust. In regards to other areas of service, the majority viewpoint was that we should 'just deal with it', meaning that they trusted us to deliver the service, using our internal expertise without having to consult customers or external specialists. The areas of service participants most frequently stated we should 'just deal with' relate to water resource management and included 'supplying a reliable and sufficient supply of water' and 'providing clean, clear drinking water that tastes good'. Customers also told us that we should engage with other expert organisations when considering how to manage our performance in the wider environment.

Our Communicating Risk (2017) research was about engaging our customers around how they prefer probability, chance and risk to be communicated. We conducted this research for two reasons; firstly because we knew that some of our customers, who are less comfortable with numbers, struggle to interpret numerical presentations of risk. This includes the types of ratios typically used to indicate the likelihood of drought or appeal for restraint (e.g. a 1 in 200 year drought). During the research we presented participants with different numeric options (i.e. percentages, ratios, fractions, and visual formats) and asked them to order them from the most to least likely to happen. A considerable minority instantly switched off, perturbed by

their belief that they struggle with numbers. This disengagement impacts on the reliability of any data resulting from customer research into risk management.

Many customers have had no personal experience of water-related service failure, or know anyone who has. This means that they perceive the risk of experiencing a failure to be very low, especially for rarer events such as a drought or hosepipe ban. Customers who have experienced a more common water-related service failure, such as discoloured tap water, highway flooding or leakage from pipes in the street perceive a greater likelihood of these reoccurring. Hence, these more common service failures tend to be prioritised higher than addressing longer term strategic issues, such as water resource management.

Our Communicating Risk research findings supported the findings of Defining the Conversation in that participants told us that there are some complex aspects of service which they expect us to manage and plan for without the need for consultation. The most often cited areas of population increases, climate change and ageing infrastructure all relate to our approach to water resource management.

Over 2017 and 2018 we engaged our customers on water resource management options, as part of the shaping of our plan. Informed from our engagement and risk research findings we chose to concentrate on demand management options, rather than the more complex and poorly understood levels of service, such as hose pipe ban frequency. Our project explored the views of 831 of our customers' on leakage, metering, tariffs, consumption and preferences for managing the supply demand balance.

Participants were asked how they would allocate a £10 budget across five potential water resource management investment options, in order to understand their priorities.

1. Highest Priority	Build more reservoirs, water treatment works and pipes
2.	Reduce leaks
3.	Inform customers about water meters for optional meters
4.	Reduce consumption with compulsory water meters at all customers' homes
5. Lowest Priority	Install water meters whenever someone moves house

In addition to this research we have gone on an extensive journey to understand the views of our customers and have conducted several other projects which touch on elements of water resource management planning including:

- Trust & Value (2017)
- Service Measures (2017)
- Communicating Risk (2017)
- Behaviour change and funds (2017)

- Tariff Structures (2017)
- Resilience, Asset Health and Long-Term Affordability (2017)
- Long-Term Strategy Consultation (2018)

The key messages from customers, from these projects, which have influenced the design of our WRMP are:

Customer research finding	How the research influenced our WRMP
1. Increasing supply capacity is prioritised over demand management	We understand customers to be saying that they want us to plan ahead and develop new resources rather than pursue an aggressive demand management policy. We do not have a supply deficit in either operating area which requires us to invest in new water resources at this time. However, we do plan to reduce demand further in order to reduce the amount of water that is lost through leakage and also in the way it is used by customers. We want to respect what our customers have told us and our ambitions relating to water consumption are shaped accordingly.
2. Customers prefer water meters to be optional	We are introducing 'whole area metering' with opt-in measured billing to replace change of occupier metering.
3. Customers take individual responsibility for levels of water consumption but also expect us to do more to encourage water efficiency in future.	We commit to sustained gradual reductions in consumption which will enable us to put customer experience first. We will invest in both existing and new approaches to incentivise water efficiency.

More detail on metering, whole area metering, smart meters and options are included in the relevant sections of this report.

Our independent Water Forum, whose role it is to challenge us to always make sure we put our customers at the heart of our future plans and pricing, were updated on the development of our WRMP in November 2017. Members challenged the presentation of return periods, suggesting that percentage chance of restrictions would be much more meaningful (e.g. 5% chance in 20 years as opposed to a 1 in 20 year restriction). We noted in response that the use of return periods, expressed as annual ratio (e.g. 1 in 20 years) was explicitly required by DEFRA. Members also agreed that our proposed metering strategy was a good scheme.

These views have shaped our draft final WRMP, which is currently going through a final round of testing as part of our PR19 Acceptability Research. A representative sample of our customers are being given the opportunity to look at a summary of our whole PR19 Business Plan and to tell us whether or not they accept it. A section of the summary specifically relates to water resource management. Here participants can read about how from 2020 we will focus on:

- Improving how we can move water around our regions to reduce the chance of customers' water supplies being interrupted;
- Always making sure that local communities have sufficient water to meet their needs;
- Reducing the risks of hazards like climate change and extremes of weather impacting on our ability to maintain water services to customers;
- Increasing our ability to respond to and recover from long-term interruptions to the water supply which could impact up to 100,000 customers;
- We will continue to make sure that none of our customers are at risk of Level 4 supply restrictions in a 1 in 200 year drought;
- We will reduce interruptions to water supply lasting longer than 12 hours; and
- Offering our customers smart water meters.

Our customers are asked one 'killer question' to measure their acceptability of our whole business plan:

To summarise, in our proposed plan we will make improvements to the services you receive between 2020 and 2025, and will also reduce the risk of more serious problems happening in the future. Our plan is built on what customers have already said is important to them and will be delivered for a lower bill than you pay today.

On the basis of this information, do you accept Essex & Suffolk Water's plan?

Yes – I accept the plan

No – I don't accept the plan

Don't know

The acceptability research has not concluded at the time of preparing this summary, however initial results on acceptability are high.

1.3.4 Draft Water Resources Management Plan Consultation

We ran a public consultation on our draft WRMPs between Monday 5th March and Sunday 27th May 2018. The start of the consultation coincided with publication of the document on our website (<http://www.eswater.co.uk/wrmp>)

We invited the following statutory consultees to comment on this Plan:

- Ofwat
- Environment Agency
- Secretary of State (c/o Defra)
- Any Regional Development Agencies in the area covered by the Plan
- Any elected Regional Assembly in area of the Plan
- All local authorities in the area of the Plan
- The Broads Authority
- Natural England

- The Historic Buildings and Monuments Commission for England.
- Any navigation authority in the area of the Plan
- Thames Water Utilities (TWU)
- Anglian Water Services (AWS)
- The Consumer Council for Water

We also welcomed comments and representation from the wider community, including customers and other interest groups.

We have since reviewed the feedback received during the consultation and have prepared a Statement of Response (SoR) which details any changes we have made to the draft WRMP19 as a result of the feedback received during the public consultation. We will publish our SoR on our website on 31 August 2018. We will also submit our SoR and our draft final WRMP to Defra on 31 August 2018.

Subject to approval by the Secretary of State, our final Water Resources Management Plan will then be adopted and published in 2018/2019.

1.4 Reliable and Resilience Supplies

The importance we place on delivering reliable and resilient water supplies is demonstrated through our commitment to the following three customer outcomes:

- We are resilient and provide clean drinking water now and for future generations;
- We always provide a reliable supply of water; and
- Our drinking water is clean, clear and tastes good.

We have a strong track record in this area. This WRMP confirms we are very secure with a demonstrable supply surplus in each of our WRZs. It confirms we can provide resilient water supplies for customers without harming the environment, over a minimum of a 40-year horizon, even during a severe drought with a 1 in 200 year return period.

We are not complacent about the future and we have created a Resilience Framework that cuts across the entire business, encompassing corporate, financial and operational resilience, so that we are able to consider and address 'resilience in the round'. Our new Chief Resilience and Sustainability Officer will be responsible for managing this framework, and will lead our partnership approach to support and build regional resilience.

Even in areas where we are very resilient, we will go above and beyond so our customers can have trust in our resilience position. Our ambitious goals for reliable and resilient services are to:

- Have the lowest levels of leakage in the country;

- Have a PCC for water use in our regions of 118 litres per person per day by 2040;
- Promote confidence in our drinking water so that nine out of ten of our customers choose tap water over bottled water;

Our customers research confirms that they support us investing in resilient networks and planning ahead for impacts such as from climate change, regional population growth and major incidents impacting the operation of our sites and networks. They also expect our systems to have connectivity and back-up. However, they also understand that we cannot remove all risks (Resilience, Asset Health and Long Term Affordability, 2018). Nevertheless, they do expect us to plan for the future by updating and modernising our infrastructure and systems, and to learn from past events and to put in place the right strategies to prepare for similar events in the future.

To further increase resilience, in addition to the demand management options (see Section 5) and catchment management schemes (see Section 3.4) included in our final plan, we will improve the interconnectivity and transfer capability across our strategic raw and potable water networks. Following our appraisal of risks and current system resilience across our water service, we have identified a number of discretionary investment schemes which start to address this and deliver customers improvement to the reliability and resilience of their water service.

We will:

- Improve treatment capability at Layer water treatment works to manage annual fluctuations in water quality which we have experienced since the expansion of Abberton reservoir. This will directly benefit over 100,000 properties, while also providing a more reliable secondary source of supply to some of the 300,000 properties supplied from our water treatment plant at Hanningfield;
- Increase the resilience of our raw water transfer capability between Abberton and Hanningfield reservoirs. This will allow us to move raw water across our networks, so that we can fully use the resource capacity of Abberton, and will directly benefit over 400,000 properties. It will also enable more effective abstractions, help maintain abstraction licence compliance and allows us to meet demand resulting from forecasted future population growth in North Essex without the need for any additional treatment capacity at our existing sites.
- Provide a secondary point of supply to 110,000 properties currently supplied from a single trunk main at Herongate service reservoir, Essex;
- Construct new storage capacity and improve the interconnectivity of our North Suffolk network to give 90,000 properties in Great Yarmouth, Lowestoft and North Suffolk an alternative source of supply in the event of a failure or reduced capacity at one of the three treatment works supplying this area;
- Improve overall site and system resilience to natural and manmade hazards at 25 of our water sites deemed as 'too critical to fail'. This will reduce the

likelihood of a large loss of supply event, and benefit more than 495,000 properties in total.

1.5 Innovation

Our customer research has shown us that customers expect the quality of the services they receive to continually improve. They do not have specific views on how we should innovate, but they expect us to be forward looking and to ‘move with the times’.

Our customers also expect innovation to deliver better value for money and less waste. They expect us to be able to measure how good we are at innovation and the impact it is having. As part of our openness, we will publish information on our innovations and will track the changes in our performance that arise from the new activities we undertake.

For AMP7 (2020 to 2025), we have set ourselves an ambitious innovation goal which is to **“be leading in innovation within the utilities sector and beyond”**.

We already innovate openly, working with partners from across a multitude of sectors. This is exemplified by our widely-acclaimed Innovation Festival (<https://innovationfestival.org/>) hosted by our parent company, Northumbrian Water Group (NWG). This attracted 1,000 people from across the country and from 140 different organisations in its first year and was even bigger in 2018. We have also established an external Innovation Panel to challenge and support us in developing our Innovation Strategy, which brings together innovation leaders from within and outside the industry.

We use data hacks to help us to find solutions to data-rich problems. Data scientists with fresh eyes use novel tools and techniques to consider challenging questions. We also work with universities and technology companies to provide data and subject matter expertise.

We will continue to build on and invest in our capabilities, leveraging our connections within our shareholder group to promote innovation within our region and beyond.

In this WRMP, we have set out how we will reduce our leakage by 17.5%, how we will start to use smart metering and how we will help our customers to be more water efficient. Further details of how we will innovate and use technology to reduce demand is set out in Section 5 of this report.

1.6 Our Approach to Assurance

We have used a three line of defence model for assurance, similar to that used for our other regulatory returns. Each piece of data has been provided by someone of appropriate skill and experience and has been peer reviewed.

The key approach, assumptions and strategy have been approved by key directors (principally the former Water Director and the Assets and Assurance Director) a summary paper which included a high level approach and strategy was approved by the Board.

In addition to the above, external assurance and consultancy was sought in areas of highest risk. Edge Analytics were used to calculate the population and property forecasts which is key data underpinning much of the plan.

PwC were our principal external assurance provider, and were engaged to provide the principal assurance over our WRMP. Their scope included:

- Gaining an understanding of the overall approach to the production of the WRMP;
- Gaining an understanding of the detailed underlying processes and assumptions made which were then used to prepare the WRMP;
- Tracing a sample of these non-financial and investment data points to a mix of source documentation and the outputs of detailed calculations and models;
- Testing a sample of inputs into the calculations and models by tracing these back to source systems and documentation;
- Performing a critical strategic assessment of the WRMP, specifically assessing the content against the requirements and guidance published by Defra and the Environment Agency; and
- Assessing the extent to which the data in the WRMP has been accurately extracted into the Water Resource Market Information data tables.

Any recommendations made have been incorporated into the Plan.

Our approach to assurance is described in *Our Assurance Plan 2018/19*. The plan identifies areas of risk and planned assurance activity in 2018/19. The PR19 is identified as a risk, and the WRMP have been produced and assured in line with the PR19 process. Given the critical importance of PR19, the Board has formed a dedicated Board Sub-Group to provide integrated support to both the Board and management in driving forward and assuring preparation of our PR19 plan. The Board Sub-Group has overseen the production and assurance of the WRMP.

1.7 Water Resources Plan Structure

Subsequent sections of this draft WRMP are as follows:

Section 2 Background Information: This section provides background information including a description of each of our WRZs, progress made in implementing our 2015 WRMP, confirmation of the base year and planning period and confirmation of our position regarding the trading of surplus water resources.

Section 3 Water Supply: This section presents the results of the Deployable Output (DO) assessments and describes how DO has been calculated for each source and

WRZ. Additionally, it describes reductions in DO, treatment works process losses and outage allowances.

Section 4 Water Demand Forecasts: This section presents the results of the demand forecast and describes in detail the method used to prepare the forecast.

Section 5 Water Efficiency: This section covers our full and ongoing commitment to demand management and covers water efficiency, metering and leakage.

Section 6 Effects of Climate Change: This section presents the results of the climate change assessments and describes the methodology used. The assessments consider the effect of climate change on both baseline supply and demand.

Section 7 Target Headroom: Target headroom is a buffer between supply and demand designed to cater for specified uncertainties. This section presents the results of the target headroom assessment and describes the method used to undertake the assessment.

Section 8 Baseline Supply Demand Balance: This uses the supply and demand data from the previous sections to prepare a supply demand balance graph for each WRZ. These graphs are then used to identify whether there is likely to be a supply deficit at any point across the planning horizon.

Section 9 Options Appraisal: This section would normally cover an appraisal of all supply and demand options that would be required to ensure there is a supply surplus in each WRZ over the planning horizon. However, our baseline supply demand balance confirms all four WRZs are in surplus over the whole planning horizon and so an options appraisal is not required.

Section 10 Final Water Resources Strategy: This section confirms our final water resources strategy.

2.0 BACKGROUND INFORMATION



2.1 Water Resource Zones

2.1.1 Background

We have geographically separate supply areas, known as the Essex supply area and Suffolk supply area (Figure 1, Appendix 1). Water is supplied to approximately 1.65 million customers in the Essex supply area and 0.27 million customers in the Suffolk supply area.

In line with the Water Resources Planning Guidelines (WRPG), our Water Resources Management Plan (WRMP) is based on assessments undertaken at a Water Resource Zone (WRZ) level. The definition of a WRZ (from Water Resources Planning Tools (WR27), UKWIR, 2012a) is:

The largest possible zone in which all resources, including external transfers, can be shared and hence the zone in which all customers will experience the same risk of supply failure from a resource shortfall.

We have four WRZs, one in Essex (the Essex WRZ) and three in Suffolk known as the Blyth, Hartismere, and Northern Central WRZs. Schematic diagrams of the

WRZs and associated infrastructure are shown in Figures 2 and 3 in Appendix 1 for Essex and Suffolk respectively.

None of our WRZs have changed from those last reported to the Environment Agency. The resource zones used for water resources planning purposes are described below.

2.1.2 The Essex Water Resource Zone

The Essex WRZ (see Figure 2, Appendix 1) is bounded by the Thames Estuary in the south and the Essex coastline up to Salcott in the east. The WRZ stretches as far north as Silver End and as far west as the London Boroughs of Redbridge, Barking and Havering. The WRZ includes the towns of Southend-on-Sea, Chelmsford, Witham, Brentwood, Billericay, Basildon, Grays, Dagenham and Romford.

The intrinsic water resources include the rivers Chelmer, Blackwater, Stour and Roman River, which support pumped storage reservoirs at Hanningfield and Abberton, and treatment works near Langford, Langham, Hanningfield and Layer. The remaining water sourced from inside the Essex WRZ (approximately 2% of total water supplied in the zone) is derived from groundwater via Chalk well and adit sources in the south and south west of the zone near Stifford and Roding.

Water transferred into the Essex supply area comes from two sources, namely the Chigwell raw water bulk supply from Thames Water Utilities (TWU) Lea Valley Reservoirs and the Ely Ouse to Essex Transfer Scheme (EOETS).

Of the potable water supplied in the Essex WRZ, approximately 20% is provided via the Chigwell raw water bulk supply. The raw water is pumped directly to our treatment works for treatment and then into distribution.

In a dry year, flows in the River Stour and River Blackwater can be supported by the EOETS which is owned and operated by the Environment Agency. Raw water is transferred via pipelines and pumping stations, from Denver in Norfolk to the headwaters of the River Stour and River Blackwater (see Figure 1, Appendix 1).

Additionally, in dry periods the Environment Agency may operate its groundwater river support schemes, particularly when transfers via Denver are limited or not possible. The two schemes with potential to support river flows in Essex are the Stour Augmentation Groundwater Scheme (SAGS) and the Great Ouse Groundwater Scheme (GOGS).

The Essex rivers and their associated intakes, the pumped storage reservoirs near Abberton and Hanningfield, and associated raw water transfer pipes, pumping stations and treatment works are collectively known as the 'Essex System'. This reflects the nature of the supply network in Essex which is a highly integrated one, with a large degree of flexibility for moving raw and potable water around the zone to where it is required.

The preferred mode of operation of the Essex treatment works during the summer is for Langham, Langford, Layer and Chigwell treatment works to provide a reasonably constant base-load, with output from Hanningfield treatment works varying to meet the remaining demand.

At the end of 2003, we completed works to construct an innovative effluent recycling scheme near Langford. The Scheme intercepts effluent from Chelmsford Sewage Treatment Works and treats it to a very high standard at a purpose built treatment plant near Langford. Once treated, the water is discharged into the River Chelmer 3km upstream of our abstraction intake where it augments the natural flow. It is then available for re-abstraction via existing intakes supporting both Langford treatment works and storage into Hanningfield Reservoir. The Scheme can provide up to an additional 20 MI/d of water during May to November for use within the Essex System during dry periods.

2.1.3 Suffolk Blyth Water Resource Zone

The Blyth WRZ (see Figure 3, Appendix 1) is bounded by the Suffolk coastline in the east stretching from Aldeburgh in the south to Walberswick in the north. The WRZ stretches as far west as Earl Soham, and as far north as Chediston, and includes the towns and villages of Saxmundham, Leiston, Framlingham, Peasenhall and the southern side of Halesworth. The Blyth WRZ is predominantly rural in nature.

All the water supplied within the Blyth WRZ is sourced from groundwater via Chalk and Crag boreholes.

2.1.4 Suffolk Hartismere Resource Zone

The Hartismere WRZ (see Figure 3, Appendix 1) is bounded to the north by the River Waveney, from its source at Redgrave in the west, to Mendham in the east. The zone stretches as far west as Rickingham and Wyverstone Street, and as far south as Mendlesham Green and Aspell. The WRZ includes the town of Eye, situated on the River Dove, a major tributary of the River Waveney. The Hartismere WRZ is also predominantly rural in nature and the landscape is characterised by arable farming.

All the water supplied within the Hartismere WRZ is sourced from groundwater abstracted from Chalk and Crag boreholes. It should be noted that Syleham Treatment Works is located within the Hartismere WRZ although receives a raw water import from boreholes located in the Northern Central WRZ.

The Hartismere WRZ was particularly affected by the 1995 -1997 drought. As a result, we made a large number of improvements in the zone, including the commissioning of new groundwater sources near Bedingfield and Syleham, and network improvements to enable water to be more easily transferred around the WRZ.

2.1.5 Suffolk Northern Central Water Resource Zone

The Northern Central WRZ is bounded by the River Waveney and River Bure to the west, and the Suffolk coastline from Southwold to Winterton-on-Sea in the east. The WRZ includes the towns of Lowestoft, Great Yarmouth, north Halesworth, Bungay and Beccles. Demand in the WRZ is heavily influenced by the large population centres of Lowestoft and Great Yarmouth.

Approximately 70% of the water supplied in the Northern Central WRZ is sourced from surface water, and 30% sourced from groundwater in the south of the WRZ.

Surface water is provided via four sources, namely the River Waveney near Beccles, the River Bure near Wroxham, and groundwater fed lakes called Ormesby Broad, and the Lound Ponds and Fritton Lake. Water from the River Waveney is treated at Barsham River treatment works, water from the River Bure and Ormesby Broad is treated at Ormesby water treatment works (WTW) and water from Lound Ponds and Fritton Lake is treated at Lound treatment works.

A smaller component of raw water from groundwater can be sourced from remote Chalk groundwater sources near Wroxham in the north of the WRZ, which is treated at Ormesby WTW. Larger quantities of groundwater produced in the south of the WRZ are sourced from Chalk groundwater sources near Halesworth, Holton and Beccles and Crag and Gravel wells near Southwold and Broome respectively.

The Northern Central WRZ is named to reflect the fact that historically it effectively operated as two 'sub-zones' called the Northern WRZ and the Central WRZ, although it is no longer appropriate to consider these as separate resource zones. The Northern 'sub-zone' contains Ormesby treatment works and Lound WTW, whilst the Central 'sub-zone' contains Barsham treatment works and all the groundwater sources, except those near Wroxham.

2.2 Water Resource Zone Integrity

The WRPG states that WRMPs should be built up of assessments undertaken at a WRZ level. The WRZ describes an area within which the abstraction and distribution of supply to meet demand is largely self-contained (with the exception of agreed bulk transfers).

Within a WRZ, all parts of the supply system and demand centres (where water is needed) should be connected so that all customers in the WRZ should experience the same risk of supply failure and the same level of service for demand restrictions. The WRPG accepts that there will be limitations to achieving these due to the specific characteristics of a distribution network but significant numbers of customers should not experience different risks of supply failure within a single WRZ. We undertook a Water Resource Zone Integrity Assessment as part of our 2019 Periodic Review (PR19) WRMP.

For all of our WRZs, treated water transfers can be made between Distribution Zones (DZ) within the respective WRZ. If there is a supply deficit within a DZ, this can be balanced by an internal transfer from a neighbouring DZ and/or by substitution from other DZs within the WRZ. These intra-WRZ transfers are physically made by opening DZ boundary valves or by pumping. Consequently, a supply shortfall in one DZ can be made up from other DZs within the WRZ. Given the above, our initial assessment concluded that all of its WRZs meet the WRZ definition.

The assessment, which was accepted by the Environment Agency, concluded that all WRZs met the UKWIR and Environment Agency definition.

We reviewed and updated our PR14 WRZ Integrity Assessment in February 2017 and submitted it to the Environment Agency. The update followed the Environment Agency's 2016 guidance entitled, "WRZ assessment methods (Water Resource Zone Integrity)".

Our PR19 assessment concluded that there have been no significant changes to the infrastructure in the Essex, Blyth and Hartismere WRZs and so they remain compliant with the WRZ definition. A new scheme called the 'Lound to Gorleston Pumping Station and Pipeline' is currently being implemented in the Northern Central WRZ and will be operational in 2018/19. This means that the Northern Central WRZ will also fully comply with the WRZ definition.

2.3 Progress with Implementing the 2015 Water Resources Management Plan

The 2015 WRMP did not contain any supply side options as a supply surplus was maintained in all four WRZs across the full planning horizon.

Our AMP6 National Environment Programme (NEP) obligations will be fully met by 31 March 2020. Progress with the delivery of the AMP6 NEP is presented in Section 3.8 while progress with our leakage, metering and water efficiency programmes are presented in Section 5.

2.4 Sharing Surplus Water Resources

2.4.1 Background

We prepared WRZ supply demand balance calculations in early 2017. These showed that whilst the three Suffolk WRZs were likely to all be in surplus of supply to demand over the planning horizon, there were not sufficient surpluses to make sharing with a neighbouring water company, even for a limited period, a viable option. The Essex WRZ had a small surplus supporting a trade of 5 MI/d until 2035. This increases to 25 MI/d from 2036 when a 20 MI/d bulk supply agreement with Thames Water comes to an end.

In accordance with the WRRPG (Environment Agency, 2016a) we wrote to neighbouring water companies to confirm what volumes could be potentially available for sharing (i.e. trading) with other water companies.

As with previous periodic reviews, we have held discussions with regional companies including Thames Water, Anglian Water Services, Affinity Water and Cambridge Water either directly or through the Water Resources East (WRE) project (see section 2.5 below) or the Ouse Working Group.

No water companies have asked us to formally progress agreements to trade water. However, we will continue to explore trades both directly with other water companies and through WRE.

2.5 Water UK Water Resources Long-term Planning Framework

The primary aim of this project was to develop a strategy and framework for the long-term planning of water resources at a national level, and in doing so to assess the long-term water needs and the available options to meet them.

The project considered droughts worse than those within the historic record and worse than current levels of service plan for. It looked ahead 50 years and undertook new modelling of droughts, assessed climate change impacts and provided conclusions on the national scale resilience of water supplies.

The project:

- i. Took a sector-wide view of future resilience and options for improving that resilience;
- ii. Assessment of variation in levels of service and potential minimum levels of service for customers and the environment, accounting for costs and benefits at a national, regional and sub-regional level, which includes the wider social impacts of drought and drought resilience;
- iii. Exploration of opportunities to integrate investment (WRMPs) & operational management (Drought Plans);
- iv. Qualitative identification of potential implications of drought failure on other sectors Identification of the potential barriers that are represented by current and future arrangements that might exist between water companies, including potential trading arrangements, the implications of competition etc.
- v. Identification of the likely nature of resilience infrastructure and preferred levels of service to inform discussions relating to national infrastructure planning and the development of a national policy statement on water resources.

The study concluded that:

- i. There is a significant and growing risk arising from drought, climate change, population growth and sustainability reductions;
- ii. There is a strong case for government to promote a consistent national minimum level of resilience for water resources;
- iii. There is an economic benefit of increased resilience because the investment needed to increase resilience is 'modest' compared to the potential reactive costs to drought and flood;
- iv. Companies should continue to seek a twin-track approach which includes demand management and supply enhancement including transfers between companies; and
- v. There is a strong case for 'adaptive planning' to support company WRMPs. While individual companies will need to make investment in the next 25 year planning period, nationally, 2040 and 2065 were identified as key points in time to make investment.

The report considered Essex & Suffolk Water within a group called South East (Anglian sub-region). For this group, the report concluded that there is currently some supply/demand surplus in this sub-Region (i.e. our Essex WRZ), but this could be eroded by growth over the time horizon if current planning assumptions are maintained. The risk to resilience as a result of the need to tackle potentially unsustainable abstraction is significant and immediate. Since the report was published, we have developed our final plan demand management options. These maintain a surplus across the planning period. We continue to be in discussions with neighbouring water companies regarding potential trades. These will continue with progress being reported through the WRMP Annual Reviews. The reports conclusion that the group is at risk of sustainability reductions still applies. AMP7 NEP investigations may well result in sustainability reduction which could cause a supply deficit in our Blyth and Hartismere WRZs. This being the case, we would need to identify schemes with WRE to bring the WRZs back into surplus.

2.6 Regional Water Resources

2.6.1 Regional Overview

Although our WRZs are in surplus through to the end of the planning period, eventually new water resources will need to be developed for all areas. Operating in the driest part of the country, with increasing demands on current supplies of fresh water and the potential for sustainability reductions being applied to our abstraction licences, we recognise that "new" water for potable supplies will be difficult to come by. We also recognise that in the future, it is going to be more economically viable and politically acceptable to develop joint regional water resource schemes that benefit a number of water companies and, most probably, other abstractors.

For some East Anglian region water companies, supply-demand deficits by 2060 will become more widespread, the deficits being driven by growth, climate change and sustainability reductions to abstraction licences. In response, connectivity in supply systems may have to be increased, more trading of resources may be required along

with the development of new supplies. Most demand management initiatives will have been completed by 2060. Since there are no resources available for year-round direct abstraction, options for developing these will be limited to winter storage reservoirs, water reuse schemes and aquifer storage and recovery. All of these have high CAPEX, OPEX and carbon requirements.

We share the ambition of government and regulators that greater focus be given to regional water resource planning through bodies such as WRE. We are determined to play a leading role in this process and to ensure that a fully integrated regional planning approach is adopted for the 2024 planning cycle.

2.6.2 Water Resources East



WATER RESOURCES EAST

Given the above, the WRE project was setup with the mission to work in partnership to safeguard a sustainable supply of water for the East of England, resilient to future challenges and enabling the area's communities, environment and economy to reach their full potential. The WRE project brings together partners from a wide range of industries, including water, energy, retail, the environment, land management and agriculture, who are working collaboratively to manage these challenges, building on the area's unique opportunities for sustainable future growth and pioneering a new approach to managing water resources.

The goal of the WRE project is to develop a long-term, multi-sector water resource strategy for the East. The vision is for an integrated strategy, with trade-offs between industry sectors that will balance the needs of all partners.

The project has delivered a baseline vulnerability assessment for the region. This highlights that by 2080, water supplies in some parts of the region will be vulnerable due to:

- The impact of climate change on hydrological flows and groundwater levels;
- Growth in customer demand; and
- Sustainability reductions applied to abstraction licence licensed quantities.

The project has also used modelling techniques called Robust Decision Making (RDM) and Multi-criteria Search (MCS) to identify a potential investment portfolio that will deliver water supply resilience to all sectors in the region. A plausible set of future scenarios has been developed allowing investment portfolios to be tested. These comprised different combinations of demand forecasts and supply-side options and each have been assessed on the basis of their performance against criteria designed to reflect the priorities of water companies, other industries (agriculture and power generation), regulators, customers and the environment.

We fully support the WRE project both now and in the future. We operate in a water stressed area and so have welcomed the opportunity to work collaboratively with a

wide range of industries to develop a long-term, multi-sector water resource strategy for the East.

The baseline vulnerability assessment has highlighted that the resilience of water supplies, for example, in the county of Suffolk, could be vulnerable to future droughts by 2060. This is partly because of the reliance of the county on groundwater supplies from the Chalk and Crag aquifers and the likelihood that abstraction licences could be subject to reductions in annual licensed quantities to ensure they are sustainable. The sustainability of our Suffolk groundwater abstraction licences will be investigated in AMP7 (2020 to 2025) as part of the Water Industry National Environment Programme (WINEP).

The WRE project has identified an early investment portfolio based on its performance across a wide variety of different futures and so aims to increase multi-sector water resource resilience across the region. However, as we have a supply surplus in all four of our water resource zones, we do not have a requirement to develop new supply schemes. In Suffolk, the size of the supply surplus precludes any trading of water. In Essex, the supply surplus is not big enough to allow us to make large exports (>5 Ml/d) of raw or treated water to other companies until 2035.

Nevertheless, we recognise that in the future, there may be schemes that do involve our water supplies but that do not impact on our DO or our own resilience. When such schemes are developed, we will consider them in future WRMPs. We also note that if sustainability changes are applied to Suffolk groundwater abstractions in AMP7, this could cause a supply deficit. We will therefore consider any options to eliminate such a supply deficit with the WRE project.

2.6.3 Water Resources South East

The Water Resources in the South East Group (WRSE) is an alliance of six south east water companies, the Environment Agency, Ofwat, Consumer Council for Water, Natural England and Defra. The Group's aim is to develop a regional water resources strategy which will contain a range of options to find the best long term solutions for securing water supplies for customers and the environment in the south east of England. As with WRE, we fully support the WRSE alliance and will work with it to meet its aims.

2.7 Planning Period and Base Year

The statutory planning period for WRMPs is a minimum of 25 years, from 1 April 2020 to 31 March 2045. However, the WRPG encourages water companies to plan over a longer planning horizon. For the purposes of this Plan, the planning period is for 40 years from 2020 to 2060.

The base year for supply/demand data is 2016/17, as this was the most recent year we had out-turn data for, and is also in line with the WRPG.

2.8 Planning Scenarios

The baseline and final plan supply forecasts for each WRZ are based on a ‘dry year’, which is defined by the worst historical drought in the record used for planning. The worst historical drought years are described in section 2.9.1.

The WRPB also requires water companies to provide a supply and demand forecast for each WRZ for a drought with a return period of 1 in 200 years. These are presented in section 3.3 for the Essex system, 3.5 for the Waveney and Bure area and section 3.7 for groundwater sources. Table 2.1 outlines the methodology used to assess the impact of a 1 in 200 year return period drought. Due to variation between the characteristics and data coverage of different WRZs, a combination of methods have been used.

Table 2.1: Approach used for assessing the impact of a 1 in 200 year return period drought

Water Zone	Resource	Approach Used & Justification	
Essex WRZ - Essex System		Approach	Aquator Scottish Method – the behavioural model is run multiple times with incrementally increasing demand, and counts the number of failure years in the analysis period for each demand. The return period for each number of failure years is calculated based on the total record length, and a linear relationship between the demand and return period is established.
		Justification	There is a behavioural model for the Essex System. The parameters in the rainfall-runoff models for the Essex System need to be reviewed before the models can be used to create stochastic flow sequences from weather generator data.
		Result	For a 1 in 200 year return period drought, the result was a DO of 391 MI/d, a 1 MI/d increase from baseline DO.
Northern Central WRZ - River Bure Intake		Approach	Stochastic weather generator rainfall and potential evapotranspiration (PET) data from the Water Resources East (WRE) project was run through the Northern East Anglia Chalk (NERC) model to develop a River Bure flow series for a 1 in 200 year drought. A spreadsheet analysis of the flow data was carried out to determine daily abstraction potential and calculate a DO for the River Bure.
		Justification	There is no behavioural model for the Northern Central WRZ. The spreadsheet analysis approach is consistent with the baseline DO assessment for the River Bure intake.
		Result	The DO results at 22.84 MI/d and 22.89 MI/d are higher than the 17.84 MI/d baseline DO.

Water Zone	Resource	Approach Used & Justification	
Northern WRZ - Waveney Intake	Central River	Approach	Stochastic weather generator rainfall and PET data from the WRE project was run through the NERC model to develop a River Waveney flow series for a 1 in 200 year drought. The flows were run through the River Waveney Aquator model to obtain a DO value.
		Justification	There is a behavioural model for the River Waveney System, but not for the whole Northern Central WRZ.
		Result	The stochastic flows produced the same DO as the baseline, indicating that a 1 in 200 year drought would not constrain resource from the River Waveney.
Northern WRZ - Broad, Fritton Lake & Lound Ponds	Central Ormesby	Approach	No drought assessment carried out.
		Justification	There is no water balance model for these systems, so it is hard to assess water levels for different scenarios. The baseline DO is based upon utilisation of the abstractions during the worst historical drought, which is estimated to have a return period greater than 1 in 200 years (section 2.9.1).
All WRZs - Groundwater Sources		Approach	Stochastic weather data was run through the Environment Agency regional groundwater model to model water levels in groundwater sources.
		Justification	This is the standard method for modelling water levels in groundwater sources.
		Result	All groundwater sources were found to be resilient to a 1 in 200 year drought, with no decline in DO. Only one source was an exception, which showed a reduction from 3.4 MI/d to 1.95 MI/d.

The following planning scenarios are included in this WRMP:

- Dry year annual average daily demand forecast (baseline);
- Dry year annual average daily demand forecast (final plan); and
- Normal year annual average daily demand forecast (baseline).

Our assumptions regarding the impacts of climate change on both Water Available for Use (WAFU) and demand are described in section 6.

Operational experience has indicated that critical period scenarios such as those based on Average Day Peak Week (ADPW) are not appropriate for the Essex and Suffolk WRZs as none are significantly peak constrained from a water resources perspective. In the case of the Essex WRZ, peaks can be absorbed due to the integrated nature of the supply network and the storage provided by the two large pumped storage reservoirs. Similarly, in the Suffolk Northern Central WRZ, the

flexibility over utilisation of the three main surface WTWs at Lound, Barsham and Ormesby provides a buffer to impacts from peak demands. Subsequent to the 1995-1997 drought, significant investment was made in network improvements and enhancement of security of supply within the groundwater fed zones of Hartismere and Blyth. This effectively removed any residual peak/critical period concerns, and hence no ADPW or similar peak scenarios are presented in this WRMP.

2.9 Problem Characterisation and Risk Composition

2.9.1 Drought Analysis

Rainfall data for critical historical droughts known to have affected our supply areas, namely the 1920s and 1930s droughts in the Essex WRZ and the 1990s drought in the Suffolk WRZs, has been analysed to determine the return periods of the droughts.

Methodology based upon papers published by the National Climate Information Centre (Allen, 2012) and in the Meteorological Office Scientific Paper No. 37 (Tabony, 1977), was followed. Monthly rainfall totals for a 5-year period containing the known drought were obtained, and monthly long-term rainfall averages for the 1961-1990 period were calculated. 1961-1990 climatology was used as it was approximately 5% drier than for the 1981-2010 period, so would provide a more conservative estimate. A rainfall deficit for each month in the analysis period was calculated relative to the long-term average, and then summed to obtain a series of cumulative deficits.

Plotting the cumulative deficit series allows a window of analysis to be identified. An example for each drought is provided in Figures 2.1-2.5, in which an arrow indicates the window used for dry period analysis.




Figure 2.1: Monthly cumulative rainfall deficits for the 1920s Essex WRZ drought




Figure 2.2: Monthly cumulative rainfall deficits for the 1930s Essex WRZ drought




Figure 2.3: Monthly cumulative rainfall deficits for the 1990s Blyth WRZ drought




Figure 2.4: Monthly cumulative rainfall deficits for the 1990s Hartismere WRZ drought




Figure 2.5: Monthly cumulative rainfall deficits for the 1990s Northern Central WRZ drought

For dry periods lasting one month or more, it is suggested to use Tabony tables for extreme value analysis. The cumulative rainfall and cumulative long-term average rainfall is calculated throughout the analysis period, and the percentage of the cumulative rainfall in relation to the cumulative long-term average rainfall is calculated for each month. The Tabony table for the Anglian region, which identifies the percentage of long-term average rainfall corresponding to a given return period, was used to estimate a return period for a range of drought durations (Table 2.2).

Table 2.2: Tabony table for the Anglian region (Allen, 2012)

Return periods of dry spells	6 months	12 months	18 months	24 months	36 months	48 months
1 in 5	82	87	89	91	92	93
1 in 10	73	80	84	86	88	90
1 in 20	66	75	79	82	85	87
1 in 50	58	69	74	78	81	84
1 in 100	53	66	71	75	79	81
1 in 200	49	62	68	72	77	80

The return periods quoted in the table are determined from 1961-1990 long-term averages for areal averages of precipitation within the Anglian region, and the return periods are for rainfall of n-month duration starting in any month. Comprehensive uncertainties have not been determined for the return period estimates, but they will be high for the multi-century return periods, which should be viewed as indicative only. Therefore, the return periods are disaggregated into broad categories, and the tables do not specify return periods beyond 200 years.

Results

Essex WRZ

Start month: November 1920		Start month: December 1932	
Duration	Return period (years)	Duration (months)	Return period (years)
6 months	40	6 months	40
12 months	>200	12 months	50
18 months	>200	18 months	>200
24 months	85	24 months	>200
36 months	200	36 months	50

Blyth WRZ

Start month: November 1995	
Duration	Return period (years)
6 months	60
12 months	>200
18 months	>200
24 months	>200
36 months	30

Hartismere WRZ

Start month: August 1995	
Duration	Return period (years)
6 months	25
12 months	>200
18 months	165
24 months	85
36 months	15

Northern Central WRZ

Start month: November 1995	
Duration	Return period (years)
6 months	125
12 months	200
18 months	200
24 months	>200
36 months	35

The results show that, for Essex WRZ, the 1920-1922 drought has a return period of greater than 1 in 200 years for the 12-month and 18-month durations. A separate analysis of this drought has estimated that this event has a return period in excess of 1 in 250 years, as outlined in section 2.14.2. The 1932-1934 Essex drought has a return period of greater than 1 in 200 years for the 18-month and 24-month durations. In Suffolk, the 1995-1997 drought has a return period in excess of 1 in 200 years at the 12-month duration in Hartismere WRZ, the 24-month duration in Northern Central WRZ, and the 12- to 24-month durations in Blyth WRZ.

2.9.2 Problem Characterisation

The Problem Characterisation process requires water companies to assess the vulnerability of each of their WRZs to various strategic issues, uncertainties, and risks. We completed our problem characterisation assessment in 2016 and submitted the resulting report to the Environment Agency. The assessment was completed following the method outlined in the 2016 UKWIR report entitled 'WRMP19 Methods – Risk Based Planning' (UKWIR, 2016a).

The first stage of the problem characterisation assessment was an assessment of 'strategic needs'. This entailed three simple 'headline' questions that explored the size of any potential supply demand deficit, and if required, the cost of any supply and demand management options. All four of our WRZs had a supply surplus in all years of the planning horizon under the Baseline scenario. At the time of the assessment, it was reasonable to assume that all of our WRZs would continue to have a supply surplus in our draft PR19 WRMP and so no investment would be sought to fund supply and / or demand management measures.

The second stage of the problem characterisation was an assessment of the 'complexity factors'. This stage asked whether there was concern regarding understanding of near term supply system performance, either because of:

- i. Recent Level of Service (LoS) failures; or
- ii. Poor understanding of system reliability/resilience under different or more severe droughts than those contained in the historic record.

Given the forecast supply surplus in all four of our WRZs, we did not have any significant concerns about the understanding of near term supply system performance. Additionally, we continue to meet our LoS.

A similar question was asked regarding demand and whether the nature of current or near term demand had recently changed or was likely to change, e.g. because of large scale metering programmes or sudden changes in economics/demographics. At the time of the assessment, the nature of current and near term demand had not recently changed. Industrial demand was generally falling and domestic demand was fairly constant.

Our problem characterisation assessment concluded that all four of our WRZs had a “low vulnerability” score. The results of this assessment were then carried forward to the risk composition stage detailed below.

2.9.3 Risk Composition

Risk composition requires water companies to select and justify one of the following three approaches in developing their WRMPs:

Conventional;

- i. Resilience Tested; or
- ii. Fully risk-based.

The guidance provides a summary description of the approaches and techniques for each approach for developing supply and demand forecasts and is re-produced below.

Table 2.3: Risk composition approaches

Risk Composition	What is it?	Specifics of what is Involved (supply, demand, investment)
1 – The ‘Conventional’ Plan	Estimates of supply capability are based on the historic record, perturbed for climate change. Any testing of droughts outside of the historic record is done using a simple ‘top down’ method and is only done to examine supply / demand risk under more extreme conditions (i.e. sensitivity analysis only). Uses a simple representation of dry year/normal year demand.	<i>Supply</i> – conventional ‘Deployable Output’ (DO) or historically based time series. <i>Demand</i> – dry year/normal year estimates. <i>Investment</i> – inputs to the Decision Making Tool (DMT) are based on analysis of the historic record and the investment programme therefore represents the ‘best value’ response to maintaining LoS and resilience against the historic record.
2 – The ‘Resilience Tested’ Plan	Companies use ‘Drought Events’ to test the Plan and look at the implications of alternative/more severe droughts on the ‘best value’ investment programme. These ‘Drought Events’ can be derived using a variety of top down methods, but their	<i>Supply</i> – conventional plus ‘event based’ DO or time series. <i>Demand</i> - conventional, or can use demand/weather models to create equivalent demands for generated events. <i>Investment</i> – Events are used to test the

Risk Composition	What is it?	Specifics of what is Involved (supply, demand, investment)
	‘plausibility’ (approximate level of severity) is checked using <i>metrics</i> of rainfall, aridity or hydrology. More complex representation of demand <i>variability</i> can be tested.	programme; either by comparing the resilience of similar NPV programmes, or to look at the cost implications of achieving LoS commitments and resilience to droughts outside of the historic record.
3 – The ‘Fully Risk Based’ Plan	Companies use modelling methods to evaluate a full range of drought risks to their supply system, supported by more sophisticated approaches to matching this with demand <i>variability</i> . This is used to generate a ‘best value’ WRMP at a level of resilience that is linked to Levels of Service and the Drought Plan.	<p><i>Supply</i> – companies use generated data sets to explore the yield response to drought severity and patterns. Inputs to system-simulation DMTs are based on probabilistic sampling of the drought response.</p> <p><i>Demand</i> - demand variability to drought is incorporated, although methods/complexity can vary.</p> <p><i>Investment</i> the Plan is developed to represent the ‘best value’ response to overall drought risk, according to the Company’s stated LoS and drought resilience.</p>

The guidance states that the over-riding concept when choosing which approach to follow is that non-conventional methods (i.e. Risk Composition 2 and 3) for forecasting supply and demand should only be used where they are warranted and should be proportionate to the supply demand problem as defined in the problem characterisation stage. Methods beyond the ‘Conventional’ baseline can be chosen, but only need to be followed where there are specific concerns with the supply/demand components that mean a risk based approach is needed to better understand the supply/demand problem that they face.

Our early (2016) supply and demand forecasts indicated that all four of our WRZs would have a supply surplus across the full planning period. As such, the problem characterisation assessment concluded that all four of our WRZs had a low vulnerability to supply deficits. Consequently, the ‘Conventional’ methods (i.e. Risk Composition 1) have been used to forecast future demand, water supplies and target headroom to allow for uncertainty in the forecasts.

Baseline supply and demand forecasts were re-calculated during 2016/17 and these also confirmed that a supply surplus would be maintained across the statutory minimum 25 year planning horizon. Consequently, there was no need to re-assess the forecasts using Risk Composition 2 or 3 methods.

In line with the WRPG, we have applied some Risk Composition 2 approaches in that each WRZ has been tested against a theoretical drought event which could occur 1 year in every 200 years on average.

2.10 Resilience to Droughts More Severe than those used to test this WRMP

For each of our WRZs, we have completed DO assessments both against our worst drought on record and for a drought with a return period of 1 in 200 years on average. The resulting DOs ensure that there is a supply surplus across the 40 year planning period without the need for Level 3 customer restrictions (i.e. we only need to make appeals for restraint once in every 10 years on average and impose a temporary use ban once in 20 years on average). Based upon these assessments, we have followed Ofwat's Drought Resilience Metric guidance to develop Certainty Grades for each WRZ, outlined in section 2.10.1.

In line with the Defra Guiding Principles and with the revised WRPG (July 2018), we will be testing our DO against even more extreme droughts including those with a return period of 1 in 500 years and 1 in 1,000 years on average. This work will be completed using the Drought Resilience Framework method and will be reported in the first Annual Review of our published WRMP19.

If a more severe drought than those we have tested our plan against were to occur, the actions we would take are outlined in our Drought Plan (www.eswater.co.uk/droughtplan). The next actions would be to apply for drought permits which would provide additional supplies of water as outlined in Table 10 of the WRMP Tables else impose a Level 3 non-essential use ban.

2.10.1 Drought Resilience Common Performance Commitments

Ofwat has developed a common performance commitment for drought resilience. The measure is, "the percentage of the population the company serves that would experience severe supply restrictions (e.g. standpipes or rota cuts) in a 1 in 200 year drought".

As described above, our PR19 modelling has confirmed that 0% of our customers would experience severe supply restrictions (e.g. standpipes or rota cuts) in a 1 in 200 year drought. This is due to the Company having invested for the long term in Abberton Reservoir.

Ofwat note that due to uncertainties surrounding data reliability and inconsistent methodologies, it is not possible to assign a quantitative level of certainty to the drought metric. As an alternative, a semi-qualitative 'Certainty Grade' has been suggested, adapted from the established Ofwat Confidence Grade process.

The first step is to assign a grade to the sophistication of the methodology used to derive a 1 in 200 year drought event in each WRZ. Table 2.4 outlines the criteria proposed, and Table 2.5 shows the grade assigned to each WRZ in this process, based upon the methodologies outlined in section 2.8.

Table 2.4: Methodology grading criteria

Method Grade	Description
A	Use of drought event data from latest research outputs that have employed global climate model ensemble runs to simulate droughts, such as those arising from the MaRIUS Project within the NERC Drought and Water Scarcity Programme ¹ ,
B	Use of perturbed data from existing observed weather datasets, using stochastic processes, in a “weather generator” approach used with UKCP09 Regional Climate and Future Flows (2012 ² .)
C	Extrapolation from limited sample of historic company data
D	Use of arbitrary or ‘yardstick’ deviations based on historic observations

Table 2.5: Methodology grading results

WRZ	Grade
Blyth	B
Essex – Surface Water Sources	C
Essex – Groundwater Sources	B
Hartismere	B
Northern Central – River Intakes and Groundwater Sources	B
Northern Central – Groundwater-fed Lakes	D

The next step is to determine how close a company would come to implementing Level 4 restrictions during a 1 in 200 year drought event. For a WRZ with a surplus supply-demand balance for a 1 in 200 year drought event, which all ESW WRZs have, the risk score represents the amount and reliability of this surplus water. Table 2.6 outlines the proposed calculation steps, and Table 2.7 shows the criteria for each Risk Score.

Table 2.6: Calculating the surplus for the 1:200 drought event

Step	Detail	Output
Step 1A	For each WRZ, calculate the volume available for the 1:200 drought event: <i>WAFU minus outage minus demand plus Table 10 (Drought Interventions) benefits</i>	The surplus or deficit volume at 1:200 year drought
Step 1B	Express the output from Step 1A as a percentage of the Target Headroom volume, from WRMP Table 10	An ‘ <i>Optimistic</i> ’ percentage of the surplus or deficit relative to the WRZ Target Headroom
Step 2A	Taking the outputs from Step 1A, determine how much of the surplus or deficit depends on supplies and operational interventions which are outside of the company’s direct control, such as bulk supplies (where there is uncertainty over the volume that might be delivered during a severe regional event); Drought Permits and Drought Orders.	The surplus or deficit volume at 1:200 year drought within the company’s direct control

Step 2B	Express the output from Step 2A as a percentage of the Target Headroom volume, from WRMP Table 10	A 'Pessimistic' percentage of the surplus or deficit relative to the WRZ Target Headroom
---------	---	--

Table 2.7: Risk Score Definitions

Risk Label	Resilient WRZs, i.e. have a surplus
1	'Pessimistic' surplus % is > 125% of Target Headroom
2	'Pessimistic' surplus % <125% but still > 100% of Target Headroom
3	'Optimistic' surplus % >= 100% of Target Headroom, but 'Pessimistic' surplus only 50% to 100% of Target Headroom
4	'Optimistic' surplus % >= 100% of Target Headroom, but 'Pessimistic' surplus only 0% to 50% of Target Headroom
5	'Optimistic' surplus % >= 100% of Target Headroom, but the 'Pessimistic surplus' shows an SDB deficit
6	'Optimistic' surplus % >= 100% of Target Headroom, but the 'Pessimistic surplus' shows an SDB deficit AND there is a significant reliance on higher risk interventions to generate the initial surplus

For each WRZ, both the Optimistic and Pessimistic surplus for a 1 in 200 year drought event, relative to Target Headroom, are represented in Table 2.8. As specified in guidance provided by Ofwat (Ofwat (2017) Drought Resilience Metric), these figures are calculated as an average over the 25-year planning horizon. For Essex WRZ, only a Pessimistic surplus is presented as there are no drought permits/orders for the WRZ. The Thames Water Utilities (TWU) bulk supply to Chigwell for the Essex WRZ is still included in this Pessimistic surplus as it is a guaranteed supply, on the condition that both ESW and TWU have Level 1 and 2 restrictions enforced at the same time.

Table 2.8: Risk scoring results

WRZ	Target Headroom (MI/d)	Optimistic Surplus (MI/d)	Optimistic Surplus relative to Target Headroom	Pessimistic Surplus (MI/d)	Pessimistic Surplus relative to Target Headroom	Risk score
Blyth	1.05	3.54	337%	2.98	284%	1
Essex	28.21	-	-	57.55	204%	1
Hartismere	0.69	1.73	251%	0.19	28%	4
Northern Central	4.85	20.66	426%	18.49	381%	1

The final element is to select the acceptability of the Certainty Grade (the Methodology Grade combined with the Risk Score) by determining whether the methodology used is appropriate to the risk for the Company. This is done by assigning a colour band that suitably defines the Certainty Grade, as shown in Tables 2.9 and 2.10.

Table 2.9: Acceptability colour band definition

Colour	Acceptability definition
Blue	Very certain, no need to review unless there is a large change to the SDB
Green	Certain; approach and margin are acceptable, but there may be some benefit in reviewing either the method or the role of transfers, Orders and Permits on the SDB.
Amber	Some uncertainty; the classification of the WRZ is relatively uncertain and the method and/or the assessment of transfers, Orders and Permits should be reviewed at the next WRMP.
Red	Significant uncertainty; the adopted method is not appropriate and further work on the method and assessment of transfers, Orders and Permits is required.

Table 2.10: Compatibility of the Acceptability colour band and the Certainty Grade

Risk Score	Methodology Grade			
	A	B	C	D
1	A1	B1	C1	D1
2	A2	B2	C2	D2
3	A3	B3	C3	D3
4	A4	B4	C4	D4
5	A5	B5	C5	D5
6	A6	B6	C6	D6

The resulting Certainty Grade and colour band for each WRZ, or where appropriate sub-WRZ, is presented in Table 2.11.

Table 2.11: Certainty grading results

WRZ	Certainty Grade
Blyth	B1
Essex – Surface Water Sources	C1
Essex – Groundwater Sources	B1
Hartismere	B4
Northern Central – River Intakes and Groundwater Sources	B1
Northern Central – Groundwater-fed Lakes	D1

2.11 Resilience to Non-Drought Hazards

2.11.1 Overview

We have extensive experience in supplying high levels of demand not associated with drought conditions. Typically high demands occur either due to customers using more water during hot weather, for watering the garden or filling paddling pools etc, or in the winter when freeze-thaw events lead to an increase in burst water mains.

Our network is sufficiently resilient to such increases in demand, potable storage in the network allows any sudden increase in demand to be met whilst the headroom in

our treatment capacity allows the DI of the treatment works to be increased to recover this lost network storage whilst supplying the higher level of demand.

Our production planning and short interval control processes ensure that WTW are able to increase production if high demand does occur.

Recent examples of high summer demand include the recent heat wave in 2018 where demand increased by over 20%, with a 30% peak. We have been able to maintain supplies without issue during these events.

2.11.2 Flooding

As required by the Security and Emergency Measures Direction, our abstraction sites and water treatment works were assessed for pluvial, fluvial and coastal flood risk in 2009. Investment requirements to fund mitigation schemes to reduce flood risk to an acceptable level were then included in our PR09 Business Plan. The main scheme covered an abstraction well near Southwold in Suffolk which was at risk from saline intrusion. The preferred option was to supply Southwold via an alternative site and so a new pipeline was commissioned in AMP5.

All of our water supply assets were assessed to be resilient to flood risk in our PR14 flood risk assessments. Consequently, we have not undertaken any further sensitivity testing in Section 11 of this WRMP. We will review and update our flood risk assessment when the CP18 climate projections are issued.

2.11.3 Freeze / Thaw

Severe winter weather conditions, like those seen during the 'Beast from the East', can result in short-term increases in leakage when frozen pipes burst and then thaw. Such increases in leakage and distribution input can be sudden if there is a rapid thaw.

It is not possible to prevent bursts caused by severe weather conditions. However, network monitoring and ensuring we are adequately resourced to promptly respond is paramount. The interrogation of our DMA monitors quickly showed the areas of greatest increase in leakage and also pin pointed that it was predominantly on the customer side. In Essex the demand immediately before the rapid thaw was about 380 MI/d. On the Sunday it reached 480 MI/d. We shut off a number of caravan/mobile home sites until they reduced their leakage as well as a number of commercial properties. On Monday the demand had dropped to 410 MI/d, and we had found very few mains bursts to repair on the Sunday. This shows about 70 MI/d was customer side and 30 MI/d network side. We are well placed in this respect to deal with such events with dedicated leakage crews (direct labour and contactors) and other distribution network crews who can be diverted to find and fix leaks. Additionally, extra monitoring, analysis, response and recovery mitigation were also used to minimise the impact of the bursts.

We are continually improving and developing our business resilience policy, our adverse weather response plan, and our business continuity arrangements for adverse weather. The company has a complete 24 hour standby up to Senior Manager level, with the Executive Leadership Team being contacted if incidents are escalating. This means that all resources and permissions are immediately available to mitigate the effects of events, such as “Beast from the East”, to the best of our ability.

The “Beast from the East” in 2018 presented very challenging conditions to the water industry. A particular problem for us was leakage from pipes to unoccupied static caravans on holiday parks and commercial/industrial complexes. However we had pre-empted the thaw by maximising our output from the water treatment works and increasing storage of potable water in our distribution system. We were proud that we did not have any more interruptions to supply during that period than we have in a “normal” week. This demonstrates the resilience of our network and incident management processes to freeze / thaw events.

We conclude that we are resilient to freeze / thaw events and so have not undertaken any further sensitivity testing in Section 11 of this WRMP. However, we will review the impact of the “Beast from the East” on the water industry by working with the other companies via WaterUK and apply learning where relevant to do so.

2.12 Reconciliation of Data

We have used the Maximum Likelihood Estimation method (MLE) to reconcile the water balance at resource zone level in order to minimise the uncertainty in base year estimates. MLE provides a good framework to reconcile the water balance to ensure the sum of the estimated components equates to distribution input. The standard method for MLE is provided in an UKWIR / NRA report (UKWIR and NRA, 1995).

2.13 Sensitivity Testing

In developing this WRMP, we have made a number of assumptions. The Environment Agency has highlighted the importance of including a description of the sensitivity of the WRMP to these assumptions.

The WRPG (Environment Agency, 2017a) indicates that as a minimum the sensitivity analysis should consider:

- i. The sensitivity of the supply demand balance to data uncertainty; and
- ii. The sensitivity of the DO to leakage, climate change and sustainability reductions.

Item (i) is considered in detail within the calculation of headroom uncertainty and hence an assessment of sensitivity for each WRZ has been included in section 7.4 within the chapter on target headroom.

Item (ii) is considered in section 5 (Leakage), section 6 (Climate Change) and section 8.8 (Sustainability Reductions).

2.14 Company Policies including Level of Service

2.14.1 Customer Consultation

CCWater and YouGov research into restrictions on the use of water (June 2012) found that customers perceive three main causes of drought; lack of rain (77%), leaks from water pipes (77%) and household customers using too much water (49%). Businesses (31%), agriculture (12%), climate change (38%) and extraction of water from river (31%) were also expressed as causes of drought, but to a lesser extent.

The 1 in 20 year risk of a hosepipe ban appears to be acceptable to the majority of domestic and business research participants. Customer priorities and willingness to pay research conducted in 2011 suggested a low willingness to pay for reduced risk of water restrictions; three Essex and Suffolk participants out of 40 suggested they would be willing to see their bills increase by £0.63 for a reduced risk of hosepipe bans. Two participants were less accepting of this level of risk, however their reasoning was based on inaccurate information that Essex and Suffolk Water had sold a reservoir and had facilities for desalination of sea water.

Qualitative research conducted for PR14 suggested that during a prolonged interruption to supply customers are most concerned about the plants in their gardens dying and how supply would be maintained for vulnerable customers.

2.14.2 PR19 WRMP Planned Levels of Service

Levels of service are expressed in terms of expectations about the frequency of restrictions on use during dry years, and set out the standard of service that customers can expect to receive from their water company.

Levels of service are generally grouped into the following categories:

- Level 1: Appeal for restraint
- Level 2: Temporary Use Ban
- Level 3: Drought Order Ban
- Level 4: Reduced supply at customer tap

A Level 1 restriction is when we ask customers to use water wisely. For example, watering plants at night and not watering the lawn because grass is resilient to drought.

A Level 2 restriction (Temporary Use Ban or TUB) applies mainly to the domestic use of water and stops the use of a hosepipe or sprinkler for any garden watering or cleaning. For household customers, this is referred to as a hosepipe ban.

A Level 3 restriction (Drought Order) bans what has been applicable to the domestic customer under the Temporary Use Ban, to non domestic or commercial customers. These bans have economic consequences for businesses and have to be used as sparingly as possible.

A Level 4 restriction results in a temporary reduction or nil supply of water at the customer tap. Examples of Level 4 restrictions include:

- Reduced pressure at the customer tap (and therefore reduced flow);
- Rota cuts (e.g. 12 hours normal supply, 12 hours no supply); or
- Standpipes where supplies to customer’s taps are turned off leaving customers to fill containers from an in pavement standpipe tap.

Defra and the Environment Agency held a drought workshop called Exercise Arica in November 2017. This considered Level 4 (Stand pipe and Rota Cuts) restrictions on the use of water during drought. It was largely agreed that imposing such restrictions were technically not possible and that they are unacceptable in modern society and could lead to civil unrest. Instead, reducing the water pressure in water company networks was considered a more viable Level 4 option. Consequently, we have used pressure reduction as our Level 4 restriction on water use in our WRMP.

Reducing water pressure would reduce the flow of water to properties which in turn would result in lower household consumption. In some cases, most notably high rise tower blocks, pressure reduction could result in nil supply. To ensure customers in such building receive a supply, we would provide bottled water and tankered supplies.

Further work is required to estimate the demand savings which we will report in future Annual Reviews of our WRMP.

It is important to note that our actual levels of service assessment in our WRMP concludes that we would never need to impose a Level 4 restriction for a drought with a return period of 1 in 200 years or for our design droughts which have a return period greater than in 200 years.

The PR19 ‘planned’ levels of service for our customers are as follows:

Level 1: Appeal for restraint	1 in 10 years: (10% probability in any one year)
Level 2: Phase 1 Temporary Use Ban	1 in 20 years: (5% probability in any one year)
Level 3: Phase 2 Drought Order Ban	1 in 50 years: (2% probability in any one year)
Level 4: Pressure Reduction	1 in 250 years: (0.4% probability in any one year)

The levels of service for Level 1, 2 and 3 restrictions remain the same as in PR14. Our actual levels of service assessment confirms that we would comply with them in all years across the planning period (2020 to 2060) (see section 0). Therefore, we intend that our planned levels of service above will remain the same across the planning period.

The levels of service are applied to the combined Essex reservoir system in the Essex System Aquator model as control curves, which when crossed implement a 7%, 5% and 2% demand reduction for the Level, 1, 2 and 3 restrictions respectively.

The PR14 Level 4 restriction related to the use of rota cuts, and the level of service was 'never' (i.e. even in the most extreme of droughts, we would only ever impose Level 1, 2 and 3 restrictions). However, the Environment Agency requires us to state a level of service for Level 4 restrictions. As described above, it is still believed that rota cuts and standpipes should never be used, but that pressure reduction to reduce the flow rate at customer's tap is viable. We therefore define the PR19 Level 4 restriction as reducing pressure at the customer tap with a return period of 1 in 250 years on average. This return period is based on the following methodology, providing evidence of a 1 in 250 year return period to be an appropriate level of service for a Level 4 demand restriction.

The Essex System Aquator model was run over the full 107 year record (1910-2016) at the Essex System PR19 DO demand (390 MI/d). The lowest combined reservoir storage level for each year of the record was extracted, and ranked from lowest (27.52% in 1922) to highest (74.82% in 1912). Extreme Value Analysis of the 107 ranked annual minimum storage levels was carried out to obtain a fitted distribution that could be extrapolated to estimate storage levels for a range of return periods (Figure 2.6).

Extrapolation of the fitted distribution to a 1 in 250 year level of service returns a combined reservoir storage of 28% for a Level 4 demand restriction. This Level 4 curve would sit above the combined emergency storage level of 26.81%, whereas for example a 1 in 500 year level of service Level 4 curve would sit below it at 25%. Therefore, a 1 in 250 year level of service for a Level 4 demand restriction is suitable. This curve, along with the Level 1, 2 and 3 curves and combined emergency storage level, is plotted in Figure 2.7.

It is worth noting that at 28.56% and 27.52% respectively, the minimum storages of the Essex System worst historic drought years of 1921 and 1922 are similar to the 1 in 250 year level of service of 28%. The 1 in 250 year return period DO of the Essex System was calculated using the Aquator Scottish Method as 391 MI/d, a 1 MI/d increase from baseline DO, and therefore indicates that the return period of the worst historic drought is in excess of 1 in 250 years.




Figure 2.6: Annual minimum storage distribution for the Essex System combined reservoir storage




Figure 2.7: Level of Service curves and emergency storage level for Essex System combined reservoir storage

Our customer research has shown that there was no desire amongst customers to pay more for increasing the Level 2 return period above 1 in 20 years.

2.14.3 PR19 Actual Levels of Service Assessment

In terms of actual levels of service, this can only be determined retrospectively and through consideration of return periods. The following table indicates the dates on which appeals for restraint and restrictions have been implemented within the Essex and Suffolk supply areas since 1976.

Table 2.12: ESW appeals for customer restraint and restrictions since 1976

Drought Year	Supply Area*	Appeals for Restraint	Phase 1 Temporary Use Ban (Previously known as a Temporary use ban)	Phase 2 Drought Order Ban (Previously known as Non Essential Use Restrictions)	Rota Cuts
1976	Essex	Yes	Yes	No	No
	Suffolk	Yes	Yes	No	No
1990/92	Essex	Yes	Yes	No	No
	Suffolk	Yes	Yes	No	No
1995/97	Essex	Yes	Yes	No	No
	Suffolk	Yes	Yes	No	No
2006	Essex	Yes	No	No	No
	Suffolk	Yes	No	No	No
2011/12	Essex	Yes	No	No	No
	Suffolk	Yes	No	No	No

*Restrictions in Suffolk have always been applied across the whole supply area and not in selected resource zones

Essex

We have undertaken a modelling assessment to determine the frequency of temporary use bans in Essex in terms of the historic naturalised flow time series available in the Aquator model. Total reservoir storage volumes were estimated using the average dry year demand forecast for AMP7 and the naturalised flow time series from 1910-2016. Daily combined storage for the Essex reservoirs was exported from the model and compared to the reservoir curves for the implementation of demand reduction actions. The number of occasions that reservoir storage was below the reservoir curves was calculated and used to determine the actual level of service the Essex System customers could expect. The results are presented in Table 2.13, and indicate that we are exceeding the 'planned' levels of service. The Level 3 and 4 curves are never crossed, and the Level 2 curve is only crossed once during the 107-year period of analysis, under the 2019/20 Dry Year Essex System DI demand. The Level 1 curve is crossed three times under each demand scenario, in 1921, 1922 and 1934. As the 1921 and 1922 crossings are

contained within the same drought (section 2.9.1), the period between the 1921 crossing and the 1934 crossing define a return period of 13 years, which is higher than the planned return period of 10 years.

Table 2.13: Number of Level of Service crossings under Dry Year Essex System DI demands throughout planning horizon

Year	Dry Year Essex System DI (MI/d)	Level 1	Level 2	Level 3	Level 4
2019/20	309.07	Three	One	Never	Never
2024/25	294.59	Three	Never	Never	Never
2029/30	282.98	Three	Never	Never	Never
2034/35	274.41	Three	Never	Never	Never
2039/40	272.47	Three	Never	Never	Never
2044/45	275.25	Three	Never	Never	Never
2049/50	281.62	Three	Never	Never	Never
2054/55	290.52	Three	Never	Never	Never
2059/60	299.65	Three	Never	Never	Never

Suffolk

Currently there is no mechanism by which to equate levels of service with groundwater levels, therefore we undertook an assessment based on an analysis of historic rainfall in the surface water dominated Northern Central resource zone. The information on actual levels of service in terms of the implementation of restrictions indicated that there was a correlation between the Essex and Suffolk supply areas, in that the same levels of appeals for restraint and restrictions have been implemented in each of the supply areas during the same drought years considered. To quantify this, a statistical analysis was carried out on the rainfall records for Barsham in Suffolk and Layer in Essex to determine the statistical significance of the relationship between rainfall in Suffolk and Essex. This assessment gave a correlation co-efficient of 0.75 for the monthly average rainfall data from 1987-2016. A further assessment was carried out on the drought years 1995-1997, and this gave a correlation co-efficient of 0.87. These results suggest that there is a strong similarity between the levels of rainfall in Essex and the levels of rainfall in Suffolk. This supports the view that actual levels of service achieved in Suffolk would be the same or very similar to those achieved in Essex, based on historic experience of the implementation of restrictions in both of these areas and the similarities in their rainfall record.

In the PR14 assessment, levels of service were also considered through modelling as part of the groundwater DO assessment (see section 3). Within the model, abstraction was reduced by 10% which is the minimum reduction in demand that we would expect to achieve from an appeal for restraint and a Phase 1 Temporary Use Ban (12% is considered likely). However, even before the 10% demand reduction was applied, DO was only ever constrained by the annual average daily licence and has never been resource constrained. The results of this assessment still apply.

2.15 Third Party Provision of Supply and Demand Options

We have produced a Bid Assessment Framework which is designed to set out the principles, policies and procedures that we will adopt to ensure a level playing field is created when assessing a bid from a third party for the provision of water resources and/or leakage demand management services against our own provision.

It aims to provide clarity and confidence to third party bidders about the process and that all bids will be assessed in a fair and transparent way against any in house solutions.

We are willing to accept bids from any party that would bring innovation and allow us to identify more efficient ways of delivering water resources, demand management and leakage services without adding avoided costs. We have published the water resources market information on our website (www.eswater.co.uk/wrmp).

Through this bid assessment framework we are looking to promote innovation which will allow us to deliver water resources, demand management and leakage services more efficiently for the benefit of customers. This will ultimately mean a reduced cost for our customers.

2.16 Details of Competitors in Each Resource Zone

The Water Act 2003 amended the Water Industry Act 1991 to extend the opportunities for competition within England and Wales. Companies that are interested in supplying customers with water can now apply to Ofwat for a water supply licence. This will allow them to supply water to eligible premises anywhere within England and Wales.

The following inset appointments are located within our WRZs:

The first is to Barking Riverside, a domestic housing development in the London Borough of Barking and Dagenham in the Essex WRZ. The inset supplier is SSE and the water is supplied by us. An application to include the next phase of this development (phase 2-4) is in process and the first connections of this phase were made in July 2016. The anticipated annual demand is 71.5Ml.

The second is to Woods Meadow a domestic housing development in Oulton in the Suffolk Northern Central WRZ with some commercial units in Mobbs Way. The inset supplier is Anglian Water and the water is supplied by us. The anticipated annual demand is 170.6Ml.

The third is to Five Oaks a domestic housing development in Chigwell in the Essex WRZ. The inset supplier is Albion Water and the water is supplied by a combination

of ourselves and Albion Water's own resources. The anticipated annual demand is 31MI.

The previous Water Supply Licence (WSL >5MLD) regime supply to a food producer in the Suffolk Blyth WRZ where the supplier was Business Stream has now been relinquished and the supply returned fully to us.

Anglian Water Services (AWS) has an existing inset appointment (secured in 1997) to supply Buxted Chickens at Flixton in the Suffolk Northern Central WRZ. Buxted Chickens is located close to the ESW and AWS supply boundary and so AWS supply the water via an AWS water main.

2.17 Links to Other Plans

2.17.1 Links to Northumbrian Water Limited Business Plan

We are part of Northumbrian Water Limited (NWL). This WRMP also informs NWL's Business Plan for the 2019 Periodic Review of Price Limits (PR19). This covers the period from 1 April 2020 to 31 March 2025, otherwise known as AMP7.

Funding requirements to allow all strategies linked with this draft WRMP and regulatory programmes of work will be included in the PR19 Business Plan. This includes:

- Metering, leakage and water efficiency strategies that have been built into baseline distribution input calculations; and
- Schemes in the Water Industry National Environment Programme (WINEP) – currently WINEP2.

The baseline supply demand balance calculations have confirmed a supply surplus for all four WRZs across all years of the planning horizon. Therefore, no further supply or demand management schemes are required. This position will be acknowledged in the NWL PR19 business plan.

2.17.2 Links with Essex & Suffolk Water Drought Plan

The WRPG states that WRMPs should be appropriately linked. The planned levels of service (see section 3) in this draft WRMP will be the same as those in the final Drought Plan when it is published in 2018. Additionally, the calculation of all elements relating to the supply demand balance are consistent in both plans.

As described in Section 2.10 above, in this WRMP, we have completed DO assessments for each of our WRZs both against our worst drought on record and for a drought with a return period of 1 in 200 years on average. The resulting DOs ensure that there is a supply surplus across the 40 year planning period without the need for Level 3 customer restrictions (i.e. we only need to make appeals for restraint once in every 10 years on average and impose a temporary use ban once in 20 years on average).

If a more severe drought than those we have tested our plan against were to occur, the actions we would take are outlined in our Drought Plan (www.eswater.co.uk/droughtplan).

Our Drought plan enables us to respond to developing sustained dry weather (drought) conditions that have the potential to detrimentally affect public water supplies. Drought conditions are usually manifested in the form of:

- Reduced raw water availability (e.g. low river flows, low reservoir storage, low groundwater levels); and/or
- Increased demand (e.g. due to increased garden watering, showering etc in dry weather).

Our Drought Plan identifies how we intend to manage a future drought, what trigger levels can be used to identify when action is required, and what short term measures are available to support supplies when levels of service are compromised. The benefit of supply side drought actions has not been included in the baseline supply forecast. However, the benefit of demand side drought actions has been taken account of in our final plan supply demand balance calculations.

2.17.3 Links with Environment Agency Drought Plan

An Environment Agency document called “Drought response: our framework for England” (Environment Agency, 2017b) sets out how the Environment Agency works with government, water companies and others to manage the effects of drought on people, business and the environment. It sets out who is involved in managing drought and how the Environment Agency and stakeholders work together and take action to manage drought. The national framework aligns with the Environment Agency’s operational area drought plans to provide a strategic overview for how it will manage a drought to minimise damage to the environment and to secure essential public water supply. Information in the framework and local Environment Agency Drought Plans has been taken into account in the development of our Drought Plan, and therefore in this draft final WRMP.

2.17.4 Links to Defra’s 25 Year Plan

In January 2018, Defra published its much-anticipated environment strategy ‘A green future: Our 25-year plan to improve the environment’. We have a responsibility to play our part in this, and are keen to support all of the ten goals in the plan to protect

and enhance the environment for future generations. Our business plan sets out how our ambitions for 2020-25 will contribute to meeting these goals, including achieving clean air, clean and plentiful water, thriving plants and wildlife, reducing risk of harm from environmental hazards, using resources from nature more sustainably and efficiently, enhancing beauty, heritage and engagement with the natural environment, minimising waste, and enhancing biosecurity.

Our WRMP and the WINEP detailed in it (see Section 3.8), specifically supports the goals in Defra's 25 Year Plan in terms of:

- Drinking water catchment management under the Drinking Water Protection Area (DWPA) driver;
- River Chelmer holistic water management project under the Natural Environment & Rural Communities (NERC) Act driver;
- Further improvements under the Eel Regulations driver;
- Measures to reduce the risk of transferring Invasive Non-Native Species (INNS); and
- Abstraction sustainability investigations under the Water Framework Directive (WFD) driver.

Outside of the WINEP, our demand management strategy will also reduce customer water use and reduce leakage from our own distribution network (see Section 5).

2.17.5 Links with River Basin Management Plans

The Environment Agency has published an Anglian river basin district River Basin Management Plan (RBMP) called "Water for life and livelihoods" (Environment Agency, 2016b). The RBMP sets out the current state and pressures on the environment and sets environmental objectives and a programme of measures to improve the environment. Information in the RBMP has, where required, been used to inform the development of this draft WRMP, most notably in the development of the PR19 WINEP and in considering whether this draft WRMP could increase the risk of deterioration of the status of the surface and groundwaters from which our abstractions could impact.

2.17.6 Links with Flood Risk Management Plans

Consultants, Royal Haskoning, have previously undertaken flood risk assessments to confirm whether any infrastructure including pumping stations and treatment works are at risk of flooding both now and the future. These confirm that the supply forecasts used in this draft WRMP are not compromised because of any current or future flood risk.

We will re-assess flood risk after the CP18 climate projections are released in 2018.

2.17.7 Links with Plans Produced by Local Authorities

Information from local authority Plans has been used to develop property and population forecasts which in turn have been used to develop our demand forecast (see section 4).

2.18 Water Industry Strategic Environmental Requirements (WISER)

WISER describes the environmental, resilience and flood risk obligations that water companies must take into account when developing their PR19 business plans.

We are confident that our ambitious plans for 2020-25 and the step change this represents in our relationship with the environment more than meets the EA and NE's expectations.

The figure below shows how our PR19 business plan addresses the objectives set out in WISER, and how we are demonstrating leadership through the three good practice approaches identified.

We have embedded the statutory obligations and regulatory expectations set out in WISER into our plan, through the resilience and environment themes and the performance commitments and investment plans set out within the business plan.

The Environment Agency also requested in WISER that we 'consider enhancements which go beyond the statutory minimum where there is customer support, and wherever possible identify opportunities for working in partnership to achieve wider environmental benefits'. Our partners are key to delivering our plan, and our aspirations for the 'wider environment' illustrate our commitment to go 'above and beyond'.



In developing our plan, we worked with the Environment Agency and Natural England to develop and agree the content of our portion of the WINEP, a key part of our business plan for 2020-25. The WINEP identifies environmental transformation activities, setting out the schemes to be delivered, level of investment required, and targets to be achieved in order to make environmental improvements that will allow us to meet our regulatory obligations.

Representatives of the Environment Agency and Natural England also play an important role on our Water Forums. Their challenge through Water Forum discussions shaped our ambitious goals for the environment, our development of demand-side options for water resource management planning, and our commitment to take a catchment based integrated approach to delivering water and wastewater services, joining up planning and agreeing shared objectives with partners for better management of all our catchments.

Our business plan is based on the full delivery of our WINEP3 by 2025 as originally planned and as indicated in our SoR. We have benefitted from very good relations with our local and national Agency contacts which means that requirements for the Company were well flagged with no surprises in the final WINEP. The scale of the plan is deliverable taking into account our other planned capital investments and we have already started to engage with our supply chain as part of our preparations for delivery. We have already worked closely with our local Environment Agency representatives to ensure that we have a robust WINEP3, and that uncertainty has

been managed where possible through the adopted traffic light system and has been kept to a minimum through this process.

We are very keen to continue to look for opportunities for innovative approaches to delivering better outcomes and working in partnership to identify catchment measures where possible. We see this very much as an ongoing activity and do not propose that a longer timeframe would be beneficial to this process.

2.19 Biodiversity 2020

Biodiversity 2020 was published in 2011 and is a biodiversity strategy for England which builds on the Natural Environment White Paper and provides a comprehensive picture of how we are implementing our international and EU commitments. It sets out the strategic direction for biodiversity policy for the next decade on land (including rivers and lakes) and at sea.

The mission of the strategy is *“to halt overall biodiversity loss, support healthy well-functioning ecosystems and establish coherent ecological networks, with more and better places for nature for the benefit of wildlife and people”*.

The strategy sets four high-level outcomes to show what achieving this overarching objective by 2020 will mean in practice. The outcomes are reproduced in the table below.

Outcome	Outcome Description
Outcome 1 – Habitats and ecosystems on land (including freshwater environments)	By 2020 we will have put in place measures so that biodiversity is maintained and enhanced, further degradation has been halted and where possible, restoration is underway, helping deliver more resilient and coherent ecological networks, healthy and well-functioning ecosystems, which deliver multiple benefits for wildlife and people
Outcome 2 – Marine habitats, ecosystems and fisheries	By 2020 we will have put in place measures so that biodiversity is maintained, further degradation has been halted and where possible, restoration is underway, helping deliver good environmental status and our vision of clean, healthy, safe productive and biologically diverse oceans and seas.
Outcome 3 – Species	By 2020, we will see an overall improvement in the status of our wildlife and will have prevented further human-induced extinctions of known threatened species.
Outcome 4 – People	By 2020, significantly more people will be engaged in biodiversity issues, aware of its value and taking positive action.

We believe that delivery of our part of the WINEP (see Section 3.8.3) will help support all four of the outcomes. Our WINEP will ensure all of our surface water and groundwater abstraction are sustainable, that all of our abstraction intakes and river structures are Eel

Regulations compliant, that we will be enhancing the biodiversity of our own land holdings and that we will be leading a holistic water management project in the River Chelmer catchment with the overall aim improving biodiversity.

2.20 Natural Capitals

We are seeking to understand and monitor the impact we have on our five identified capitals (financial, manufactured, natural, human & intellectual, social). Our essential core function is not the limit of our role or ambition, and the contribution we make is much wider than this. Better understanding how we depend on and interact with the capitals will enable us to reap the benefits of successfully managing those interactions with potential benefits for the business, society and the natural world.

Engagement with staff and stakeholders has identified seven key areas of natural capital that are of specific importance to us:

- Greenhouse gases
- Air pollution
- Ecosystem services & land use
- Flood attenuation
- Water and sewage pollution
- Water resource management and use
- Waste disposal (including sludge)

We are making good progress on this journey and have identified three opportunities that we are currently pursuing:

- Adapting the investment process to include impact on the five capitals in the decision making to ensure well-rounded decisions are made.
- Including capitals-related data in its Management Information and Business Intelligence systems, to be able to understand and monitor progress.
- External reporting of progress via its 'our contribution' reports.

Looking at our own landholding, we have produced a number of ecosystem service assessments; displaying them as interactive pdfs to enable engagement with a wide audience. These include a mixture of qualitative and quantitative measures.

We have also embarked on a biodiversity site ranking exercise. It aims to rank all ESW sites in terms of biodiversity value – using the Defra metric as the starting point, but building on that to include measures such as the presence of priority habitats or species, site connectivity and the presence of invasive species. This will provide a superb baseline of information to enable us to measure the impact of our activities on the biodiversity of our landholding and hopefully, as Natural England's eco-metric develops, that can then be used to show the benefit or harm that could come from the development of other eco-system services on the land.

2.21 Habitats Regulation Assessment

All four of our WRZs have a baseline supply surplus in each year of the planning horizon and so no new supply schemes will be developed. Consequently, a Habitats Regulation Assessment is not required.

2.22 Strategic Environmental Assessment

Directive 2001/42/EC of the European Parliament and of the Council on the Assessment of the Effects of Certain Plans and Programmes on the Environment (the Strategic Environmental Assessment Directive) was transposed into English law by the Environmental Assessment of Plans and Programmes Regulations 2004 (Statutory Instrument 2004 No.1633).

Subject to meeting defined conditions (confirmed through screening), plans and programmes require a Strategic Environmental Assessment (SEA) to be undertaken and an environmental report to be produced.


We have undertaken an assessment to identify whether we are required to undertake an SEA of our draft WRMP using UKWIR guidance (UKWIR, 2007).

Figure 2.1 illustrates the key stages and the results of our SEA screening exercise using the 2007 UKWIR methodology.

The results of the screening exercise are as follows:

- i. The WRMP will be prepared and adopted by ourselves who, under the EIA Directive, is considered an “authority”;
- ii. The WRMP is required by legislative provision, being a statutory document under the Water Act 2003 amending the Water Industry Act 1991;
- iii. The WRMP will be prepared for water management although based on the current draft supply demand balance calculations, it will not contain any supply schemes;
- iv. The WRMP will not be seeking permission for any schemes which will require an assessment under Article 6 or 7 of the Habitats Directive;
- v. The WRMP does not set the framework for future development consent or projects (not just projects in Annexes I and II in the Directive).

Based on the above assessment, we conclude that our draft WRMP does not fall within the remit of the SEA Directive and therefore it is not required to undertake an SEA or prepare an SEA Environmental Report.



Source: UKWIR (2007) Guidance for Water Resources Mgt Plans & Drought Plans

Figure 2.1: Key Stages of SEA Screening

2.23 Optimisation of Existing Operations

2.23.1 Business as Usual Optimisation

The WRPG asks water companies to describe the action that the Company has taken to lower the overall costs (financial, environmental, social and carbon) of its existing operations.

We consider optimising existing operations to be part of “business as usual”. This includes minimising process losses as back washing filters more frequently than is required incurs additional pumping which has an associated financial and carbon cost. Additionally, optimisation also reduces utilisation of annual licensed abstraction quantities. This process is controlled through the close monitoring of filter performance through the use of online water quality monitors.

In 2015, we agreed to reduce abstraction (when resources allow) during periods of eel migration from its lower intake on the River Stour. This would increase flows over weir structures thus aiding eel passage. Further details on abstraction from the lower River Stour is provided in section 3.8.

2.23.2 Abstraction Incentive Mechanism (AIM)

Following an earlier successful pilot, our Ormesby & River Bure licence has been subject to Ofwat’s Abstraction Incentive Mechanism (AIM) since April 2016. The objective of the AIM is to encourage water companies to reduce the environmental impact of abstracting water at environmentally sensitive sites during defined periods of low surface water flows (Ofwat, 2017). The AIM applies once a water level or flow trigger threshold has been reached. Once flow or water level has fallen below the agreed trigger threshold, abstraction at the sensitive site should be reduced so that it is less than the agreed baseline daily quantity, and the balance is made up by increasing abstracting from an alternative, less sensitive, source.

Ormesby Broad is a more environmentally sensitive site with respect to abstraction than the River Bure, and so during dry years, when water levels in the Broad fall below the defined trigger, abstraction from the Broads is reduced and abstraction from the Bure is increased. Following the implementation of the Review of Consents mud pumping solution, which ensures that a minimum water depth is always maintained across the Broads, it is proposed that the site will remain in the AIM for PR19, although the scheme will be reviewed to ensure that the water level trigger and baseline abstraction value are appropriate going forwards.

We are also investigating whether the abstraction from boreholes that supply Langham treatment works should be an AIM site for PR19. These boreholes are licensed for public water supply under certain emergency conditions, including drought, frost and pollution of the river. The boreholes have been identified by the Environment Agency in the PR19 WINEP2 as causing serious damage to flows in the River Brett. The Environment Agency has proposed a sustainability change to the licence from 2024. The AIM scheme will be relatively complex, as it is proposed

that the scheme should only cover drought and low river flow use of the boreholes, not abstraction for water quality, as this would severely constrain our ability to undertake abstraction management to achieve drinking water compliance for metaldehyde and other parameters, such as nitrates. The AIM scheme would also be subject to there being sufficient water stored in Abberton Reservoir, the less sensitive alternative source, to allow back pumping to be viable. In addition, the water in Abberton Reservoir would need to be of a good enough quality so as not to compromise the treatment capability of Langham treatment works. If these issues can be overcome and a clear set of triggers and rules established, then we intend to include the Boreholes as an AIM site for PR19.

3.0 WATER SUPPLY



3.1 Deployable Output (DO) Overview

In developing a water resource zone (WRZ) Supply Demand Balance, water companies are required to estimate the yield of their resource zones in terms of DO, a building block in determining Water Available For Use (WAFU). DO is defined in the Water Resource Planning Guideline (WRPG) (Environment Agency, 2016a) as:

“The output of a commissioned source or group of sources for the design drought you have chosen as constrained by:

- *hydrological yield;*
- *licensed quantities;*
- *environment (represented through licence constraints);*
- *pumping plant and/or well/aquifer properties;*
- *raw water mains and/or aqueducts;*
- *transfer and/or output main;*
- *treatment;*
- *water quality.”*

A requirement is to assign a level of confidence to DO figures. The validity of DO assessments is related to the length of record used in the calculations, with an expectation that they should extend back to at least 1920 in order to capture the

extreme droughts of the early 1920s and 1930s. The following matrix is provided to indicate the appropriate confidence label:

		LENGTH of Hydrological and/or hydrogeological data sets				
		> 99 years	71 – 99 years	< 70 years		
		A	B	C		
AVAILABILITY (and consistency) of Constraints Data	Available and of consistent quality	A	AA	AB	AC	
	Mostly available but of variable quality	B	BA	BB	BC	
	Not available	C	CA	CB	CC	
			HIGH	←	→	LOW

Figure 3.1: Confidence Label Matrix

We have not included the benefits drawn from supply drought measures (e.g. drought permits and orders) in the baseline supply forecast.

Since submitting our draft WRMP, the Environment Agency has asked all water companies to test their WRMPs against droughts of greater magnitude than those currently presented using its new Drought Vulnerability Framework. This includes droughts with a return period of 1 in 500 years on average and 1 in 1,000 years on average. Given the scale of the task, it has asked all water companies to report progress with the assessment in the first Annual Review of published WRMP19.

3.2 Essex Resource Zone Deployable Output Assessment

3.2.1 Overview

The DO of the Essex WRZ has three separate components which are:

- The Essex System (including Langford Recycling Scheme);
- Essex groundwater sources; and
- Chigwell bulk supply. We have an agreement with Thames Water to supply our Chigwell Treatment Works with 91 MI/d of raw water. However, in 2015, we entered into a separate agreement with Thames Water and traded 20 MI/d of raw water back to Thames Water. However, in a normal year, the agreement still allows us to take the full 91 MI/d. For the purposes of defining dry year deployable output, we assume Thames Water will take the 20 MI/d leaving 71 MI/d to supply Chigwell treatment works.

The determination of the first element is indicated in this section. The Essex groundwater sources DO figures are summarised in section 3.6.3. The assumptions for the Chigwell bulk supply are detailed in section 3.14.1.

3.2.2 Essex System Deployable Output Assessment Approach

The DO of the Essex System is calculated using Aquator, a Windows-based water resource modelling system that utilises Microsoft Access to store information and data, and Microsoft Visual Basic for Applications (VBA) programming to explicitly define the behaviour of the components which are used to represent the hydrological entities in a water resources system.

The key features of the Essex System Aquator model are the single demand centre, due to the integrated nature of the raw and potable network, and the river catchment components, which are assigned the naturalised river flow time series (1910-2016) that represent the majority of raw water resource in the model. All infrastructure, licence, and operational constraints are included in the model.

Aquator models a water resource system by combining a daily multi-pass calculation of how water is to be distributed within a system together with the operating rules built into each component in the model. This approach attempts to optimise the allocation of water, by allowing demands to first reserve and then take water. The reservation of water by all demands before any one demand actually takes water allows a sharing algorithm to make decisions based on predefined rules. These rules can be replaced or modified by the user to simulate the requirements of the water resource system being modelled.

We use the 'English & Welsh' method of determining DO. This method tests the resource system against a range of demands in turn until the system fails to meet the required demand during a design drought, and the highest demand the system is able to meet is the DO.

3.2.3 Model updates since PR14

Extension of the naturalised river flow record

Naturalised river flows are required in the Essex System Aquator model for four primary catchments, or Points of Interest:

- Chelmer to Langford
- Blackwater to Langford
- Stour to Stratford St Mary
- Ely Ouse to Denver

In all previous Periodic Reviews, flows in these rivers were derived from naturalisation studies undertaken in the late 1990s and provided a time series extending from 1 October 1932 to 31 December 1996. The critical drought defining Deployable Output in this case was 1933-34.

Flows in the Ely Ouse, the Stour, and the Blackwater catchments are significantly affected by groundwater abstractions, predominantly from the Chalk aquifer, and therefore have been notoriously difficult to estimate. In recent years the Agency has undertaken extended regional groundwater modelling that includes the entire area of these four catchments. Furthermore, the Centre for Ecology and Hydrology (CEH) has recently published daily rainfall data at a 1km² resolution for the whole of England and Scotland extending from 1890-2015 (known as CEH-GEAR). A naturalisation study undertaken by Hydrology.UK in 2015 for the Essex Rivers for 1970-2013 reported substantial inhomogeneity and inconsistency in historic parts of the naturalised records on the Essex Rivers, particularly for the period prior to 1970.

These factors combine to indicate that the time was right to review the historic records and derive new, consistent and homogenous data sets for all four catchments, extending as far back as the CEH-GEAR data would allow, and preferably to at least 1920.

The exercise to achieve this was carried out in two parts:

- i. Naturalise existing, reliable gauged river flows for the period 1970-2016 for all four catchments, and use these to derive flow records to the points of interest; and
- ii. Using the 1970-2016 naturalised flows, calibrate, validate, and blind-test rainfall-runoff models and extend the records back as far as is sensible based on rainfall and evaporation data up to 1969.

Flows for the Essex Rivers were recently naturalised up to 2013 using data from abstraction returns and Sewage Treatment Works (STW) gauged outflows up to 2011. These required extension up to 2016 for PR19. For the Ely Ouse, naturalisation was required for the entire period to ensure a consistent methodology and homogenous data set.

The request for discharge consent data resulted in being directed to the national database. When this data was processed, a large number of consents were discovered in the Essex catchments that had not been supplied during the previous study. Furthermore, updated abstraction returns were supplied by the Environment Agency on a licence-by-licence basis dating from 1970, which were not available for the 2015 study. This allowed differentiation between ground and surface water licence usage and summer and winter spray irrigation licence usage.

New groundwater modelling, undertaken on behalf of the Environment Agency, extended the period of coverage from 1970-2007 to 1970-2014. The additional discharge and groundwater modelling data made it necessary to re-visit the earlier naturalisation work for the Essex Rivers. The opportunity was therefore taken to also revisit the abstraction data to include these additional effects.

Reliable and good quality gauged flow records are not available on the Essex Rivers at the points of interest (POI). Indeed, only the Stour has currently operational flow gauging at the POI, but this is not a purpose-built structure and produces data of poor quality. Upstream gauging stations were therefore utilised on all three rivers, and the contribution from the intervening un-gauged catchment then estimated. In addition to the impact of surface and groundwater abstractions, and STW discharges, the Stour and Blackwater flows required the influence of the Ely Ouse to Essex Transfer Scheme (EOETS) removing from the gauged flows. The latter has a highly variable and complex influence that changes with time of year, rate of discharge into the river, length of time the discharge is operating, and the level of flow in the receiving river. It must therefore be accounted for by manual inspection on a daily basis throughout the record.

In total, 11 upstream gauges were used in the flow naturalisation for the Ely Ouse. These gauges measure flows on rivers prior to their entry into the fens and tend to be dominated by the response of the Chalk aquifer. They account for 2225km², or 65%, of the total area draining to Denver (3430km²). Much of the remaining area lies at or below sea level, below the level of the Ely Ouse itself, and therefore requires a different approach.

Flows for the 11 upstream gauges were naturalised for the period 1970-2016 using much of the same methodology as for the Essex Rivers. However, the contribution of the un-gauged area was estimated by using an areal rainfall factor on the sum of the naturalised upstream flows, and then deducting an amount for daily evaporation from the large area of open water surfaces. The same methodology was employed for all catchments in the Essex Rivers and Ely Ouse.

In order to ensure consistency and homogeneity throughout the rainfall-runoff modelling process, input rainfall and evaporation data from the same sources was used for the whole modelling period, 1910-2015. The rainfall data comprised the CEH-GEAR dataset which, when inspected, was found to have a reasonably robust description of rainfall in the study area from 1910 onwards. This was therefore selected as the start date for modelling.

Evapotranspiration data is not available throughout the modelling period and therefore had to be derived from data that was available. For this reason the East Anglia mean monthly temperature data series were used, which extend from 1910 to 2015. These were adjusted to match the mean annual temperature over a standard period for each catchment, and then converted into Potential Evapotranspiration using the Adjusted PE Model.

A rainfall-runoff model (Catchmod) was calibrated on the naturalised flow data for each of the contributing upstream catchments (1970-1992). The calibration was then tested on a validation period (1993-2006), adjusted if necessary, and then re-tested on a blind period (2007-2015), after which no further adjustments were allowed. The calibrated models were then used to derive 'natural' flows for the period 1910-1969, which were prepended to the naturalised gauged record for each station. This gave a composite record extending from 1 January 1910 to 31 December 2016 at each site.

Areal-rainfall adjustment factors, and open water losses for the Ely Ouse, were then applied as for the naturalised gauged records to give four composite series representing natural flows at each of the Points of Interest for the period 1910-2016.

The new flows are generally higher than indicated in the previous records, particularly in the pre-1965 era. However, they now also include the 1920-21 drought, which is more severe for the Essex system than the 1933-34 drought and replaces it as the critical drought.

Derivation of new flow denaturalisation profiles

Naturalisation attempts to remove the influence of human activity over time from the river flow records to leave the naturally-varying response of the catchments to the historic rainfall and evaporation signals. However, these influences continue to take place and have an impact on the available water resources. They must therefore be added back in to the record, but in a way that is consistent and takes account of known and/or potential future uses by third parties.

The existing flow denaturalisation profiles in the Essex System model had been derived using 1996 abstraction return data, so it was decided to derive new profiles that relate to more recent usage.

Following discussion with the Environment Agency, separate approaches were adopted for each of the main influences, as follows:

- Surface water discharges - the most recent estimates of the total discharge for each of the upstream catchments was summed to give a monthly profile. The intervening un-gauged catchments between the upstream gauges and the POIs were checked for any additional discharges, which were then added in to the total.
- Surface water abstractions - the vast majority of these relate to spray irrigation (SI) abstractions, either for direct use in summer, or to replenish winter storage for use in the subsequent summer. SI usage is notoriously difficult to predict from one year to the next, being governed by market forces as much as land use, rainfall, and temperature. For this reason it was agreed to use the maximum licence return over the last five years (2010-2015) for each individual licence, distributing the volume abstracted equally over the months for which that abstraction is licensed. This gave a monthly profile of annually abstracted maxima. All surface water abstractions were treated in this way.
- Ground water abstractions (Essex Rivers) - the Essex Rivers were treated differently to the Ely Ouse catchments. This is because virtually all ground water abstractions in the Essex river catchments are for public water supply, and so are much more uniform, whereas in the Ely Ouse basin a large proportion are used for SI. For the Essex Rivers the Recent Actual ground water impacts were extracted from the regional ground water modelling runs as close to the POIs as was available. The mean monthly impact over the last six years of model runs (2009-2014) was derived to give a monthly profile of

abstraction. This was added to the surface water abstraction monthly profile to give a total monthly abstraction profile.

- Groundwater (GW) abstractions (Ely Ouse catchments) – the regional GW modelling results do not allow for the SI method described above, so an alternative was adopted. All of the gauging stations used in this study are on unconfined Chalk, so it was assumed that all GW abstractions were to the detriment of river flows. Therefore the GW SI abstractions were treated in exactly the same way as surface water SI abstractions. Monthly public water supply abstractions, on the other hand, were averaged over the last six years and the resulting monthly profile combined with the ground water SI monthly profile to give a total GW abstraction profile. This GW profile was then added to the surface water abstraction profile to give an overall monthly abstraction profile for the gauged Ely Ouse catchments. There were no significant ground water abstractions downstream of these gauges that would affect river flows, so no further adjustments were necessary.

3.2.4 Deployable output modelling assumptions and set-up

For the purposes of DO assessment, the Essex System model has been set-up using with the following assumptions:

- Reference Levels of Service demand reductions:** The WRPG does not specify the percentage of demand reduction that should be used for the reference levels of service (LoS). We, in consultation with the Environment Agency, have therefore applied the most appropriate reductions from our planned LoS to the reference LoS. The demand reductions for each scenario are shown in Table 3.1 below.

Table 3.1: Demand Reductions

Scenario		Appeal for Restraint		Phase 1 Temporary Use Ban (TUB)		Phase 2 Drought Order Ban	
		Freq.	% demand reduction	Freq.	% demand reduction	Freq.	% demand reduction
1	No restrictions	x		x		x	
2	Planned LoS	1 in 10 years	7%	1 in 20 years	5%	1 in 50 years	2%
3	Reference LoS	x		1 in 10 years	5%	1 in 40 years	2%

To reflect likely operational practice, as well as return period curves, implementation of the demand reduction actions during a model run are controlled by the 'hold' and 'delay' facility in Aquator. These are set to hold demand reduction actions for a

minimum of 31 days once triggered; to delay the implementation of the Phase 1 Temporary Use Ban (TUB) for 21 days after Appeals for Restraint; and to delay implementation of a Phase 2 Drought Order Ban for 3 months (93 days) after a Phase 1 TUB. These delays reflect the likely time it would take to consult, and gain consent to implement, these customer demand reduction actions. The planned levels of service scenario set-up is shown below:

Level	Delay	Hold	Days
1	0	31	0
2	21	31	0
3	93	31	0
4	0	0	0
5	0	0	0

Figure 3.2: Planned Levels of Service scenario set-up

For the reference levels of service scenario, the hold and delay set-up for the demand reductions actions were altered to reflect the change from our planned levels of service, shown below.

Level	Delay	Hold	Days
1	0	0	0
2	0	31	0
3	93	31	0
4	0	0	0
5	0	0	0

Figure 3.3: Reference Levels of Service scenario set-up

- ii. **Supporting Resources:** The ‘planning’ control curves for EOETS and groundwater support were applied in the Hanningfield and Abberton Reservoir Group component sequences to trigger the supporting resources. The Stour Augmentation Groundwater Scheme (SAGS) and Langham groundwater resources were made available when the combined storage crossed the groundwater support curve. The Great Ouse Groundwater Scheme (GOGS) resource was made available after a delay of 28 days once the control curve was crossed, to represent operational procedure.

The frequency with which the use of SAGS and GOGS is triggered is dependent on the groundwater control curve and the demand placed on the water resource system during a model run. A new planning groundwater control curve was derived for use in the PR14 WRMP. As directed by the Agency during consultation, the derivation of the groundwater support control curve was based

on the assumption that groundwater support resources should only be available in drought years, to reflect operational practice. Once derived, the control curve was used to trigger groundwater support in order to achieve the required refill reliability, and ensure that the Essex reservoirs are sufficiently full by the start of the drawdown period.

- iii. **Emergency Storage:** When drought resources and demand reduction actions are included in a DO assessment, an allowance for emergency storage must be made. If the DO of the system, derived with drought resources and demand reduction actions included, is used for water resources planning purposes, inclusion of emergency storage is required to reduce the risk of the system failing if a drought more severe than the design drought was to be experienced.

During PR09, we worked with the Environment Agency to find a pragmatic approach to calculating emergency storage provision. The calculation is based on the volume required to meet demand for 30 days during a drought, accounting for the supply from supporting resources, including the Langford Recycling Scheme, SAGS, Langham groundwater sources and GOGS, and also that the demand on the system will have been reduced by demand reduction actions. It is assumed that the supporting resources will be reliable throughout a drought and so the demand met by these resources is deducted from the demand placed on the reservoirs.

Emergency storage is added on top of reservoir dead storage, which by definition is unavailable for abstraction under any circumstances. The resulting emergency storage levels, which are the lowest levels the two reservoirs can be drawn down to in the model runs that include demand reduction actions, are shown in table 3.2 below:

Table 3.2: Emergency Storage Levels

	Capacity		Dead Storage Volume		Emergency Storage Volume		Emergency Storage Level	
	MI	MI	MI	%	MI	%	MI	%
Hanningfield	26,075	3,911	15		4,005	15.36	7,916	30.36
Abberton	41,375	3,807	9.2		6,355	15.36	10,162	24.56
Total	67,450	7,718			10,360		18,078	

3.2.5 Results

Three baseline DO scenarios are required to be assessed, to demonstrate the impact of 'levels of service' (i.e. demand reduction actions) on DO. They are:

1. **No restrictions:** The constant rate of supply that can be maintained from the resource zone throughout the entire period of assessment, with no customer restrictions applied.

2. **Water Company planned levels of service:** The rate of supply that can be maintained from the resource zone when the system is operated to meet our planned levels of service. The DO resulting from this scenario is used in the supply demand planning tables.
3. **Reference scenario levels of service:** The rate of supply that can be maintained from the resource zone throughout the entire period of assessment when the system is operated to meet specified levels of service. These are for temporary customer use restrictions of 1 in 10 years and non-essential use restrictions of 1 in 40 years.

The DO of the Essex System under these three baseline DO scenarios is shown in the table below.

Table 3.3: Essex System Deployable Output Scenarios

Deployable Output Scenario		Supporting Resources				Demand Reductions			Minimum reservoir drawdown level	Deployable Output (M/d)
		EOETS	SAGS	Langham BHS	GOGS	Appeals for restraint (7%)	Phase 1 TUB (5%)	Phase 2 Drought Order Ban (2%)		
1	No restrictions	✓	✓	✓	✓	x	x	x	Dead storage	391
2	Planned LoS	✓	✓	✓	✓	1 in 10 years	1 in 20 years	1 in 50 years	Emergency storage	390
3	Reference LoS	✓	✓	✓	✓	x	1 in 10 years	1 in 40 years	Emergency storage	390

In our draft WRMP, we included a sustainability reduction for an emergency-use groundwater source that may affect the River Brett, however we did not allow for this sustainability reduction in our draft WRMP DO assessment, as there was insufficient evidence regarding what the total sustainability reduction for all abstraction licence holders should be in order for the River Brett to reach good status. Additionally, there was insufficient evidence to confirm what the apportionment of effect should be between ourselves, Anglian Water and Affinity Water. The Environment Agency has since undertaken further assessments and revised our sustainability reduction to 4.5 MI/d, which has now been allowed for in our Essex System Aquator model and included in the calculations of our Essex System DO. The inclusion of this sustainability reduction reduces the Essex System Planned LoS deployable output from the figure reported in our draft WRMP by 2 MI/d.

3.3 Essex System Sensitivity Testing against a 1 in 200 year drought

To test the resilience of the Essex System against droughts not represented within the baseline DO assessment, the Aquator Scottish Method DO Analyser was utilised. The Analyser runs the model multiple times with an incrementally increasing overall demand, similar to the English & Welsh method, however instead of ceasing the analysis at the first failure, the Analyser keeps running and for each overall demand counts the number of failure years in the analysis period.

The number of failure years occurring for each demand tested is outlined in Table 3.4. The return period of the number of failure years is then calculated based on the total record length and overall demand is plotted against the return period of each number of failure years, creating a linear trend line representing the relationship between the demand and return period, shown in Figure 3.4.

Table 3.4: Results of Essex System Aquator Scottish Method DO Assessment

Demand, MI/d	Number of Failure Years
391	1
392	2
398	4
401	7
402	10
403	12
405	14
406	21
408	23
409	29
410	44
411	54

Demand, MI/d	Number of Failure Years
412	62
413	99
414	102




Figure 3.4: Graph of results of Essex System Aquator Scottish Method DO Assessment

For a drought with a 0.5% Annual Exceedance Probability (i.e. a 1 in 200 years return period drought), the result was a DO of 391 MI/d, a 1 MI/d increase from baseline DO.

Confidence Labelling

We have assigned the confidence label of 'AA' to the DO figures for the Essex System, using the matrix provided in the guidance, and reproduced in section 3.1. The Essex System is a conjunctive use system with a medium to high degree of constraints on output. The Essex System Aquator model includes up-to-date, validated and consistent quality constraint data and therefore is assessed as an 'A' for this parameter. We are confident that the model satisfactorily reflects the constraints within the system.

The length of the hydrological data set is 107 years, and it incorporates an adequate number and range of drought years, and a sufficiently severe drought (1921/22) for water resource planning purposes. Therefore for this parameter, the label 'A' has been assigned, giving an overall confidence level of 'AA'.

3.4 Suffolk Surface Water Source Deployable Output Assessment

3.4.1 River Bure and Ormesby Broad

Background

Abstraction from the River Bure, Ormesby Broad, and groundwater chalk sources in the Bure valley is authorised by a group abstraction licence (Licence number 7/34/09/*S/0054), which allows a total annual quantity of 10,000 MI to be abstracted. The main conditions of the licence are summarised in Table 3.5 below.

Table 3.5: Ormesby / Bure Licence Conditions

Source	Instantaneous (l/sec)	Daily Quantity (MI/d)	Annual Quantity (MI/annum)
River Bure	316	27.2	10,000 (7,500MI between April to October)
Ormesby Broad	581	36.3	

An insignificant contribution is abstracted from the groundwater sources which tend to be only used as emergency sources when abstraction from the River Bure intake is not possible. This is generally due to elevated turbidity and/or nitrate concentrations following major rainfall events.

The bulk of the abstraction comes from the River Bure and Ormesby Broad, with close to the total 10,000MI limit being abstracted in most years. The quantity abstracted from each intake often depends on the source water quality and may result in more water being abstracted from Ormesby Broad one month and less in another. However, a review of the abstraction return data shows that on average, approximately 40% of Distribution Input (DI) is satisfied by the Broad and 60% by the Bure.

Review of Consents

The Ormesby Broad and River Bure abstraction licence was identified by the Environment Agency and Natural England as having the potential to significantly affect the hydrology of the Trinity Broads Special Protection Area and the Bure Broads & Marshes Special Protection Area and therefore impact on the condition of the water dependant designated features. Consequently, we investigated the sustainability of our abstractions under the Agency’s AMP3 and AMP4 National Environment Programme (NEP) while the Environment Agency considered the abstractions under its Review of Consents process.

The abstraction licence conditions relating to the River Bure and Northern Central Boreholes 5 and 8 were reaffirmed as no likely significant effects arising from our abstraction.

In terms of the Ormesby Broad abstraction, the licence was modified to include an abstraction cessation level of -0.44mAOD, subject to mud pumping, to maintain a minimum water depth across the Trinity Broads system of 0.3m.

PR19 Deployable Output: Ormesby Broad

The annual quantities of water abstracted from Ormesby Broad in the following drought years was:

1995/96:	3,910MI
1996/97:	3,489MI
1997/98:	3,820MI

This DO assessment is based on Ormesby Broad water levels and abstraction quantities for the year 1996/97. This is because:

- 1996/97 is the year the abstraction cessation level is based on;
- 1996/97 follows a preceding dry year in 1995/96; and
- The NEAC regional groundwater model shows that groundwater levels in 1996/97 were lower than those during other drought years including 1976.

Given the above, the annual average DO for 1996/97 is:

$$\frac{3,489 \text{ MI/annum}}{365 \text{ days}} = 9.56 \text{ MI/d}$$

A drought worse than 1996/97 could happen, in which case Broad water levels could fall below the abstraction cessation level when abstracting the same quantity of Broad water as that in 1996/97. However, a new abstraction regime was implemented in 2015 to:

- i. Ensure that the same annual quantity abstracted in 1996/97 can be abstracted while still maintaining a Broad level above the new abstraction cessation level; and
- ii. Ensure compliance with the Abstraction Incentive Mechanism (AIM).

The new abstraction regime required the development of control bands (see Figure 3.5 below), each of which specifies a different ratio of source water that should be abstracted. When winter Broad levels are high, it is possible to abstract a greater proportion of Broad water which otherwise would be pumped from the Muckfleet Channel and lost to sea.




Figure 3.5: Ormesby Broad Abstraction Regime

Conversely, as Broad levels fall, the proportion of source water abstracted from the Broad reduces, thus conserving Broad storage. This is important for two reasons:

- i. To manage Broad levels so that they remain above the cessation level; and
- ii. To ensure that some storage above the cessation level remains should abstraction from the River Bure be constrained by the Bure Minimum Residual Flow (MRF) conditions (as was the case on 38 days during the 1976 drought)

Where abstraction from the Bure is constrained by the MRF, the balance required to meet customer demand would have to be met by the Broad and from increased transfer from the Lound supply zone. Under this scenario, Broad abstraction may need to be higher than the control band ratio would normally allow. However, this would be possible, as with the new abstraction regime, Broad storage will be greater than it otherwise would have been.

The peak DO for Ormesby Broad is 10.7 Ml/d. This is based on the quantity of water that can be treated through the Candy process stream.

PR19 Deployable Output: River Bure

There are flow conditions on the licence relating to abstraction from the River Bure as set out in the East Anglian (Bure Valley) Water Order 1964.

When the rates of flow in the River Bure, as measured by the Environment Agency gauging station at Ingworth, correspond with those specified in Table 3.6 below, the daily rate of abstraction must be reduced accordingly.

Table 3.6: River Bure MRF Conditions

Rate of Flow at Ingworth GS (MI/d)	Daily Rates of Abstraction from the River Bure not to exceed (MI/d)
≥38.88	27.2
<38.88 but ≥36.29	22.73
<36.29 but ≥33.26	20.45
<33.26	18.18

The River Bure pumping station is capable of abstracting the full unrestricted daily licensed volume of 27.2 MI/d.

Historical Droughts

River Bure flow data from the Environment Agency’s Ingworth gauging station from 1975 to 2011 is presented in Figure 3.6. The characteristic drought year for the zone is 1976 but there are a number of other dry years in the record particularly in the early 1990s that may be useful to assess. The total annual flow and minimum daily flow was calculated for each year of the data set and those five years with the lowest in respect of both measures, as shown below in

Table 3.7, were investigated further by plotting the flow duration curve for each year (Figure 3.7).




Figure 3.6: River Bure flow at Ingworth gauging station (1975-2011)

Table 3.7: River Bure Total Annual Flow

Year	Total Annual Flow (MI)	Year	Minimum daily flow (MI/d)
1991	23,745	1976	33.09
1992	25,507	1992	34.13
1996	26,626	1996	34.82
1990	26,869	1991	35.08
1976	27,617	1990	36.81




Figure 3.7: Flow duration curves for the five driest years on record at Ingworth Gauging Station (1975-2011)

The low flow end of the flow duration curve is the most pertinent to this assessment, specifically the flows below 38.88 MI/d, as this is the first trigger requiring the abstraction rate to be reduced. By comparing the flow duration curves it can be seen that 1976 experienced flows of less than 40 MI/d for the most number of days, and so this year has been used to assess water availability in a worst case scenario.

Assessing river water availability

Daily Abstraction

Daily mean river flow at Ingworth gauging station for 1976 was used to assess how constrained abstraction from the River Bure could be if a drought of similar severity were occur again. 1976 is characterised by low flows from January through to September as shown in Figure 3.8.

Assessment of the data from Ingworth gauging station from 1976 shows that a flow equal to or greater than 38.88 MI/d occurred on 327 days (89.6% of the time), which could support the maximum daily licensed abstraction of 27.2 MI/d, with continuous

abstraction at this rate achievable between 1 January and 23 June, and 28 August and 31 December, with an additional period of 26 days between 16 July and 10 August (Figure 3.9).




Figure 3.8: River Bure daily mean flow at Ingworth gauging station during 1976 and long term (1975-2011) minimum, average and maximum flow




Figure 3.9: River Bure flow at Ingworth during 1976 and the flow conditions for a reduction in ESW abstraction

A flow less than 38.88 MI/d but equal to or greater than 36.29 MI/d, which could support a daily licensed abstraction of 22.73 MI/d, occurred on 18 days (4.9% of the year), during the last week of June and middle of August.

A flow less than 36.29 MI/d but equal to or greater than 33.26 MI/d, which could support a daily licensed abstraction of 20.45 Mld, occurred on 18 days (4.9% of the year), between 27 June and 14 July, and for 4 days in August.

A flow of less than 33.26 MI/d, which would require a reduction in our abstraction from the River Bure to 18.18 MI/d, occurred on 2 days (0.5% of the year), on 8 July and 24 August.

Given the above, taking an average of the following gives a dry year annual average DO of 26.67 MI/d:

- 327 days at 27.2 MI/d
- 18 days at 22.73 MI/d
- 18 days at 20.45 Mld
- 2 days at 18.18 MI/d

The Broad Dry Year Annual Average (DYAA) DO has been calculated to be 9.56 MI/d, and the Bure DYAA DO to be 26.67 MI/d. The sum of the DO values (36.23 MI/d) is significantly higher than the annual average daily allowance of the group abstraction licence of 27.4 MI/d, therefore it is assumed that the maximum DO would be taken from the Broad (9.56 MI/d) and the Bure DYAA DO is reduced to 17.84 MI/d for reporting purposes.

Given the full daily licence of 27.2 MI/d was achieved on 327 out of 365 days, the peak DO is 27.2 MI/d.

Annual Abstraction

The daily flow at Ingworth gauging station in 1976 was used to calculate the daily volume that would have been available for abstraction, adhering to the required reduction in abstraction rates as river flow decreases. These daily volumes were then summed up to give a total annual abstraction volume of 9,735MI, less than the annual licensed volume of 10,000MI, which includes all of the raw water sources for Ormesby WTWs (Ormesby Broad, River Bure and groundwater sources). This calculation indicates that even in a severe drought, almost the whole Ormesby annual abstraction licence could potentially be taken from the river source. Thus, abstraction from Ormesby Broad could in theory be reduced to adhere to potential new abstraction cessation levels, in favour of abstraction from the River Bure if resources are available from this source.

PR19 DO Assessment Summary

The PR19 DO figures are as follows:

Table 3.8: PR19 DO

	Source Average DO MI/d	Peak DO MI/d
River Bure	17.84	27.27
Ormesby Broad	9.56	10.70
Northern Central Borehole 8 *	0.54	6.80
Northern Central Borehole 5 *	0.47	6.80
Ormesby Bure Group Licence	27.40	51.57

* Groundwater sources are operated by ESW as emergency use groundwater sources due to elevated nitrate and silica. Average DO is based on dry year annual average utilisation.

All of the 10,000MI/annum licensed quantity was abstracted in each of the drought years from 1995 to 1997. This provides further confidence that the combined average DO figures for the Bure and Ormesby Broad (which equate to the equivalent annual licensed quantity of 27.4 MI/d) are robust.

3.4.2 River Waveney DO Assessment

The water resource software Aquator was used to develop a model of the system, which included the River Waveney’s catchment inputs, the Environment Agency’s river support groundwater sources which are collectively known as the Waveney Augmentation Groundwater Scheme (WAGS), and the licence constraints of the Shipmeadow intake. The model development is detailed in the report River Waveney Water Resource Modelling & Deployable Output Calculation (Essex & Suffolk Water, 2009).

The DO of the Shipmeadow intake on the River Waveney was calculated to be 20.5 MI/d using Aquator. This is an increase from the DO of 13.8 MI/d reported in the draft WRMP. A review of the River Waveney Aquator model was undertaken as it was felt that the effect of the climate change scenarios on the DO figures reported in the draft WRMP was unrealistically severe. It was agreed between ESW and the Environment Agency that the issue may stem from a fixed loss of 18.81 MI/d deducted from all flows entering the river reach between Needham and Ellingham Mill gauging stations in the model, upstream of the Shipmeadow Intake, and therefore the method of representing river transmission losses in the model should be updated.

In the River Waveney Aquator model, the WAGS boreholes operate with a 75% efficiency, but are also required to support a maintained flow at Ellingham Mill. This effectively means that the boreholes already lose 25% of discharge before it enters the river system, and therefore the boreholes over-discharge to compensate for this loss. Upon discussion with the Environment Agency it was decided that, given losses are in line with the observed net gain at Shipmeadow Intake, the 25% efficiency loss from the boreholes would already be sufficient to cover river transmission losses. Therefore, the action taken was to remove the 18.81 MI/d fixed river flow loss from the river reach upstream of Ellingham Mill in the model.

The DO of the Shipmeadow intake is constrained by abstraction limits based on river flows. Figure 3.10 shows the modelled river flow at the Shipmeadow intake during the summer of 1997, a known severe drought year (section 2.9.1), and how the licensed abstraction volume is reduced to 20.5 MI/d when the river flow falls below 53.4 MI/d.




Figure 3.10: Waveney flow and abstraction licence constraints

It can be seen from Figure 3.10 that for 98% of the year, there is sufficient river water to support potential abstraction of the maximum daily licensed volume of 28 MI/d. Quantifying this availability is required to inform future resource and infrastructure development of Barsham WTWs and the Northern Central Water Resource Zone.

3.4.3 Lound and Fritton Lake DO Assessment

Background

Fritton and Lound Lakes are located within the Northern Central WRZ near to the coastal town of Lowestoft. Fritton Lake has no conservation designations while Lound Lakes are designated a County Wildlife Site.

Abstraction licence 7/34/19/S/60 authorises abstraction from the lakes at the following licensed quantities:

- Annual licence: 2,955MI/annum
- Annual average licence: 8.10 MI/d
- Peak daily licence: 20.40 MI/d

Abstraction is via an intake located on Lound Run pond. Surface water flows into Lound Run Pond from other Lound ponds to the east and from Fritton Lake to the

west. The water is then treated at Lound WTWs before being pumping into the distribution network for onward supply to customers.

Fritton Lake is thought to be a flooded peat digging while Lound lakes were created at the start of the 20th century for the purpose of water storage. They were dug along the valley line of a natural watercourse, which would originally have drained into the River Waveney. The lakes are spring-fed from the underlying Crag aquifer, although runoff, direct rainfall and some small dykes also contribute to the volume of water stored in the lakes. In addition to losses from evapotranspiration, outflows include discharge from Fritton Lake into the River Waveney and our abstraction.

PR19 DO Assessment

The average and peak DO figures for Lound Lakes and Fritton Lake used in the previous four periodic reviews were 8.09 MI/d and 13.40 MI/d respectively. This assumed DO was licence constrained where the annual licensed quantity is 2,955 MI and the equivalent annual average daily licence is 8.095 MI/d.

The surface area and storage capacities for Fritton and Lound Lakes are as follows:

Table 3.9: Lake Surface Area and Volume

Lake	Surface Area (km ²)	Storage Volume (MI)
Fritton Lake	0.56	4,453
Lound Lakes	0.13	121
Total	0.69	4,574

Fritton Lake comprises 81% of the total open water but 97% of the total lake storage. Consequently, this assessment focuses on Fritton Lake.

Figure 3.11 shows minimum, mean and maximum Fritton Lake water levels. The minimum (lowest) surface water level is a combination of water levels observed in the drought years of 1991/92 and 1996/97.




Figure 3.11: Fritton Lake Min, Mean and Max Water Levels

A water balance model for Fritton Lake does not exist. However, it is possible to calculate an indicative water balance based on an observation that Fritton Lake water level increases by 100mm for every 25mm of rainfall as measured at Lound WTWs. This relationship is used to determine inflows for the drought year of 1996 and for an average year.

1996 Scenario

Annual rainfall: 467mm
Rainfall / Storage relationship: 1 to 4

$467\text{mm} \times 4 = 1868\text{mm} (1.87\text{m})$

Using the Fritton Lake storage tables, 1.87m is equivalent to a volume of 2,303MI/annum (78% of the annual licence).

Average Year Scenario

Annual rainfall: 630mm
Rainfall / Storage relationship: 1 to 4

$630\text{mm} \times 4 = 2520\text{mm} (2.52\text{m})$

Using the Fritton Lake storage tables, 2.52m is equivalent to a volume of 3,203MI/annum (108% of the annual licence).

These estimates are supported by Figure 3.12 below which shows that following the low lake levels in 1992/93, lake levels quickly recovered to a level that necessitated Internal Drainage Board (IDB) pumping into the River Waveney. However, lake levels in the 1996/97 recharge season only recovered to ~0.2mAOD reflecting the below average winter rainfall and recharge. Nevertheless, even following a dry summer in 1997, lake levels fully recovered in the 1997/98 winter following above average rainfall.

IDB pumping to the River Waveney has been required in all subsequent years.




Figure 3.12: Fritton Lake Surface Water Levels

Crag groundwater levels have previously been monitored by us at Lound WTW. Figure 3.13 below presents groundwater levels for the period 2007 to 2012.




Figure 3.13: Lound Crag Groundwater Levels

The time series includes data for the 2012 drought although not for a 1990s drought year. However, even in 2012, groundwater levels are significantly above Fritton Lake bed level and indeed above the top lake water level. This suggests that there would always have been the potential for vertical groundwater flow into Fritton Lake. Monitoring of groundwater levels in the Lound boreholes will recommence once the Environment Agency has confirmed the next drought for the area.

Summary

An estimated Fritton Lake inflow (rainfall, runoff, tributary inflows and groundwater inflow) suggests that in a drought year, inflow may be in the region of 78% of the annual licence while in an average year, this increases to 108% of the annual licence.

Although in a drought year, inflows account for only 78% of the annual licence, the remaining 22% can be supplied by Lound Lakes to the east of Fritton Lake.

The annual licensed quantity of 2,955 MI/annum was fully utilised in 1995/96 and 1996/97 and was satisfied by abstraction from both Fritton Lake and Lound Ponds. As the full annual licence was utilised in these drought years without any significant adverse effects, the average and peak DO values are assessed to remain at 8.09 MI/d and 13.40 MI/d respectively.

Further Work

We had intended to develop a water balance model in AMP6 so that the water balance calculation could be refined, specifically the groundwater inflow and lake

discharge to the River Waveney. However, it has not been possible to install a flow gauging station on the outlet of Fritton Lake due to ground conditions and the lack of power. Additionally, the preferred gauging station would be a v-notch weir with an ultrasonic probe. However, it is not possible to install a v-notch weir as this would create a further barrier to eel passage.

3.5 River Waveney and River Bure DO Sensitivity Testing Against a 1 in 200 year drought

3.5.1 River Waveney

To test the resilience of the River Waveney system to a drought not represented by the baseline DO assessment, the Aquator model was run with stochastic inflows for a 0.5% Annual Exceedance Probability (i.e. 200 year return period) drought. The stochastic weather data was generated for the Water Resources East (WRE) project and then imported into the Environment Agency’s regional model to generate a River Waveney flow sequence for a 1 in 200 year drought. Two sets of flows were provided – one for a naturalised scenario, and one for a fully licensed scenario. The results of the assessment are provided in the table below.

Table 3.10: Results of River Waveney Stochastic Drought Assessment

Flow Scenario	DO (MI/d)	Change from baseline (MI/d)
Naturalised	20.5	0
Fully Licensed	20.5	0

Both sets of stochastic flows produce the same DO as the baseline, indicating that a 1 in 200 year drought would not constrain resource from the River Waveney.

3.5.2 River Bure

To test the resilience of the River Bure to a drought not represented by the baseline DO assessment, the assessment process was repeated using stochastic flows for a 200 year return period drought. The stochastic weather data was generated for the WRE project and then imported into the Environment Agency’s regional model to generate a River Bure flow sequence for a 1 in 200 year drought. Two sets of flows were provided – one for a naturalised scenario, and one for a fully licensed scenario. The results of the assessment are provided in the table below.

Table 3.11: Results of River Bure Stochastic Drought Assessment

Flow Scenario	DO (MI/d)	Change from 26.67 MI/d baseline (MI/d)
Naturalised	22.89	-3.78
Fully Licensed	22.84	-3.83

Both results for the 1 in 200 year drought are higher than the 17.84 MI/d baseline DO we are reporting for this draft WRMP, therefore a 1 in 200 year drought would not constrain DO for the River Bure.

3.6 Essex and Suffolk Groundwater Source Deployable Output Assessment

3.6.1 Methodology

DOs for Essex and Suffolk groundwater sources have been determined using the standard UKWIR methodology entitled “A Methodology for the Determination of Outputs for Groundwater Sources” (UKWIR, 1995a).

This methodology has been used to determine dry year annual average DO and is based on utilising either analytical test pumping data and/or operational data (including drought periods) in the form of water level/output data to assess source performance.

A graph of this information on a water level-output plot can then be utilised to determine a lower bounding ‘drought curve’ for the source. The drought curve can then be compared with key water-level and output constraints such as licence limits, pump capacity, water treatment works capacity, deepest advisable pumping water level and pump intake depth in order to determine DO. The DO is defined as the point at which the drought curve intersects the most restricting water-level or output constraint.

The DO determination for the average demand condition ideally utilises average monthly source output and monthly lowest pumping water levels in drought years. Where only analytical step pumping test data has been used, this has been extrapolated to 200 days in order to estimate the likely draw down that would occur over longer periods of time than those typically encountered during step test pumping.

An example of a DO assessment using the above methodology is illustrated in Figure 3.14 below.




Figure 3.124: Example Deployable Output Assessment

3.6.2 Confidence Labelling

As in our PR09 and PR14 WRMPs, the operational and test pumping data sets used in this assessment often include the 1991/92 and 1996/97 droughts unless the groundwater source was developed after this date. In order to assess whether there are any other droughts prior to the 1990's, we requested that the Environment Agency's NEAC and Essex regional groundwater models were run back to 1970 (this is the model's earliest possible start date), thereby including the 1976 drought. The baseline (no climate change) model runs show that the lowest groundwater levels were observed in 1997. This is illustrated in Figure 3.15 below.



Figure 3.15: Example Baseline Model Run (1970 onwards)

This finding provides for a robust assessment given the wider data availability and also that it is a recent drought and so groundwater source performance and our ability to maintain supply is well known.

We have assigned the confidence label of ‘AC’ to the Essex and Suffolk groundwater source DO figures using the matrix provided in the guidance, and reproduced in section 3.1. The constraints data is available and of a consistent quality (A) while the length of the hydrogeological record is less than 70 years (C). Although the assessment is based on less than 70 years of data, the regional model runs go back to 1970 and incorporate an adequate number and range of drought years including those of 1976 and in the 1990’s.

3.6.3 Essex Groundwater Source Deployable Output

DOs for the Essex groundwater sources near Stifford, Roding and Colchester have been determined using the above approach.

The results of the PR19 WRMP DO Assessment are detailed in a report entitled Essex & Suffolk Water Deployable Output Assessments (Essex & Suffolk Water, 2017a).

The following table summarises the groundwater DO figures determined for the Essex resource zone:

Table 3.12: Essex Groundwater DO

Source	Annual Average Deployable Output (MI/d)
South Essex Well 1	3.5
South Essex Well 2	3.4
Colchester Borehole 1	1.93

3.6.4 Suffolk Resources Zones Deployable Output

Annual average DOs for the Suffolk groundwater sources have also been determined using the above UKWIR methodology.

The following table summarises the groundwater DO figures determined for the Suffolk water resource zones.

Table 3.13: Suffolk Groundwater DO

Source	Average DO		Peak DO		
	(MI/d)	Constraint	(MI/d)	Constraint	
Blyth					
Blyth Borehole 1	3.170	Distributed Annual Licence	4.546	Daily Licence	
Blyth Borehole 2	2.210	Annual Licence	2.730	Daily Licence	
Blyth Borehole 3	2.270	Annual Licence	2.935	Daily Licence	
Blyth Borehole 4	3.110	Annual Licence	3.888	Daily Licence	
Blyth Borehole 5	0.290	Distributed Annual Licence	1.137	Daily Licence	
Blyth Borehole 6	0.780	Distributed Annual Licence	0.909	Daily Licence	
Blyth Borehole 7	2.850	Distributed Annual Licence	3.864	Daily Licence	
Hartismere					
Hartismere 1	0.548	Annual Licence	1.600	Daily Licence	
Hartismere 2	0.630	Annual Licence	1.091	Daily Licence	
Hartismere 3	0.450	Annual Licence	0.900	Daily Licence	
Hartismere 4	0.000	Emergency Use Only	3.637	Daily Licence	
Hartismere 5	3.020	Annual Licence	3.637	Daily Licence	
Hartismere 6	1.250	Annual Licence	2.273	Daily Licence	
Hartismere 7	2.749	Annual Licence	5.364	Daily Licence	
Northern Central					
Northern Borehole 1	Central	7.120	Annual Licence	7.274	Daily Licence
Northern Borehole 2	Central	3.410	Annual Licence	3.410	Daily Licence
Northern Borehole 3	Central	2.000	Annual Licence	2.592	Daily Licence

Source		Average DO		Peak DO	
		(MI/d)	Constraint	(MI/d)	Constraint
Northern Borehole 4	Central	2.356	Annual Licence	2.356	Daily Licence
Northern Borehole 5	Central	0.470	Annual Licence	6.900	Daily Licence
Northern Borehole 6	Central	1.350	Distributed Annual Licence	2.273	Daily Licence
Northern Borehole 7	Central	1.510	Distributed Annual Licence	2.455	Daily Licence
Northern Borehole 8	Central	0.540	Annual Licence	6.900	Daily Licence
Northern Borehole 9	Central	1.900	Distributed Annual Licence	2.273	Daily Licence
Northern Borehole 10	Central	2.279	Annual Licence	2.279	Daily Licence
Northern Borehole 11	Central	1.230	Annual Licence	1.630	Daily Licence
Northern Borehole 12	Central	0.000	Emergency Use Only	0.000	Emergency Use Only

3.7 Groundwater Deployable Output Sensitivity Testing Against a 1 in 200 Year Drought

To test the resilience of our groundwater sources to a 1:200 year drought, Amec Foster Wheeler (AFW) was employed to carry out groundwater modelling using the Northern East Anglian Chalk (NEAC) and Essex regional groundwater models.

The stochastic weather data generated for the WRE project was imported into the Environment Agency's regional groundwater models. 1949/50 was determined as being equivalent to a 1 in 200 year drought. The model runs were carried out from January 1900 to December 1990 inclusive, and included a new 4R and Modflow run in each case. New rainfall inputs to 4R were created using the Trace 41 Rainfall and Potential Evapotranspiration (PET) stochastic dataset for nine gauges (V33, V34, V35, V37, V38, V39, V40, V41 and V42). The timeseries data was distributed spatially using Thiessen polygons. This data did not include one gauge in every MORECS square, therefore the PET data for each gauge was simply assigned to the containing Thiessen polygon in the same manner as the rainfall.

Three model runs were carried out for each regional model; 1 in 200 year Naturalised, 1 in 200 year Fully Licensed (FL) and 1 in 200 year Recent Actual (RA) with our sources at FL. It was agreed with the Environment Agency that the most realistic model run was the RA run with all our sources at FL, with the exception of

the North Essex boreholes and Waveney Augmentation Groundwater Scheme (WAGS), which used utilisation and abstraction rates from our Aquator model.

Each NEAC and Essex model run (i.e. Naturalised, FL and RA) with our sources at FL used the same processed rainfall and PET timeseries dataset described above (specific to the model) to maintain consistent climatic conditions. Differences between runs were in the representation of abstractions and discharges.

Modelled groundwater heads for all of our groundwater sources were determined. For each groundwater source the lowest modelled historical water level experienced between 1970 and 2014 was compared with the lowest modelled 1 in 200 year drought groundwater level during 1949 and 1950. The difference between these two groundwater level heads was then applied to the drought baseline curve for each groundwater source reliable output graph to determine whether there was likely to be a reduction in DO due to a 1 in 200 year drought.

The following graph presents an example of how the drought baseline curve was adjusted for Northern Central Borehole 6 to take into account the modelled change in groundwater level for a 1 in 200 year drought event, to determine whether this would affect the DO of the source.




Figure 3.136: Northern Central Borehole 6 reliable output with 1 in 200 year drought

From the groundwater modelling assessment all of our sources were found to be resilient to a 1 in 200 year drought, with no decline in DO. The only exception was the South Essex Well 2 which showed a reduction from 3.4 Ml/d to 1.95 Ml/d.

Further details of this work and the perturbation level applied to each of our groundwater sources for a 1 in 200 year drought is provided in our groundwater deployable output report (Essex & Suffolk Water, 2017a).

3.8 Water Industry National Environment Programme & Effect on Deployable Output

3.8.1 Background

The Water Industry National Environment Programme (WINEP) is a list of environmental requirements produced by the Environment Agency and Natural England that water companies should include in their business plans submitted to Ofwat. It was previously called the National Environment Programme.

The WINEP is an integrated list of requirements for water resources, water quality and fisheries, biodiversity and geomorphology. It consists of investigations, options appraisals and actions to protect (prevent deterioration) and improve the water environment. Actions to protect or improve the environment include both licence changes, also known as sustainability changes, and non-licence change actions, such as river restoration.

WINEP actions generally fall into one of the following categories:

- Investigation;
- Options Appraisal; and
- Implementation

Investigations are required where the Environment Agency suspects that an abstraction could be having an adverse effect on the environment but where the level of certainty is low. Consequently, investigations are required to raise the level of certainty so that conclusions can be drawn over the sustainability of the abstraction. Where an investigation concludes an abstraction is sustainable, the licence is re-affirmed. Where an investigation concludes an abstraction is unsustainable, then a sustainability reduction (i.e. a reduction in the annual and / or daily licensed quantities) is quantified and then implemented.

Options appraisals are required where a sustainability reduction causes a supply deficit. The appraisal considers a series of options which will:

- Reduce demand to eliminate the supply deficit;
- Increase supplies to eliminate the supply deficit; and
- Mitigate any impact on the environment to a level whereby the sustainability reduction is no longer required.

The preferred option may comprise of either one measure or a series of supply, demand and mitigation measures.

The WINEP does not just consider the direct effect of abstraction. It also considers, among other aspects, catchment measures to improve the quality of water at abstraction intakes, invasive non-native species risk, fish passage and discharges to the environment.

The sections below describe:

- Our progress on delivering our PR14 AMP6 National Environment Programme; and
- The PR19 AMP7 WINEP

3.8.2 AMP6 National Environment Programme (NEP)

The PR14 AMP6 NEP included the following:

- Three Review of Consents Implementation schemes:
 - Trinity Broads SAC: Sediment removal via mud pumping
 - Geldeston Meadows SAC: Provision of a compensation discharge
 - Alde Ore Estuary SPA: Provision of a compensation discharge
- Two WFD implementation schemes, both also with an Eel Regulations driver:
 - River Blackwater: Provision of a River Blackwater Sluice Fish Pass
 - Fritton Decoy: Provision of a sluice eel pass
- One Restoring Sustainable Abstraction (RSA) implementation scheme:
 - River Stour at Cattawade: Raise abstraction cessation level from 1.5mAOD to 1.65mAOD; and install variable speed abstraction pumps to pump to a level to reduce daily fluctuation in water level. This will prevent the exposure and re-wetting of river bank which might be responsible for the release of toxins that cause fish stress. Additionally it will help facilitate eel passage.
- Eel Regulations:
 - Fifteen Eel Regulations Implementation Schemes, of which ten were to improve intake screening and six to install or improve eel passes.
 - Six Eel Regulations Investigations to investigate opportunities to facilitate eel passage.
- Water Quality / Drinking Water Protected Areas (DrWPA):
 - A programme of work under the DrWPA driver, implementing catchment schemes to protect raw water quality.

Summary descriptions of the various schemes and investigations are given below:

Trinity Broads SAC

The Trinity Broads (the Broads) are located in east Norfolk and comprise of five interconnected shallow lowland lakes including Ormesby, Ormesby Little, Rollesby, Lily and Filby Broads.

Our public water supply abstraction from Ormesby Broad was identified by the Environment Agency as having the potential to significantly affect the hydrology of the Broads and therefore impact on the condition of the water dependant designated features. Our completed NEP investigations in both AMP3 and AMP4 which fed into the Environment Agency's Review of Consents (RoC) process.

These investigations concluded that while the Broad water inflows and outflows were balanced, a minimum Broad water depth of 30cm was not maintained across the extent of the Broads in a drought year. These areas tended to be close to the margins, within bays and near to Filby Bridge and Rollesby Bridge. Consequently, our River Bure & Ormesby Broad abstraction licence (7/34/09/*S/0054) was modified in 2015 to include a Broad abstraction cessation level of -0.14mAOD. This new abstraction cessation level would have constrained abstraction in a drought year and would have reduced deployable output. Consequently, following the completion of a comprehensive options appraisal, it was agreed with the Environment Agency and Natural England that the abstraction cessation level could be reduced to -0.44mAOD (the lowest drought water level observed in 1996/97), subject to the removal of sediment to ensure that a minimum water depth of 30cm is maintained going forwards across the extent of the Broads.

We completed a significant investment project between September 2016 and April 2017 to remove 10,000 cubic metres of nutrient rich mud from shallow areas of the Broads which had accumulated over decades. As well as maintaining water depths during drought years, removing this mud will encourage the growth of water plants which provide important habitat for wildlife and will also help to maintain clear water supplies to the local water treatment works. The project involved the hydraulic pumping of approximately 50,000 cubic metres of sediment and water which was pumped up to 1km into 'geobags' – huge woven polypropylene bags that retained the solid material and allowed for surplus water to be removed. This was the first time that geobags have been used for a project on this scale in the UK. The de-watered sediment was then used as a soil improver for local farmland.

The work was carefully planned with Norfolk Wildlife Trust, Natural England and local landowners to prevent any disturbance to breeding birds, for which the site is important.

Following completion of the project, the NEP implementation scheme has now been signed off by the Environment Agency allowing the Ormesby Broad abstraction cessation level to be reduced from -0.14 mAOD to -0.44 mAOD.

We are committed to continuing to work with the Broads Authority and the other parties in the Trinity Broads Partnership to deliver the Trinity Broads Management

Plan and are keen to be involved in any workshops run by the Broads Authority to better understand the complex issues around turbidity, water depth, water quality and plant communities in restored shallow lakes, including the use of the PC Lake model to assess potential impact.

Geldeston Meadows

Geldeston Meadows is designated a Site of Special Scientific Interest (SSSI) for its botanical and invertebrate interest and forms part of the Broadland Special Area of Conservation and Broads Special Protection Area. It is located in the Waveney Valley in Norfolk and comprises grazing meadows, ditches with Magnopotamion or Hydrocharition-type vegetation and alluvial woodland.

In AMP4, ourselves and Anglian Water Services (AWS) investigated the effects of our respective local groundwater abstractions on the water dependant features of the site. These investigations concentrated on the effect of historical and current abstraction and concluded that abstraction was unlikely to have a significant effect on groundwater supply to Geldeston Meadows.

The Environment Agency also investigated the effect of historical and fully licensed abstraction as part of its RoC process. Its investigations supported Water Company conclusions regarding historical abstraction although concluded that fully licensed abstraction could cause significant effect.

Given the outcome of the Environment Agency's RoC investigations, ourselves and AWS prepared a comprehensive options appraisal to identify and appraise a series of options that could be implemented to mitigate against potential significant adverse effects whilst minimising any adverse effect on the Water Companies' resource zone supply demand balances.

Our preferred option was to make a compensation discharge into the Geldeston Meadows ditch system. This, along with two new water level management structures, will enable the site conservation objectives to be met.

A compensation discharge of up to 1.35 Ml/d will be made in a dry year similar to or drier than the 1996/97 drought.

Infrastructure is now in place allowing a compensation discharge to be made in future drought years.

Alde Ore Estuary

As part of its RoC process, the Environment Agency has assessed the effect of our Group licence (Blyth WRZ) to establish whether abstraction from local groundwater sources could have significant adverse effect on the Alde Ore Estuary designated features of interest.

The flow from the River Alde is seen as a significant component of the freshwater contribution to the western areas of the Alde Estuary. Since groundwater levels

influence base flow and therefore river flow, groundwater abstraction authorised under the Benhall Group Licence could affect flows in the River Alde. This reduction in flow could increase the mudflat and estuary salinity and reduce the area of grazing marsh. These changes could alter the habitat and food sources available to over-wintering wild fowl and could reduce their numbers.

The Environment Agency completed a comparison of observed river flows against the Alde Ore Estuary's Minimum Residual Flow (MRF) requirement. This confirmed a drought year deficit of approximately 70MI between June and September.

We completed a comprehensive options appraisal to establish how the MRF could be maintained with least impact on the Benhall Group licence DO.

Our preferred option to make a 1.6 MI/d compensation discharge during drought directly into the River Alde has since been implemented.

Fritton Decoy Eel Pass

A dam is located on the outlet of Fritton Decoy to prevent a significant volume of the lake from draining to tide. However, the wooden structure inhibited eel passage when lake levels were low.

In fulfilment of our AMP6 NEP obligations, an improved eel pass will be installed.

River Blackwater Sluice Fish Pass

The Blackwater Sluice at Langford maintains water levels within the upstream channel to allow us to abstract water from its River Blackwater intakes. The structure is also operated to manage flood flows.

The Environment Agency is concerned that the structure prevents fish and eel passage, both up and down stream.

A project has commenced to deliver a new fish pass structure by April 2020. The structure will require a minimum of 3 MI/d flow to allow it to function. The top of the fish pass will be located upstream of our Blackwater intake and Langford Mill intake. Consequently, the 3 MI/d loss of water has been included in the Essex WRZ Aquator model. This has reduced the Essex WRZ DO by 1 MI/d.

Lower Stour

We investigated the potential impact of its raw water abstraction from the North Channel of the Lower River Stour on the Essex/Suffolk border in AMP5. Although there was little evidence, the Environment Agency was concerned that our abstraction from the North Channel could, at times, reduce river levels and expose river-bank sediment. It suggested that this exposure could result in microbes present in the sediment releasing an exotoxin. The exotoxin could then be flushed into the water when the river level rose again and could affect the health of fish.

To prevent such an effect, we have since agreed with the Environment Agency to raise the abstraction cessation level from 1.5mAOD to 1.65mAOD and to install variable speed pumps at its Brantham intake. This will allow variable abstraction to maintain a constant level and will have the following benefits:

- i. A more consistent river level will decrease the extent of river bank subjected to the exposure/submersion cycle reducing the potential source of exotoxin;
- ii. A narrower range of level fluctuation will increase the frequency of wetting and drying and may reduce the potential production of exotoxin by actinomycetes in the river bank; and
- iii. Raising the cessation level from 1.5 mAOD to 1.65 mAOD will result in deeper water in shallow margins and increase the area of habitat available for fish.

The Environment Agency also thought that abstraction of water from the northern channel was resulting in insufficient flows over Judas Gap weir such that the weir becomes a barrier to eel migration.

We have since:

- i. Undertaken to install eel screens on the Brantham river intake to prevent eels from being drawn into the intake and from being pumped to Abberton Reservoir; and
- ii. Agreed to reduce or stop abstraction at Brantham at key times during the autumn to facilitate the downstream migration of eels, subject to water resource status. This is coordinated by the Environment Agency chaired Ely Ouse Essex Transfer Scheme (EOETS) Operators Group.

Eel Regulations Schemes

We are on track to complete our planned Eel Regulations programme during AMP6. So far improved eel screens have been installed at the Lound intakes in Suffolk. Improved screens are due to be installed at the remaining seven intakes by March 2020.

Eel passes have been installed at the Muckfleet Sluice, Stratford St Mary (Glenfield Gates) and Beeleigh Control Gates. Improved or new eel passes are due to be installed at the remaining three locations by March 2020.

All required investigations have been completed at Ormesby Broad, Hanningfield (three sites), Abberton and the Fritton / Lound system.

At Ormesby Broad, the summary outcome of the investigation was that although the Ormesby draw-off intake is non-compliant with The Eels (England and Wales) Regulations 2009 based on Environment Agency defined life stages expected to be present given the distance from tidal limit, best practice screening for smallest life stage expected to be present (elvers) is not cost-beneficial and less than best practice screening (for eels \geq 30 cm) is also not cost-beneficial. The most

appropriate Alternative Measure is the incorporation of a slow-start to pumping regimes.

Flow velocities in the vicinity of the Ormesby intake are typically (75% of time) within the sustained swimming capabilities of eels ≥ 5 cm and observations showed eels of 84 to 154 mm were not involuntarily drawn into the intake structure under the highest pumping rates used during spring / summer. Therefore, the Ormesby draw-off intake is not considered to present a high risk to eel through entrainment and loss, particularly because the current population is skewed towards adult life stages.

The investigation recommended that slow start-up be incorporated into operating regimes and that screening be improved to best practice or near best practice within future routine maintenance / refurbishment programmes.

At Hanningfield the summary outcome of the investigation was that although both draw-off towers are non-compliant with The Eels (England and Wales) Regulations 2009 based on Environment Agency defined life stages expected to be present given the distance from tidal limit, best practice screening (2 mm) is not cost-beneficial and less than best practice screening to protect eels ≥ 30 cm is also not cost-beneficial. The most appropriate Alternative Measure is trap and transport, namely periodic netting to remove the existing resident stock and translocate eels to locations nearby in the River Chelmer / Blackwater. The Sandon Brook Intake is also non-compliant; however, eels are likely absent from the watercourse upstream, with no possibility of ingress, so it is considered that no further action is required at this time.

At Abberton the summary outcome of the investigation was that although the draw-off intake is non-compliant with The Eels (England and Wales) Regulations 2009 based on Environment Agency defined life stages expected to be present given the distance from tidal limit, best practice screening (2 mm) is not cost beneficial. Less than best practice screening is already in place at the draw-off (5 mm spacing) and this is considered sufficient to protect the eel life stages known to be present, as evidenced by empirical eel population surveys conducted in the main reservoir in 2017. No further action is considered necessary at this intake at the present time. The causeway pumping station which conveys water from the central to the main section of the reservoir is non-compliant (75 mm bar screen), however, replacement of the existing screen with best practice screening (2 mm) is not cost beneficial.

Appropriate Alternative Measures are: 1) trap and transport of resident eels to Roman River / Colne estuary, 2) installation of an up-and-over eel pass to enable upstream ingress of eel from Layer Brook in combination with a long-term trap and transport programme, 3) investigate options to enable both natural ingress and egress. These options will be developed further during AMP7.

The design of the eel screens we have installed does not affect our ability to abstract water and has no impact on the DO.

Drinking Water Protection Areas / Water Quality schemes

Ten surface drinking water protected areas (DrWPA) are deemed to be 'at risk' from pesticides, including:

- River Bure and Trinity Broads (Norfolk);
- River Waveney (Norfolk Suffolk border);
- River Stour (Suffolk / Essex border);
- Roman River (Essex);
- Layer Brook and Abberton Reservoir (Essex);
- River Blackwater (Essex);
- River Chelmer (Essex); and
- Hanningfield Reservoir (Essex).

For further information, please see section 3.11 below.

3.8.3 AMP7 Water Industry National Environment Programme (WINEP3)

The Environment Agency's guidance entitled "Sustainable Abstraction" (Environment Agency, 2017d) states that WRMPs should include the requirements set out in the WINEP, which sets out measures needed to protect and improve the environment. By September 2018, there will have been three iterations of the WINEP as follows:

- WINEP1: Issued in March 2017;
- WINEP2: Issued on 29 September 2017; and
- WINEP3: Issued on 30 March 2018.

The Environment Agency has applied a traffic light system to WINEP3 to indicate certainty of measures. It expects all green and amber sustainability changes, as defined in WINEP3, to be allowed for in draft WRMPs as adjustments to final plan deployable output.

WINEP 2 was issued after most water companies' draft WRMP supply and demand forecasts had been completed. Therefore, where it was not possible to allow for new WINEP2 green and amber schemes to be included in the draft WRMP, the Environment Agency asked water companies to consider these schemes and their associated sustainability reductions as a supply demand balance scenario, rather than as a reduction in deployable output in the final plan supply demand balance calculation.

For this draft final WRMP, we have allowed for all sustainability reductions as adjustments to final plan DO. This only applies to our Langham boreholes which could impact on flows in the River Brett. Here, a sustainability reduction of 4.5 MI/d has been applied to the relevant licence in our Essex system Aquator model. This reduces the Essex WRZ deployable output by 2 MI/d.

The third iteration of the PR19 WINEP for AMP7, issued by the Environment Agency contains the following schemes:

Restoring sustainable abstraction

- 24 Water Framework Directive (WFD) investigations and options appraisals, of which nineteen are WFD groundwater investigations for impact on groundwater, three are for impacts on flow and two for impacts on a Heavily Modified Water Body (HMWB). The groundwater investigations are likely to be grouped together as six schemes, relating to the impacted water bodies. We have agreed with the Environment Agency that these investigations and options appraisals will be completed in AMP7 with any implementation schemes being delivered in the first two years of AMP8.
- One sustainability change implementation scheme for the Langham Boreholes. This site has been identified by the Environment Agency as causing actual serious damage to the River Brett and we are working with the Environment Agency and other abstractors, including AWS and Affinity Water, to understand the effect of our abstraction on groundwater and related surface water bodies. For this draft final WRMP, we have allowed for this sustainability reduction as an adjustment to final plan DO. A sustainability reduction of 4.5 MI/d has been applied to the relevant licence in our Essex system Aquator model. This reduces the Essex WRZ deployable output by 2MI/d. We will work with the Environment Agency, AWS and Affinity Water on a joint investigation and if required, options appraisal, in AMP7. Any required option would be implemented in AMP8.

Invasive non-native species (INNS)

- Eight INNS investigations and options appraisals, covering all of our raw water transfer systems, and other pathways of potential INNS transfer. This will involve undertaking risk assessments of the risk of spreading INNS and then an options appraisal of the available measures to reduce any identified risks.
- Three INNS no deterioration schemes, relating to implementation schemes for other, i.e. non-water transfer, pathways of INNS movement, developing a companywide INNS strategy and supporting partnership projects to address INNS transfer.
- One INNS monitoring and surveillance scheme.

Biodiversity

- Two schemes and one investigation relating to NERC delivery.

Eel Regulations

- Two investigations relating to facilitating eel passage at Hanningfield and Abberton Reservoirs.
- Two improvement schemes relating to the eel screens at Wormingford and Ormesby Broad intakes.

The design of any new eel screens we may install will ensure intake DO is not effected.

Water Quality / Drinking Water Protected Area (DrWPA)

- Five DrWPA no deterioration schemes for catchment management work to protect water quality in our main surface water catchments. (See Section 3.5).

All of the above schemes have been costed and allowed for in our PR19 Business Plan for completion in AMP7 (2020 to 2025).

3.9 Abstraction Reform

3.9.1 Allowances for Abstraction Reform

We have not planned for any changes to DO as a result of abstraction reform. This is because the Environment Agency expects that at the time of reform, abstraction licences will be sustainable, or a plan will be in place to make them sustainable.

On transition, new permits will be issued based on current licence quantities and conditions. As no new licence controls will be imposed, this will not impact deployable output.

3.9.2 Emergency Abstraction Licences

The WRPG (Environment Agency, 2017a) states that licensed volume required for emergency purposes will only be available for those purposes and asks water companies to clearly state which sources are used for emergency purposes in their WRMPs and what the emergency purposes are.

We have the following emergency use abstraction licences:

Table 3.14: Emergency Abstraction Licences

Abstraction Licence Number	Emergency Use Conditions
8/36/15/*G/0092	To be used when it is not possible to take the required quantities of water from the River Stour to supply Langham Treatment Works due to drought, frost and pollution in excess of treatable limits.
7/34/19/*G/0135	To be used when it is not possible to take the required quantities of water from the River Waveney to supply Barsham Treatment Works due to pollution in excess of treatable limits.

3.10 Climate Change

A detailed explanation of the effects of climate change on supply and demand is covered in section 6 of this report.

Additionally, an allowance for the uncertainty in the level of climate change incorporated into assessments is covered within our target headroom assessment which is covered in section 7 of this report.

3.11 Protection of Drinking Water Protected Areas

Drinking water Catchment management

Our catchment management approach is consistent across all of our WRZs with each of the main river and groundwater catchments that we abstract from having a dedicated catchment advisor. We will continue to work with the catchment partnerships to address wider water quality issues through delivery of agri-advice, and deliver multiple benefits to the environment through catchment management, linked to our environment ambitions.

Our PR19 commitment is to ensure all abstraction safeguard zones within our operating areas are supported by agri-advice or local delivery partnerships under the Catchment Based Approach (CaBA). This will help us take a catchment-based integrated approach to delivering water and wastewater services, joining up plans and agreeing shared objectives with partners for better management of all our catchments.

In June 2018, we were delighted to be able to sign the Catchment Management Declaration drawn up by the Cambridge Institute of Sustainability Leadership, which aims to bring sectors and organisations together to enable effective catchment management. The declaration will address six key principles in order to create a step change in catchment management activity to support the ambitions of the Government's 25 year plan by supporting water catchment-related activities that will facilitate a greater level of delivery. This aligns with our own ambitions for catchment working and we welcome the support from stakeholders that this declaration and its related activities will bring.

In some cases where raw water quality is poor, we also have the option to undertake abstraction management. River water quality in particular can often change, reflecting for example recent weather and upstream land management practices. During risk periods, samples are taken frequently, so we can assess the quality of our raw water. This information allows us to choose not to abstract poor quality water, if we can source supplies from less-affected locations elsewhere. Abstraction management is not always possible when water resources are constrained, however, and we remain vigilant, ready to install additional treatment options if required.

In 2020-25 we will continue to improve our abstraction management by working towards full automation of the process. This will begin with developing a wider range of real time water quality monitoring at our abstraction sites. We are already monitoring some aspects of raw water quality, such as turbidity and colour.

For other aspects like pesticide levels we are doing manual sampling which then has to be processed in a lab. If we do identify a change in water quality we then have to respond manually. We plan to link up a full range of real time water quality monitoring to our industry leading Aquadapt (now Aquadvanced Energy) water network management system, which we already use to manage and distribute treated water in the network. This software can automatically control and adjust where we take water from; this means that we can respond to changes in raw water quality more quickly to prevent this impacting on our treatment processes and ultimately on the quality of customers' water supplies.

Protection of Drinking Water Protected Areas

In most cases, the main risk is from metaldehyde, a widely used molluscicide for the control of slugs. However, all Drinking Water Protected Areas (DrWPAs), except the River Bure and Trinity Broads, are also at risk from propyzamide, carbetamide, and clopyralid.

The source of the pesticides is generally from agricultural activities in the catchments. In order to protect the DrWPA from further deterioration, the area of land where land management practices and other activities can impact on water quality at our abstraction intakes have been designated by the Environment Agency as Safeguard Zones (SGZ). The Environment Agency has also prepared SGZ action plans which detail measures designed to protect the water quality in the DrWPA. Additionally, national and local initiatives are in place to raise awareness and to work with pesticide users to try and reduce the impacts of pesticide use on the DrWPAs. Some of these initiatives are targeted specifically at controlling pesticide use while others are more generic and aim to encourage good agricultural practice. Details of all actions are shown in the following action plans:

- River Waveney: <https://ea.sharefile.com/d-s699f38f03b94b8ea>
- River Bure & Trinity Broads : <https://ea.sharefile.com/d-sc2c2eeb70a44bd1b>
- River Blackwater, River Chelmer, and Hanningfield Reservoir: <https://ea.sharefile.com/d-s6174492392940f79>
- River Stour, Roman River, Layer Brook and Abberton Reservoir: <https://ea.sharefile.com/d-s9846327223d4ecd9>

We currently have no groundwater SGZ. However, risks to groundwater are considered as part of our water safety planning process and action would be taken where there was a perceived risk.

In order to help protect raw water sources, we employ catchment advisors to work in each of the catchments from which it abstracts. Their purpose is to engage with all stakeholders such as farmers, landowners and agronomists with the aim of reducing

nutrient, sediment and pesticide runoff from land to the rivers. It is expected that this work will contribute to an improvement in river water quality and therefore reduce outage as a result of nitrate, turbidity, algae and pesticide diffuse pollution. Further information on our catchment advisors' work can be found on the website:

<https://www.eswater.co.uk/your-home/environment/catchment-management.aspx>

In AMP6 much of our catchment work has been focussed through the 'Pesti-wise' programme:

<https://www.eswater.co.uk/your-home/environment/Pesti-wise.aspx>

Pesti-wise was launched in April 2015 in three catchments; Roxwell Brook and Layer Brook in Essex and Dickleburgh Stream in Norfolk. Pesti-wise aims to work with farmers and their agronomists to deliver practical guidance and on-farm solutions that helps minimise pesticide run-off and supports sustainable agriculture.

Key objectives are to:

- i) Prove the concept that voluntary action can reduce raw water concentrations of key pesticides in catchment water-bodies; and
- ii) Determine the level of engagement, adoption of best practice, and scale of investment, required to achieve the observed pesticide reductions.

The desired outcome is to reduce average and peak pesticide concentrations at the sub-catchment outlets, compared to a control catchment and the pre-intervention dataset.

Some form of engagement, a 1:1 visit or a telephone call has been delivered to farmers covering 94% of the land area in the Pesti-wise catchments. 87% of the land holding has had face to face engagement. Those remaining who have had no engagement typically farm less than 10 hectares within the catchment and/or have no arable land. As part of this programme 34 equipment grants and seven infrastructure grants have been paid out to farmers. Attempts to engage will continue over the remainder of the AMP.

Although a good level of engagement has been achieved, there is still work to be done in terms of improvements to water quality. It has become clear that 'one size' does not fit all and we need to ensure that our approach for AMP7 recognises the differences across the catchments and looks at how we can work better with external partners to help deliver a wider range of benefits.

For AMP7 we plan to implement a grant scheme that will replace Pesti-wise with a new scheme that will consider a wider range of diffuse pollutants and measures supported by the development of a new grant delivery system. This will allow other stakeholders to bring in money that will fund other ecosystem service improvements that are not a priority to us.

Pesticides (particularly metaldehyde), colour and cryptosporidium can compromise our Overall Drinking Water Quality compliance. Currently, there is no affordable treatment process for metaldehyde removal. Abstraction management is effective at managing to diffuse pollution when reservoir storage is healthy. However, when this is not the case, there is less scope for abstraction management which increases the risk of failures. Therefore, abstraction management needs to be used in conjunction with catchment management.

Our pesticide focus is likely to be on paid for metaldehyde substitution – our AMP6 work supports that this will be by far the most cost effective method of reducing metaldehyde in raw waters. We also intend to run a multi-benefits project, possibly a reverse auction, in partnership with the local Rivers and Wildlife Trusts.

We believe that the above drinking water catchment management projects will help to deliver against two key customer outcomes which are that we supply 'clean, clear drinking water that tastes good' and provides 'a reliable and sufficient supply of water'. In a wider context, they will also deliver on our environmental outcome to 'help to improve the quality of rivers and coastal waters for the benefit of people, the environment and wildlife'.

As part of the Broads Authorities draft WRMP consultation response, they confirmed that they are supportive of our whole farm water management approach in the Waveney sub-catchment, and recommend that this could be promoted in other sub-catchments of the Broads, such as the Bure, including the Trinity Broads. We currently host an agri-advice partnership on the River Waveney and work closely with other partners to deliver practical advice and guidance to farmers in the catchment on water protection with a particular focus on pesticide use. We take a risk based approach to our catchment work and given limited resource our efforts have to focus on those catchments which cause us greatest concern from a drinking water quality perspective. Generally speaking we do not see high pesticide levels from the River Bure or Trinity Broads and overall raw water quality is very good. Consequently, this area is likely to remain a lower priority for us than the River Waveney. However, we have a long established Trinity Broads partnership through which a low level of catchment management work is delivered. This has previously focused on nutrients from manures. We will continue to monitor water quality within the catchment and through the partnership newsletter, report water quality and provide advice to land managers. Likewise, we will take a similar approach with the Bure working collaboratively with the Broadland Catchment Partnership and the Upper Bure Valley Partnership.

3.12 Invasive Non-native Species (INNS)

As part of our work to update our Water Resource Management Plan for PR19, we are required, for the first time, to review whether current abstraction operations and future solutions will risk spreading INNS, and propose measures to manage that risk.

We have done this, taking into account the Agency Position Statement “Managing the risk of spread of Invasive Non-Native Species through raw water transfers” (Environment Agency, 2017e) and the associated report and maps setting out the catchments which are considered isolated, “Invasive Species Isolated Catchment Mapping” version 3 (Environment Agency, 2018).

A supporting report “Essex & Suffolk Water (2018) Revised Draft Raw Water Transfer INNS Risk Assessment Report” presents the approach, methodology and outputs we have used to review the risk of spreading INNS via existing raw water transfers within our customer supply area.

The report shows how we have carried out baseline risk assessments to assess the risk of spreading INNS via our existing raw water transfers, based on information available at the time of the assessment and following the guiding principles and scope set out in Environment Agency guidance. As the Environment Agency has purposefully not set out a specific risk assessment methodology, the method used has been developed in-house and will be further refined and developed as part of the work planned under the PR19 WINEP.

Information from a variety of published sources, and expert knowledge from technical and operational staff within our organisation, has been used to populate a data spreadsheet to describe the source, pathway and receptor for each raw water transfer, to identify any known INNS currently present and to identify any existing measures which may reduce the risk of spreading INNS via each transfer, based on the suggested information requirements set out in the Environment Agency’s “PR19 Driver Guidance – INNS” document.

A pick list of options and associated scores (between 0 and 10) was developed by our technical staff for each aspect of each raw water transfer. The scores were added together to give a total risk score calculated out of a theoretical maximum score of 100. The total risk score was then adjusted to take into account any existing measures that might reduce the risk of spreading INNS during the raw water transfer. Multiplying the total risk scores, by the appropriate mitigation measure score, gave a final risk score for each transfer. The raw water transfers were then ranked according to the total and final risk scores.

Existing measures to reduce the risk of spreading INNS via raw water transfers, that are employed at some of our sites, include transferring water direct to a WTW process and partially treating transferred water with low doses of chlorine (specifically for mussel control). In addition, several key river intakes will have improved screens, likely to be 2mm mesh, installed as part of the Eel Regs programme of works within the current AMP6 NEP.

The baseline risk assessment, taking into account existing INNS mitigation measures, indicates the highest risk transfers for spreading INNS are those associated with the Environment Agency’s Ely Ouse to Essex Transfer Scheme (EOETS), to Abberton and Hanningfield Reservoirs and to the Stour and Blackwater. Other high scoring transfers include the two natural catchment inflows to Abberton

and Hanningfield reservoirs, and other raw water transfers within the Langham/Abberton and EOETS systems.

The Environment Agency's "PR19 Driver Guidance – INNS" acknowledges that: "Reducing the risk from existing raw water transfer pathways will be a gradual process, guided by understanding of the feasibility and costs of mitigation measures." Revisiting and updating the risk assessments, and undertaking a complete options appraisal for measures to mitigate the risk of spreading INNS via existing raw water transfers, will be carried out as part of our obligations within our PR19 WINEP.

This is the first time that a review of raw water transfers for the risk of transferring INNS has been included within the WRMP and Periodic Review processes, so no comparison is available with the PR14 WRMP.

3.13 Outage

3.13.1 Background

Our outage allowance assessment is presented in detail in a separate supporting report, Outage Allowance Report - Periodic Review 2019 (2017e). A summary of the assessment is provided below.

Outage is defined in the UKWIR report *Outage Allowances for Water Resource Planning* (UKWIR, 1995b) as:

"A temporary loss of deployable output"

Outage events can be divided into *planned outage* and *unplanned outage*. The UKWIR report defines planned outage as:

"A foreseen and pre-planned outage resulting from a requirement to maintain source works asset serviceability".

Unplanned outage is defined as:

"An outage caused by an unforeseen or unavoidable legitimate outage event affecting any part of the source works and which occurs with sufficient regularity that the probability of occurrence and severity of effect may be predicted from previous events or perceived risk".

The report also provides a definitive list of what is to be considered as legitimate unplanned outage. The categories include:

1. Pollution of Source
2. Turbidity
3. Nitrate

4. Algae
5. Power Failure
6. System Failure

The recommended approach described in the UKWIR report *Outage Allowances for Water Resource Planning* (UKWIR, 1995b) has been used as the basis for calculating outage allowance. The UKWIR approach provides a good basis for assessing the outage data, although it leaves a number of areas open to interpretation. Therefore, several assumptions have to be made and the approach adapted to the available data and the resulting modelling software output.

3.13.2 ESW's Adapted Methodology

The methodology we used to determine outage allowance comprises the following 3 stages:

Data Gathering and Interpretation

Essex Water Resource Zone

Treatment works daily output data for the period April 2012 to March 2017 inclusive were used as the basis to calculate outage magnitude and duration.

Actual daily works output data was compared against planned output for each treatment works. The former contain notes recording the reasons for any divergence of actual output from the planned output. Although the Essex treatment works are planned to operate at a minimum threshold production rate, at times staff plan 4 to 6 weeks in advance to reduce the output at a treatment works. This may be for a variety of operational reasons, for example, to allow for maintenance work to be carried out, if a reduction in demand is expected, or if raw water quality is expected to be poor and will increase the amount of chemicals required to treat the water. This additional information is used in conjunction with the minimum threshold production rates to identify when legitimate outage events have occurred and to ensure that outage was not over-estimated. However, during a confirmed outage event, its magnitude in MI/d was calculated using the minimum threshold production rate, not the planned output. If during the event planned output was below the minimum threshold production rate then this method ensured that outage was not under-estimated.

If the treatment works output data indicated a reduction in output, supporting evidence to confirm if a legitimate outage event had occurred was sought from qualitative records, such as notes and weekly reports from the Strategic Network, Water Quality and Water Supply departments. If no information could be found in these reports the Water Supply Department was consulted to search onsite treatment works diaries for information.

Additionally, the reports noted above were also fully reviewed for evidence of the occurrence of outage events and if the issue would have prevented maximum output

being achieved if required. Raw output data from the relevant time periods was then reviewed to identify if an actual reduction in output occurred and also to calculate the relevant magnitude of the event.

Suffolk Water Resource Zones

Treatment works daily output data for the period April 2012 to March 2017 inclusive were used as the basis to calculate outage magnitude in MI/d and outage duration in days. The data had undergone validation and cross-checking against pumping flows to ensure any errors in telemetry recording had been identified and rectified.

For surface water treatment works, this data was compared against Production Plan (target output) spreadsheets for Barsham, Lound and Ormesby WTWs. For the remaining treatment works, which have no associated target outputs, a method to define a minimum guideline output figure was used. This was calculated from the yearly average output minus 10% of that average. If the daily output fell below this guideline value a potential outage event was deemed to have occurred.

To validate the methods of identifying potential outage events, the works outputs were also graphically displayed to enable visual identification of sharp troughs in output or longer periods of lower output uncharacteristic for a particular works. Generally, periods of reduced output that appeared significant through visual identification had also been identified through the mathematical methods.

Potential outage events identified through the data analysis described above were cross-referenced with a range of qualitative information sources, to confirm their legitimacy and determine the reason for the event. These included Water Supply Department monthly reports, Works Status reports, Maintenance and Planning Department records and Water Quality weekly reports. If no qualitative evidence could be found to confirm a potential outage event indicated by the output data, details were passed to the Suffolk Water Supply team to cross-reference with onsite treatment works daily dairies. Where there was correlation between a quantitative data source and a qualitative source, and there was confirmation of the legitimacy of the outage, then the event was included in the assessment. Where no correlation existed between information sources, the potential outage event was discarded from the assessment.

The Suffolk groundwater source works are not operated to minimum production threshold rates in the same way as the Essex Resource Zone source works. This is due to the demand-reactive nature of many of the works, particularly the small groundwater works, and also because of the interconnectedness of the resource zones, where several works directly supply the same district storage tank or supply area. Ensuring consistency in calculating outage magnitude required developing a set of mathematical procedures, the use of which depended upon the source works and suitability of data set for a particular procedure. Where output was consistent, the average output from the 7 days previous to an event provided a baseline figure which was then used to calculate the deficit in output during the event. Where works output was highly variable or uncharacteristic just previous to an event, the minimum

guideline output figure previously identified by taking the yearly average output minus 10% of that average, was used as a baseline figure.

Development of Triangular Distributions

As found during the previous periodic review assessments, there were insufficient outage events to enable triangular distributions to be developed for each category of outage. Therefore, for the Essex WRZ, all outage events at each works were collated by month. For the Suffolk WRZ, all outage events for all of the source works in each zone were collated. The minimum, best estimate and maximum daily magnitude and outage event duration was then calculated using these combined data sets. These figures correspond to the least credible; most likely and maximum credible values discussed in the UKWIR (1995a) methodology and required to form the triangular distributions.

Due to the small number of outage events in some months, in order to determine the most likely daily outage magnitude it was necessary to first round the data to the nearest whole number (MI) for the Essex WRZ and to one decimal place for the Suffolk WRZs, before calculating the best estimate (average or mode) figure.

Monte Carlo Analysis

The UKWIR (1995a) methodology indicates a Monte Carlo simulation of 500 iterations would be considered sufficient to provide a satisfactory derived distribution. However, the UKWIR report *An Improved Methodology for Assessing Headroom* (2002) recommends that a typical number of iterations might be 5000 and this figure has been used in preference.

The minimum, most likely and maximum figures calculated using the legitimate outage events data were entered into a spreadsheet to define triangular distributions to represent the spread of outage event magnitude and duration, at each water treatment works for each month of the year in the case of the Essex WRZ, and for each WRZ for each month in the case of the Suffolk WRZs.

Monte Carlo analysis was conducted using the risk analysis software package Crystal Ball. For the Essex WRZ, each iteration combines outage magnitude and duration for each month, at each works, based on random sampling across each triangular distribution. During the course of the simulation the results from each trial are combined in pre-defined forecast cells which calculate the total monthly outage in MI for each month at each water treatment works. These results were then combined in a second tier of forecast cells to calculate the total monthly outage for the Essex WRZ in MI/d. This calculation was carried out using the following formula:

$$\text{Essex Total Monthly Outage} = \frac{\text{Total monthly outage of Langham + Layer + Langford + Chigwell}}{\text{Total number of days in data set}} \times \text{Total number of treatment works}$$

In this calculation, the total monthly outage from each WTW is summed, giving a value in MI. This is then converted into MI/d by dividing this monthly total by the total number of days in the data set for each month, and multiplying by the number of treatment works being assessed. The final multiplication allows for the double counting of days that would result if an outage event occurred at the same time at different WTW. Finally, the total monthly outage volumes for the WRZ are summed to produce an average daily outage in MI/d.

In order to demonstrate the repeatability of the Monte Carlo results, three simulations were run for each WRZ and the standard deviation of each percentile assessed.

3.13.3 Data Analysis Results

Table 3.15 summarises Essex WRZ outage data, in terms of outage magnitude and duration, experienced at the Essex WTWs from 2012/13 to 2016/17.

Table 3.16, Table 3.17 and Table 3.18 summarise the same outage data for the three Suffolk WRZs.

Table 3.15: Summary of Essex outage data

Water Resource Zone	Raw Water Source	Planned	Unplanned - Algae	Unplanned - Nitrates	Unplanned - Pollution of Source	Unplanned - Power Failure	Unplanned - System Failure	Unplanned - Turbidity	Grand Total	
Total MI										
Essex	Chigwell Reservoir	552	4,775				1,516		6,843	
	Langford River	3,862	1,232	1,215	1,357	57	330	1,912	9,965	
	Langham River	5,145	4,303	92	1,855		2,030	502	13,927	
	Layer Reservoir	3,996	17,351				219	13,442	35,007	
	Total		13,555	27,661	1,308	3,212	57	4,096	15,856	65,743
Total Days										
Essex	Chigwell Reservoir	14	229				64		307	
	Langford River	112	68	95	167	2	35	71	550	
	Langham River	282	219	12	115		109	36	773	
	Layer Reservoir	104	456				9	240	809	
	Total		512	972	107	282	2	217	347	2,439
(Average MI/d)										
Essex	Chigwell Reservoir	0.30	2.62	-	-	-	0.83	-	3.75	
	Langford River	2.12	0.68	0.67	0.74	0.03	0.18	1.05	5.46	
	Langham River	2.82	2.36	0.05	1.02	-	1.11	0.28	7.63	
	Layer Reservoir	2.19	9.51	-	-	-	0.12	7.37	19.18	
	Total		7	15	1	2	0	2	9	36
(Average Days / Year)										
Essex	Chigwell Reservoir	2.80	45.80	-	-	-	12.80	-	61.40	
	Langford River	22.40	13.60	19.00	33.40	0.40	7.00	14.20	110.00	
	Langham River	56.40	43.80	2.40	23.00	-	21.80	7.20	154.60	
	Layer Reservoir	20.80	91.20	-	-	-	1.80	48.00	161.80	
	Total		102	194	21	56	0	43	69	488

Table 3.16: Summary of Suffolk Blyth outage data

Water Resource Zone	Raw Water Source	Planned	Unplanned Algae	Unplanned Nitrates	Unplanned Pollution of Source	Unplanned Power Failure	Unplanned System Failure	Unplanned Turbidity	Grand Total
Total MI									
Blyth	Benhall	Groundwater	70.99						70.99
	CFG	Groundwater					3.77		3.77
	Coldfair Gr	Groundwater	29.29						29.29
	Parham	Groundwater			3.84		1.51		5.35
	Saxmundham	Groundwater				0.53		16.94	17.47
	Total		100.28			3.84	0.53	5.28	16.94
Total Days									
Blyth	Benhall	Groundwater	77						77
	CFG	Groundwater					3		3
	Coldfair Gr	Groundwater	39						39
	Parham	Groundwater			13		6		19
	Saxmundham	Groundwater				3		55	58
	Total		116			13	3	9	55
Average MI/d									
Blyth	Benhall	Groundwater	0.04	-	-	-	-	-	0.04
	CFG	Groundwater	-	-	-	-	0.00	-	0.00
	Coldfair Gr	Groundwater	0.02	-	-	-	-	-	0.02
	Parham	Groundwater	-	-	-	0.01	-	0.00	0.01
	Saxmundham	Groundwater	-	-	-	-	0.00	-	0.03
	Total		0.06	-	-	0.01	0.00	0.00	0.03
Average Days / Year									
Blyth	Benhall	Groundwater	15.4	0	0	0	0	0	15.4
	CFG	Groundwater	0	0	0	0	0	0.6	0.6
	Coldfair Gr	Groundwater	7.8	0	0	0	0	0	7.8
	Parham	Groundwater	0	0	0	2.6	0	1.2	3.8
	Saxmundham	Groundwater	0	0	0	0	0.6	0	11
	Total		23.2	0	0	2.6	0.6	1.8	11

Table 3.17: Summary of Suffolk Hartismere outage data

Water Resource Zone		Raw Water Source	Planned	Unplanned - Algae	Unplanned - Nitrates	Unplanned - Pollution of Source	Unplanned - Power Failure	Unplanned - System Failure	Unplanned - Turbidity	Grand Total
Total MI										
Hartismere	Eye	Groundwater	80.8085			52.2383571				133.047
	Mendlesham	Groundwater	2.9776			0.58		111.118571	47.6813	162.357
	Rickinghall	Groundwater	3.67833			0.54082857	0.43564286			4.65481
	Grand Total		87.4644			53.3591857	0.43564286	111.118571	47.6813	300.059
Total Days										
Hartismere	Eye	Groundwater	90			60				150
	Mendlesham	Groundwater	7			1		172	83	263
	Rickinghall	Groundwater	11			2	1			14
	Grand Total		108			63	1	172	83	427
Average MI/d										
Hartismere	Eye	Groundwater	0.04	-	-	0.03	-	-	-	0.07
	Mendlesham	Groundwater	0.00	-	-	0.00	-	0.06	0.03	0.09
	Rickinghall	Groundwater	0.00	-	-	0.00	0.00	-	-	0.00
	Grand Total		0.05	-	-	0.03	0.00	0.06	0.03	0.16
Average Days / Year										
Hartismere	Eye	Groundwater	18	0	0	12	0	0	0	30
	Mendlesham	Groundwater	1.4	0	0	0.2	0	34.4	16.6	52.6
	Rickinghall	Groundwater	2.2	0	0	0.4	0.2	0	0	2.8
	Grand Total		21.6	0	0	12.6	0.2	34.4	16.6	85.4

Table 3.18: Summary of Suffolk Northern Central outage data

Water Resource Zone	Raw Water Source	Planned	Unplanned - Algae	Unplanned - Nitrates	Unplanned - Pollution of Source	Unplanned - Power Failure	Unplanned - System Failure	Unplanned - Turbidity	Grand Total
Total MI									
Northern Central	Lound	Reservoir		166.404786					166.405
	Ormesby	Reservoir						3.73157143	3.73157
	Southwold	Groundwater	65.8378			573.735657			639.573
	Total		65.8378	166.404786		573.735657		3.73157143	809.71
Total Days									
Northern Central	Lound	Reservoir		164					164
	Ormesby	Reservoir						4	4
	Southwold	Groundwater	138			1035			1173
	Total		138	164		1035		4	1341
Average MI/d									
Northern Central	Lound	Reservoir	-	0.09	-	-	-	-	0.09
	Ormesby	Reservoir	-	-	-	-	-	0.00	0.00
	Southwold	Groundwater	0.04	-	-	0.31	-	-	0.35
	Total		0.04	0.09	-	0.31	-	-	0.44
Average Days / Year									
Northern Central	Lound	Reservoir	0	32.8	0	0	0	0	32.8
	Ormesby	Reservoir	0	0	0	0	0	0.8	0.8
	Southwold	Groundwater	27.6	0	0	207	0	0	234.6
	Total		27.6	32.8	0	207	0	0.8	268.2

3.13.4 Monte Carlo Simulation Results

The results of the Monte Carlo simulation are summarised in Table 3.19 for the Essex WRZ and Table 3.20, Table 3.21 and Table 3.22 for the Suffolk WRZs. The results for the three simulations are shown along with the calculated standard deviation between the results for each percentile, to demonstrate the high degree of repeatability, with a variation of just fractions of an MI. Therefore, it was decided to use the results from the first model run to determine the outage allowance figure for inclusion in the supply demand balance.

Table 3.19: Essex WRZ Monte Carlo results

Percentile (%)	Return Period	Forecast Values (MI/d)		
		Planned	Un-planned	Total
50	1 in 2 years	5.44	21.51	26.96
80	1 in 5 years	6.31	23.43	29.74
90	1 in 10 years	6.75	24.49	31.23
95	1 in 20 years	7.12	25.42	32.54
96	1 in 25 years	7.22	25.59	32.82
98	1 in 50 years	7.48	26.12	33.60

Table 3.20: Blyth WRZ Monte Carlo results

Percentile (%)	Return Period	Forecast Values (MI/d)		
		Planned	Un-planned	Total
50	1 in 2 years	0.59	0.06	0.65
80	1 in 5 years	0.73	0.08	0.81
90	1 in 10 years	0.81	0.09	0.89
95	1 in 20 years	0.88	0.10	0.97
96	1 in 25 years	0.91	0.10	1.00
98	1 in 50 years	0.96	0.10	1.07

Table 3.21: Hartismere WRZ Monte Carlo results

Percentile (%)	Return Period	Forecast Values (MI/d)		
		Planned	Un-planned	Total
50	1 in 2 years	0.23	0.38	0.61
80	1 in 5 years	0.29	0.45	0.74
90	1 in 10 years	0.32	0.48	0.80
95	1 in 20 years	0.34	0.51	0.85
96	1 in 25 years	0.35	0.52	0.87
98	1 in 50 years	0.37	0.54	0.91

Table 3.22: Northern Central WRZ Monte Carlo results

Percentile (%)	Return Period	Forecast Values (MI/d)		
		Planned	Un-planned	Total
50	1 in 2 years	0.20	0.92	1.12
80	1 in 5 years	0.25	1.07	1.32
90	1 in 10 years	0.27	1.16	1.42
95	1 in 20 years	0.29	1.23	1.51
96	1 in 25 years	0.29	1.24	1.54
98	1 in 50 years	0.31	1.30	1.61

3.13.5 Return Period Evaluation

The results in tables 3.19 to 3.22 show that the outage allowance figures decrease with increasing return period frequency. Thus a 1 in 5 year return period has a lower outage allowance than a 1 in 10 year return period.

The figures corresponding to the 50th percentile (1 in 2 year return period) for planned outages and 90th percentile (1 in 10 year return period) for unplanned outages has been selected to represent the outage in each WRZ, and are shown below in Table 3.23. The 1 in 10 year return period aligns with our first drought action, which is ‘appeals for restraint’ and is the percentile used to define the unplanned outage allowance in previous periodic reviews. The 50th percentile has been used for planned outage. We believe that this it is acceptable as the majority of the planned outage is due to investment in assets and so these assets are less likely to result in outage in future years. These values represent the level of risk that we find acceptable to plan for in each WRZ, and that best reflect the level of uncertainty in outage likely to be experienced in the future over the planning horizon.

There are no significant developments planned for the supply systems in our WRZs. Therefore, we feel that it is appropriate to use the same outage allowance figure for all years across the planning horizon. An assessment of actual outage will continue to be conducted on an annual basis, as required for the WRMP Annual Update and regulatory return, and will identify any unforeseen changes in the amount of outage being experienced by the treatment works, and if appropriate may trigger a revision of how outage allowance is profiled across the planning horizon.

Table 3.23: PR19 WRMP Outage Allowance figures and percentage of DI.

Water Resource Zone		PR19 WRMP Outage Allowance (MI/d) (Unplanned = 90 percentile and Planned = 50 percentile)	Percentage of WRZ DI (%)
Essex		29.93	7.6
Suffolk	Blyth	0.68	0.07
	Hartismere	0.71	0.09
	Northern Central	1.36	0.3

3.13.6 Opportunities to reduce outage

The WRP (Environment Agency, 2017a) states that, where appropriate, water companies should identify potential options for reducing outage allowance for inclusion in an options appraisal to solve a supply demand deficit. Our draft dry year annual average supply demand balance calculations indicate that all four of the WRZs will have a surplus across the full planning horizon. Consequently, no investment will be driven by a resource deficit and therefore it is unnecessary for us to conduct an options appraisal.

However, as part of routine investment and operations, some of the factors that result in outage will continue to be managed. For example, we have an ongoing programme of asset maintenance to refurbish abstraction and treatment works infrastructure, such as pumping stations. This should reduce the occurrence of unplanned system failures but will likely require planned outage to allow for works to be carried out. A good example of this is at Layer WTW in Essex where outage was significantly higher during 2016/17 than in previous years. The unplanned outage was due to poor water quality in Abberton Reservoir which supplies Layer WTW. Prolonged algal blooms were the main cause of the unplanned outage which appear to also have been an issue for other water companies in the south east. Consequently, water industry research is ongoing to understand the cause. To reduce Layer WTW unplanned outage in future years, a number of the slow sand filters were fully refurbished during the 2016/17 winter. Unplanned outage during 2017 has subsequently been significantly less.

Pollution of our groundwater sources is minimised through both the design of the wells and boreholes and through an ongoing inspection programme. As a minimum, all of our groundwater sources have a full inspection every five years. This includes a CCTV inspection as well as geophysical logging to identify the condition and any emerging issues with the well or borehole. Once an emerging issue has been identified, mitigative action is taken either in the form of refurbishment of the existing borehole (e.g. re-lining) or by constructing a replacement borehole.

Langford WTW and Langham WTW both suffer outage as a direct result of poor river water quality, largely due to the intensive agricultural activity in the catchments. We employ catchment advisors to work in each of the catchments we abstract from. Their purpose is to engage with all stakeholders such as farmers, landowners and agronomists with the aim of reducing nutrient, sediment and pesticide runoff from land to the rivers. It is expected that this work will contribute to an improvement in river water quality and therefore reduce outage as a result of nitrate, turbidity and algae, and the risk of outage due to pesticide pollution, as agricultural activity intensifies over the planning horizon. Further information on our catchment management work can be found on the website www.eswater.co.uk/catchmentmanagement.

3.14 Raw and Potable Water Transfers and Bulk Supplies

3.14.1 Essex Raw Water Imports - Chigwell Bulk Supply

The Chigwell bulk supply arrangement is captured in an agreement between the Metropolitan Water Board (now TWU) and South Essex Waterworks Company (now ESW) dated 30 May 1963.

In summary, the agreement allows, under normal operating conditions, for a bulk water supply of 91 MI/d on average, not exceeding 118 MI/d on any one day, from TWU to us. The bulk supply is provided from the King George V and William Girling Reservoirs in the Lea Valley, potentially supported by abstraction directly from the River Lea at defined intakes, if required.

We met with TWU in September 2007 to jointly reconfirm interpretation of the agreement with respect to how the bulk supply is operated in the event of a drought affecting either party. The results of this meeting can be summarised as follows:

- Clause 2b of the bulk supply agreement refers to what will happen in the event of TWU imposing a temporary use ban on its domestic customers. If we also apply a temporary use ban on its customers then the full average quantity of 91 MI/d remains available to us. The last occasion this occurred was in 1976. If we do not impose a temporary use ban on its domestic customers, then the supply from TWU is reduced by 25%. This was the situation in 2006.
- Within the agreement is also a statement that during an "unusual drought" TWU shall supply to us such quantities as shall represent "fair apportionment" of the water available. We have agreed with TWU that "unusual drought" will in future be defined as when TWU have entered their stage 3 drought restrictions (implemented powers for a non-essential use ban). Fair apportionment will not be pre-emptively defined as the circumstances of each particular drought differ spatially and temporally (evidenced by 1996/97 and 2005/06). This will be considered however at the time that stage 3 restrictions are put in place. The apportionment will be derived from the relative shortfall in DO that each company is experiencing.

Therefore in future droughts affecting us the potential for temporarily increasing the bulk supply will be dependent on TWU's own resource situation, the nature and spatial distribution of the drought, and demand in the Chigwell area.

On the basis that historically there has not yet been an 'unusual drought' within the TWU area that has affected the transfer of water to Essex, then the average demand DO of the transfer has been assumed to be 91 MI/d.

Although currently viewed as unlikely, there must be some uncertainty as to whether the 91 MI/d could be continued to be supplied in the future, particularly in the event of an unusual drought affecting the TWU area. The uncertainty associated with the bulk supply has therefore been included with headroom uncertainty and is outlined in Chapter 7 of this document.

In 2015, we entered into a separate agreement with TWU and traded 20 MI/d of raw water back. In a normal year, the agreement still allows us to take the full 91 MI/d. However, for the purposes of defining dry year DO, we assume TWU will take the 20 MI/d, leaving 71 MI/d to supply Chigwell treatment works.

With regard to the bulk supply, TWU has completed its own climate change assessments for the WRZ containing the Lee Valley reservoirs. This has not resulted in any change to the above assumptions regarding reliable DO.

3.14.2 Essex Raw Water Exports

Our PR14 supply demand balance for the Essex WRZ allowed us to offer the following temporary raw water trade to other water companies:

- 20 MI/d from 2015 to 2030
- 15 MI/d from 2030 to 2035
- 0 MI/d from 2035 to 2040

As described above, a further agreement was made between ourselves and TWU in 2015 allowing for a raw water export of 20 MI/d from us to TWU. This trade is captured on our supply demand balance by simply reducing Chigwell WTW DO from 91 MI/d to 71 MI/d. This negates the need for any new pipeline or pumping station infrastructure.

3.14.3 Essex Water Resource Zone Potable Water Imports

There is one treated water import from AWS into the Essex WRZ near Silver End, which has averaged 0.9 MI/d over the previous five years. Accordingly, this is the figure that has been adopted for planning purposes.

3.14.4 Essex Water Resource Zone Potable Water Exports

The Essex WRZ has the following potable water exports:

Table 3.24: Potable water exports from the Essex WRZ

Water Company	Export (MI/d) 2016/17
AWS	2.36
Affinity Water	0.02
Albion Water	0.01
SSE Water	0.39
Total	2.77

The above exports have been adopted for planning purposes except for the AWS export and Albion Water export. AWS has determined that our export (principally via Tiptree) has an effective maximum average transfer of 3.05 MI/d, although the actual

transfer has historically been much less than this. For reasons of consistency we have adopted the same figure for planning purposes. Albion Water’s maximum average transfer is 0.08 MI/d which has been used in planning.

3.15 Process Losses

Process losses in the form of raw and treatment works operational use are included in the calculation of DO for the Essex WRZ through incorporation in the Essex water resources system model Aquator. The bulk of the allowances used in the model relate to Langford WTW which assumes 7% treatment process losses (i.e. water that is not returned to source). In the case of all the other Essex works (Hanningfield, Layer, Langham and Chigwell) it is assumed that all the treatment process water is returned to source.

In the case of the Suffolk WRZs, process losses are not directly included in the definition of DO and hence an allowance for process losses has been separately defined and considered as an additional reduction in DO.

Process losses are defined as the sum of raw water operational use and losses, and treatment works operational use and losses. Raw water losses and operational use in Suffolk are assumed to be zero. Suffolk WTWs losses are also assumed to be zero but treatment works operational use (TWOU) is a feature of many of the works.

TWOU is defined as treatment process water i.e. the net losses from filter washing that exclude water returned to source waters. We have recently re-quantified these process losses using the latest information on works performance, and the results have been factored into the supply calculations. This calculation is based on the number of filter washes per day multiplied by the volume of water used in each wash. This is repeated for each filter and then the sum of filter washes is summed to give a treatment works loss in MI/d. A summary of the results is provided below.

Table 3.25: Treatment Works Process Losses

Treatment Works	Source Water	Total Volume WW per day (MI/d)	Deployable Output (MI/d)	% Process Losses
Barsham	Groundwater & Surface Water	3.36	14.71	12.00%
Bedingfield	Groundwater	0.00*	0.55	0.01%
Benhall	Groundwater	0.24	6.28	3.78%
Broome	Groundwater	0.14	2.36	6.00%
Coldfair Green	Groundwater	0.34	4.48	7.50%
Eye	Groundwater	0.02	0.63	2.47%
Holton	Groundwater	0.03	1.51	2.16%
Lound	Surface Water	0.00**	8.10	0.00%
Mendlesham	Groundwater	0.03	0.45	5.71%

Treatment Works	Source Water	Total Volume WW per day (MI/d)	Deployable Output (MI/d)	% Process Losses
Ormesby	Surface Water	0.00**	27.40	0.00
Parham	Groundwater	0.009	0.29	3.14%
Redgrave	Groundwater	0.01	3.02	0.34%
Rickinghall	Groundwater	0.1	1.25	8.35%
Saxmundham	Groundwater	0.06	0.78	8.03%
Syleham	Groundwater	0.26	4.75	5.41%
Walpole	Groundwater	0.07	4.20	1.69%
			Average	4.16%

* Treatment works with wash water recycling directly to process

** Treatment works where all process losses returned to source

For individual works in Suffolk (apart from those where water is returned to source) TWOU averages approximately 4.16% of treatment works DO.

The WRPG (Environment Agency, 2017a) states that water companies should consider options to reduce losses where there is a supply demand balance deficit or it makes sense to do so. This draft WRMP does not forecast a supply deficit in any of the WRZs. However, when upgrading or constructing new treatment works in the future, filter wash water recycling will be considered subject to compliance with the Drinking Water Inspectorate (DWI) guidelines and regulations regarding the recycling of process water and cryptosporidium risk.

3.16 Zonal Summary of Deployable Output and WAFU

The following table summarises the results of the supply calculations for each of the Essex and Suffolk resource zones for the 2016/17 base year and assuming the mid climate change scenario. The sensitivity to supply around climate change is discussed in chapter 6.

Table 3.26: Zonal Summary of Supply Parameters for 2016/17 Base Year (MI/d)

Resource Zone	Total DO of own sources 2016/17	Reductions in DO in 2016/17 (see text)	Outage	WAFU Own Sources 2016/17	Balance of Raw and Treated Water imports/exports	Total WAFU 2016/17
Essex	400.81	0	29.93	350.61	69.2	439.78
Suffolk Blyth	14.68	0	0.68	13.12	0	13.12
Suffolk Hartismere	8.65	0	0.71	7.63	2	9.63
Suffolk Northern/Central	70.02	0	1.36	67.23	-2	61.72

4.0 WATER DEMAND FORECAST



4.1 Introduction

The methodologies used to prepare the demand forecasts have followed published best practice as defined in WRMP19 Methods – Household Demand Forecasting (UKWIR, 2016b), WRMP19 methods – Risk based planning (UKWIR, 2016a), Methods of Estimating Population and Household Projections and Customer Behaviour and Water Use (UKWIR, 1995c) and (UKWIR and Environment Agency, 2002).

Forecasts have been prepared for the Essex and Suffolk areas separately. The Suffolk forecast has then been apportioned into the Suffolk WRZs. Normal year forecasts have been made against a 2016/17 base year, which has been amended from the published Annual Regulatory report figures to incorporate the rebasing process for properties, as well as normalising the 2016/17 per capita consumptions (PCCs). This ensures a smooth projection from the base year into the forecast.

The normal year forecasts have been used as the basis for dry year forecasts, and adjusted to provide figures for two climate change scenarios.

The total baseline demand forecast is comprised of the elements described in the following sections and the demand management described in section five.

4.2 Base Year Demand

As outlined in the introduction, 2016/17 is classed as a ‘normal year’ as it exhibited normal rainfall totals and temperatures through the year. Therefore no weather related adjustments have been made to base year demands for the forecast. The PCC’s have been normalised based upon the water balance being re-based.

In order to forecast from a normal year, the PCCs for both measured and unmeasured customers have been ‘normalised’ against trend.

4.2.1 Normalised PCC

The unmeasured and measured normalised PCC for 2016/17 is calculated from the re-basing of the water balance. Table 4.1 shows the result of this adjustment to PCC in Essex and Suffolk, in litres per head per day. To ensure the trend for micro-components is consistent with the WRMP, total PCC has been altered across the forecast by PCC adjustment.

Table 4.1: PCC adjustment to normalise PCC

	Essex		Suffolk	
	Unmeasured PCC (l/h/d)	Measured PCC (l/h/d)	Unmeasured PCC (l/h/d)	Measured PCC (l/h/d)
2016/17	160.29	142.73	147.15	125.20
2016/17 rebased	161.12	139.85	147.91	128.41
PCC adjustment	+0.83	-2.87	+0.76	+3.21

Figures 4.1- 4.4 show the historic trend of PCC including 2016/17 rebased figures starting with unmeasured households.




Figure 4.1: Essex Unmeasured Household PCC

Suffolk - Unmeasured Household I/h/d



Figure 4.2: Suffolk Unmeasured Household PCC

Essex - Measured Household I/h/d



Figure 4.3: Essex Measured Household PCC

Suffolk - Measured Household I/h/d



Figure 4.4: Suffolk Measured Household PCC

In addition, at the end of each AMP period we believe the best approach is to group all the metered households, metered by the base year, into a single group, which we call “Existing Metered”, for forecasting forward. This is because households which became metered through customers opting for a meter, will in time have new occupiers and no longer exhibit characteristics of a new optant household. Also from AMP to AMP our metering policy changes, which impacts upon the type of households metered, and over time the balance of low occupier/low consumption and high occupier/high consumption households varies between the unmeasured and metered categories.

4.2.2 Unmeasured Household Water Delivered

The unmeasured PCC estimate has been determined from our unmeasured individual household monitor, the Study of Water Use (SWU). Properties in the study have a meter and data logger installed which collects consumption data every 15 minutes. Once all the data has been validated and leaks checked and removed, daily and monthly summary flows are calculated. The summary flows include minimum, maximum and average flows, either on a daily or monthly basis. To calculate the annual PCC, the daily consumption for each property is determined. This means that the number of properties used in the PCC calculation is determined on a daily basis. As a result, loggers with faulty data for that period can be ignored, allowing the PCC calculation to use as many properties as possible over the whole 12 months. The daily summary flows and validated manual meter readings are used in the PCC calculation. The logged data is given the greater priority in the calculation but where no logger information is available, the manual readings are used.

The total monitor sample contains 1,136 properties after any meter optant households, empty properties, leaks and outlying data have been removed. The best estimate of supply pipe leakage (see section 4.2.5) is added to the calculated household consumption figures to provide the water delivered to unmeasured households.

For more information about the SWU and how the unmeasured PCC is calculated please refer to the Study of Water Use Technical report (Essex & Suffolk Water, 2017b).

4.2.3 Measured Household Water Delivered

The average water consumption for measured households for 2016/17 has been rebased by using the normalised measured PCCs. This is then increased to allow for meter under-registration. An estimate of supply pipe leakage for internally metered households is added to this to provide the water delivered figure. The volume of water delivered to measured households continues to increase, due to the effects of the metering.

4.2.4 Non-Household Water Delivered

Our estimate of consumption for unmeasured non-household consumption has been based on the research reported eight years ago, in which unmeasured customers were compared with metered properties of the same type (e.g. shops, warehouses) and also compared the rateable values of metered and unmetered properties. It has been assumed that an unmeasured customer consumes 50% of a similar metered property, based upon the relationship between rateable value and consumption and the average rateable value of unmeasured properties being 50% of that of equivalent measured properties.

There are currently only 2,624 unmeasured non household properties in our customer supply area. It should be noted that because of the very small number of properties involved, this group only accounts for 0.18% in Essex and 0.11% in Suffolk of total non-household demand.

Measured non-household consumption uses the metered consumption from meter reads. This is then increased to allow for meter under-registration and an estimate of supply pipe leakage for internally metered non-households is added to this to provide the water delivered figure.

4.2.5 Supply Pipe Leakage

The same methodology for quantifying supply pipe leakage has been used since 2006, when a project was undertaken to improve our estimates. Regular review of current practices has taken place in this time although no methodology has improved the accuracy of quantification of supply pipe leakage. For this project, unmeasured leakage flows were collected from the SWU and measured leaks were gathered from the customer billing database, which stores information collected in leakage allowance forms. Two databases (measured and unmeasured) were compiled, through which the average volume, duration and frequency of leaks could be calculated. It was recognised that the measured database had limitations because generally only larger leaks are recorded because they have been detected through meter readings. Similarly, the SWU leaks have not been left to run as long as undetected leaks on unmeasured households could run for and mainly referred to properties within the Essex area.

It was established early on that every leak would start with similar characteristics irrelevant of the property meter status. It was also suggested that every leak has a hypothetical flow rate, at which the leaks become 'noticeable'. The average leakage volume of the 'noticeable' stage could be taken from the respective databases. The importance of determining the average duration, frequency and flow rate of leaks before they reach the hypothetical 'noticeable' stage was recognised.

The SWU leakage records provided daily flow rates. Analysing these in detail allowed a 'natural rate of rise in leakage' curve specific to us to be constructed. From this, it was possible to assume that the average leak will run for a period at a flow rate of 0.0073 l/sec (regarded as so small that it cannot be noticed). Once

noticeable, the duration, frequency and volume of leaks depend upon the meter status of the property. The frequency of occurrence of leaks was 0.014 for unmeasured properties and 0.004 for measured properties. The frequencies were calculated using population and leakage figures specific to each year.

Calculations revealed average daily leakage volumes of 27.12 litres per property per day for unmeasured properties in Essex and 12.94 litres per property per day for measured properties in Essex. For Suffolk it was necessary to calculate equivalent values due to the very small size of the database. This gave figures of 14.22 litres per property for unmeasured properties and 6.78 litres per property for measured properties. Supply pipe losses are then allocated to the various categories of properties, on the assumption that losses from the typical externally metered household property will be lower than those of unmeasured or internally metered properties. This assumes that externally metered household customers will notice any unexpected increase in their consumption and will inform us sooner than the other categories of customer. Final supply pipe loss values are shown in Table 4.2.

Table 4.2: Supply pipe loss values

	Essex (l/p/d)	Suffolk (l/p/d)
Unmeasured Hsehd SPL	28.00	14.00
Measured Hsehd/Measured Non-Hsehd SPL (Ext)	14.00	07.00
Measured Hsehd SPL (Int)	28.00	14.00
Unmeasured Non-Hsehd SPL	28.00	14.00
Empty Property SPL	28.00	14.00

4.2.6 Meter Under-Registration

The allowance for household and non-household meter under-registration is consistent with the results found in the Review of Meter Under-Registration (WRc, 2009). The results were as follows:

- Under-registration figures for household meters have been calculated based on the data supplied to WRc, as: ESW: 3.98%
- Under-registration figures for non-household meters have been calculated based on the data supplied to WRc, as: ESW: 4.31%

4.2.7 Void Properties

Base year property figures are taken from our billing database which includes the total number of void properties each year. Void properties are forecast to decrease over the planning horizon. The forecast number of household voids as a percentage of total household properties is shown in table 4.3.

Table 4.3: Forecasted void properties

	Essex		Suffolk	
	2016/17	2059/60	2016/17	2059/60
Measured Household	3.84%	3.36%	3.60%	4.00%
Unmeasured Household	4.33%	3.04%	4.35%	3.72%

4.2.8 Operational Use and Water Taken Unbilled

As a result of the work carried out for the Annual Return (Ewans Associates, 2002) operational use continues to be assessed using similar methods to those applied in our Northumbrian Water area. This review looked at developing methodologies for determining all aspects of operational use and water taken unbilled and included site measurements for certain parameters. Since the review, wherever possible, the methodologies supported by Ewan’s report have been used and new data input where it has become available. Some improvements have been made generally in the data reporting such as the standpipes hired now being metered.

The reported figure for operational use covers volumes used for treatment works’ use, service reservoir and tower cleaning, third party bursts, flushing, new mains and rehabilitation.

Water taken legally unbilled includes the following components:

Table 4.4: Components of water taken legally unbilled

Treatment Works	Sample Taps, Filters, CRITS
	Property Use
Service Reservoirs, Tower & PS Sites	Reservoir & Tower Cleaning
	Commissioning New Sites
	Sample Taps
Bowser & Tanker Filling	Bowser
	Tanker
Third Party Bursts	
Flushing	Routine / Planned
	Repair / Reactive
New Mains	Distribution Mains
	Trunk Main
	Infrastructure Maintenance
	New Development
SPL Voids	Supply Pipe Leakage Void Properties

The reported allowances for metered volumes have been determined from individual accounts and meter readings.

Water taken illegally unbilled includes an estimate of consumption of occupied void properties, based on our recent void inspections, and an assessment of illegal hydrant use, based on methods from the Ewan’s report (Ewan Associates, 2002).

4.2.9 Bulk Supplies

The bulk supplies are as follows for 2016/17 (MI/d).

Table 4.5: Bulk supplies for 2016/17 in MI/d

Chigwell Import	84.30
Imports [Cressing]	0.86
Anglian Water Export	2.40
Affinity Bulk Supply Export	0.03
SSE Water Export	0.31

4.2.10 Re-basing the 2016/17 Figures

For both the Essex and Suffolk areas the normalised PCCs have been used to calculate measured consumption. PCCs have been calculated from the population and occupancy figures from the new forecast described below.

Our work planning database has been analysed to provide figures for the number of households internally and externally metered and for the sub-division into optants, selectives, new and pre-existing metered groups.

For the final submission of the NWL Business Plan in 2004, it was decided that the best way to forecast metered household consumption was to create a category of customers that we call “existing metered”. To forecast metered consumption, base year consumptions had been derived from our billing database for recent new houses and for recent optants. In theory, the base year customer-base could be divided into these broad categories - past metering policy had not been this simplistic, e.g. prior to free meters for all optants, we had a policy of metering sprinkler users – strictly an optant process in that the customer could choose whether to be metered or to discontinue using a sprinkler, but customers metered through this process would be expected to have different occupancy and consumption characteristics from other (financially driven) optants. Also, we had compulsorily metered the Galleywood zone in 1993/4, and later introduced free meter optants for single occupant OAPs.

For these reasons, the base year consumptions for recently metered new and optant customers, if applied to the whole metered household base in 2002/3, did not give a total metered consumption matching that of the June Return reported total household metered consumption. It was therefore decided that all households metered up until the base year would be placed into a single category of known consumption – the existing metered, with the total base year metered household

consumption. For these customers their consumption is known with confidence and so it makes sense to use this certainty in the forecast.

The existing metered customer base will not increase over time within the forecast, in that new customers will not be added until a new forecast is created every five years, but the number of households may be expected to change slightly due to voids, disconnections or demolitions. The customers metered by the 2016/17 base year have been moved into the existing metered base. Customers metered from 2017/18 onwards will join one of the following categories: new, options, selective.

We believe it is reasonable to regroup the customers every five years because changes in occupiers mean that a household metered through one particular metering process cannot be expected to keep those characteristics for all time – low occupier optants will be replaced by “average” occupiers, those whose behaviour may have changed through publicity surrounding a compulsory metering process may be replaced by occupiers who are ambivalent to the property being metered etc. Any attempt to forecast these uncertain changes could not be completed with reasonable accuracy and therefore such a process would not improve the accuracy of the demand forecast. A compromise position is therefore to re-base every five years.

To create the base year figures for the WRMP, the following processes took place:

- The households in the 2016/17 Regulatory Report new, optant and selective groups were added to the existing metered group. This means for the WRMP, figures for 2016/17 have zero households in the new, optant and selective categories, but from 2017/18 households are added to these groups in line with the metering forecast.
- For 2016/17 onwards the latest population forecast has been applied. This is the forecast based on the plan based scenario that we commissioned Edge Analytics to produce. The overall occupancy forecast for 2016/17 onwards is derived from this population forecast and household forecast.
- 64.67 MI/d total leakage figure has been applied to 2016/17.
- As a result of the changes in the base year a water balance has been produced to provide the post rebased MLE figures.
- 2017/18 actual property numbers have been used in the forecast.

4.3 Population and Properties

The base building block for demand forecasting is the base year population served and the projected growth in population annually over the WRMP. This is a highly specialised area of the demand forecast, along with property growth numbers, and

we employ specialist consultants to prepare the forecasts of population and property by each WRZ.

However, whilst the consultants use official Office of National Statistics base year and projections for population and Local Authority data for property forecasting, both forecasts vary considerably when refreshed each five years. In addition the actual number of new properties built in Essex against those forecast to be built in the WRMPs invariably fall far short.

The graph below clearly demonstrates the dramatic changes in forecast numbers that have been experienced at each five yearly refresh of Essex WRMPs. The first WRMP (PR99) we had a population forecast for 2025, and each subsequent WRMP has had a new population forecast including a population for 2025. The 2025 population given in each WRMP is plotted below:




Figure 4.5: Essex population forecast for 2025

The large variance in population for 2025, which is a reflection of updated WRMP population figures for each year of each plan, clearly demonstrates the ethereal nature of any single year's forecast of future year's populations. Given that in Essex in 2025 only approximately 15% of Distribution Input (DI) will be non-household and 10% will be leakage, then 75% of demand will be from the domestic population. The difference in population estimates in 2025 between PR99 and PR19 is in the order of 317,000 people.

The population of Essex has grown as an overspill to London. Historically migrants settle in London for a period, when they begin families they then move out to surrounding counties, especially Essex. This has brought in young people with growing families whilst the older, retiring Essex people tend to move out to Suffolk and Norfolk. This gives a net increase in Essex population. Since the recession, the already below planned level of new homes, has fallen by over 50%. Equally the number of house moves has been a fraction of the pre-2007 levels. This has had the effect of nowhere for London migrants to go in Essex and a larger population remaining in London. This partially accounts for the much higher population growth

forecast for London compared with Essex. The recent pickup in new home completions and secondary sales still falls far short of the historic numbers and it is difficult to see when in the future it will return to trend levels.

4.3.1 Population

We have commissioned Edge Analytics to prepare the base year and forecasted year populations. ESW own the forecasts produced.

In line with the WRPG (Environment Agency, 2017a) requirement, we have used local authority Plan housing growth evidence from all local authorities and has selected the Plan-based scenario. The detailed methodology used to determine household growth, including assumptions and limitations, is provided in Population, Household and Property forecast technical report (Edge Analytics, 2017). A comparison between Trend and Plan-based scenario's is shown in the below graphs.




Figure 4.6: Essex trend and plan population scenarios




Figure 4.7: Suffolk trend and plan population scenarios

Edge Analytics used best practice methodology which follows the requirements of the WRPG.

Below is the Essex supply demand balance for the local authority Plan growth projections for population and property, including a 20 MI/d supply to TWU for 20 years.




Figure 4.8: Essex supply demand balance for Local Plan growth projections

Edge Analytics were contracted to produce an update to the population and household forecasts by District Metered Areas (DMAs) in the Essex and Suffolk areas. In line with the WRPG requirement, Edge Analytics has collected Local Plan housing growth evidence from all local authorities that are either wholly or partially included within the NWG operational boundaries (Essex & Suffolk Water and Northumbrian Water).

Each of the 38 local authorities (plus five National Park Authorities) is at a different stage of Local Plan development. All have collated a variety of demographic and economic evidence to inform the plan-making process. Some plans have been adopted; others remain under development or open for consultation.

The information in the following table provides a summary of the current status of each Local Plan with an indication of the likely housing growth target over a designated plan period. These data are subject to change but provide a point-in-time perspective on likely housing growth outcomes that can be compared directly to existing 'trend' outcomes (on which the majority of the Local Plan evidence will have been based).

Table 4.6: Local Plan status, January 2017, NWG area (Source: Local Planning Inspectorate, Local Plans)

Area	Latest Local Plan Status ¹	Local Plan Period	Housing Target
Barking & Dagenham	Consultation	2015-2030	28,492
Basildon	Draft	2014-2034	15,260
Braintree	Draft	2016-2033	14,365
Brentwood	Draft	2013-2033	7,240
Castle Point	Adopted	2011-2031	2,140
Chelmsford	Consultation	2021-2036	11,625
Colchester	Emerging	2017-2032	18,400
Eden	Examination	2014-2032	3,600
Epping Forest	Consultation	2011-2033	11,400
Great Yarmouth	Adopted	2013-2030	7,140
Havering	Consultation	2017-2032	17,550
Maldon	Examination	2014-2029	4,410
Mid Suffolk	Emerging	-	11,100 (2011-2031)
Newham	Emerging	-	-
Redbridge	Draft	2015-2030	16,845
Rochford	Emerging	-	4,800 (2011-2031)
South Norfolk	Emerging	Until 2036	15,516
Southend-on-Sea UA	Emerging	-	6500 (2011-2031)
Suffolk Coastal	Emerging	2010-2027	7,900
The Broads Authority	Consultation	2012-2036	320

Area	Latest Local Plan Status ¹	Local Plan Period	Housing Target
Thurrock UA	Emerging	2014-2037	19,044
Uttlesford	Consultation	2011-2033	12,496
Waveney	Emerging	2011-2036	7,700 - 9,525

Where available, the annual allocation of the overall housing target was taken from the information provided by each council. In cases where this information was not available, the overall housing target was distributed equally over the Local Plan period with adjustments made to take account of historical completions if available. These annual housing growth trajectories form the key input to the Plan-based forecast.

The technical report (Population, Household and Property forecast (Edge Analytics, 2017) has detailed the development of two key scenarios: a Trend-based scenario which replicates the 2014-based sub-national projection from ONS; and a Plan-based scenario which is driven by local authority Plan housing growth statistics. NWL's billing data has provided the basis for alignment of property numbers in the base year of the forecast period. A sensitivity analysis has been presented, to explore the uncertainty associated with forecast development.

Household and property forecasts at Census Output Area (OA) level

- Household forecasts at OA level have been calculated by applying household representative rates from the Department for Communities and Local Government (DCLG) household projection model at Local Authority District & Unitary Authority (LADUA) level to the OA level population, excluding population not in households.
- For the forecast years, OA level households have been reconciled to the trend in the LADUA level household totals derived at Step 3.
- The DCLG provides data for a forecast period that is shorter than our forecast horizon. After the last year for which the DCLG data are available (2039), the household representative rates have been kept fixed for the remainder of the NWL forecast period.
- An OA-level vacancy rate has been calculated using statistics on households (occupied household spaces) and dwellings (shared and unshared) from the 2011 Census. This vacancy rate has been applied to the OA level households for each of the forecast years to create OA-level property figures.
- Property data from our billing database has been used to provide an alternative property forecast that is more closely aligned to the number of NWL properties in 2016.

Sensitivity analysis -

- All demographic forecasts are subject to an element of uncertainty. Consideration of this uncertainty is an important element of the WRMP demographic evidence. The Edge Analytics approach includes a 'sensitivity'

analysis, which considers the uncertainty associated with its forecasts in three ways: through the use of error distribution statistics recommended in the UKWIR guidance; through the development of both trend and plan-based scenarios; and through the application of variant assumptions to its scenarios.

- The Trend-based and Plan-based scenarios provide a range of growth outcomes, the first based on a continuation of historical trends, the second based on an expected trajectory of housing growth.
- In addition, the UKWIR guidance provides error distribution tables which have been applied to NWL growth forecasts, identifying broad upper and lower confidence percentiles for each year of the plan period. Furthermore, with international migration being a key area of uncertainty, the aggregate Trend-based scenario is presented alongside ONS high and low migration variants.
- Finally, the aggregate Plan-based forecasts have been derived using variant household growth assumptions, applying faster and slower rates of household formation from the DCLG’s 2008-based (HH-08) and 2014-based (HH-14) models respectively. These alternatives consider variations in the rate at which household occupancy is expected to decline over the plan period.

Chosen population growth scenario

In the case of Essex and Suffolk supply areas, the population forecasts for PR19 using the Plan-based scenario shows a growth in population over the planning horizon. For Essex this has resulted in a 20.0% increase over 25 years and a 19.7% increase in Suffolk.

The detailed methodology used to determine population growth is provided in detail in the Population, Household and Property forecast technical report (2017).

Table 4.7: Population Growth for Essex and Suffolk

	2016/17	2044/45	Increase	% Increase
Essex	1,648,773	1,979,281	330,51	20.0%
Suffolk	270,967	324,349	53,382	19.7%




Figure 4.9: Essex population growth




Figure 4.10: Suffolk population growth

4.3.2 Occupancy

The overall occupancy comes from the Edge Analytics domestic population figure. This total population is divided by the total number of billed households for the year to give an overall occupancy rate. However, whilst a total population figure is essential in the demand forecasts, an overall occupancy figure is at too high a level to be useful in the demand forecast directly. This is because the different housing

categories of our customers have different average occupancies. For example, unmeasured customers have a higher occupancy than that of the optant meter customers. This is due to low occupied properties where the customer gains financially by paying a measured charge whereas a high occupied property, if electing for a meter, would pay more for their water and sewage than if they remained unmeasured. It is therefore necessary to have a specific occupancy for different classes of customer.

The occupancies are set by various sources of information available to us, ranging from specific occupancy surveys sent to a random selection of customers, occupancy taken from meter optant applications, occupancy of customers on unmeasured consumption monitor 'The Study of Water Use', customer billing and professional judgement based on past occupancy and future forecasts of changes in the customer base.

The most recent survey data has come from the Micro-component Survey used to determine the ownership and frequency of use of water using appliances in the home. These surveys were carried out in January-March 2017 to populate the model for looking at future changes in PCC. For us a total of 10,714 responses were received. In the survey customers were asked to indicate the total number of people in the households and the breakdown of occupants for six different age groups as recommended in the UKWIR 'Integration of behavioural change into demand forecasting and water efficiency practices' report (UKWIR, 2016c). More information on these surveys is available in section 4.4.2.

Essex

The overall occupancy for all households steadily declines from 2.64 in 2016/17 down to 2.49 in 2059/60. The occupancy forecast for different metered properties and unmetered properties in Essex are shown in Table 4.8.

Table 4.8: Essex forecasted occupancy

Year	2016/17	2020/21	2030/31	2040/41	2050/51	2059/60
New Homes	2.26	2.29	2.35	2.40	2.45	2.50
New Optants	1.84	1.89	1.99	2.09	2.19	2.28
Existing Measured	2.20	2.25	2.30	2.35	2.40	2.45
Measured	2.20	2.23	2.27	2.33	2.39	2.45
Unmeasured	3.27	3.34	3.59	3.30	3.00	2.84

Suffolk

A number of sources of data on the occupancy of different property groups in Suffolk were used to inform the occupancy in the base year and future years for the Suffolk demand forecasts. The occupancy of the property groups is set for Suffolk as a whole and then the same occupancy used for each of the three Suffolk WRZs. It is

not considered that any of the three WRZs have different occupancy characteristics nor is it considered viable to determine the three WRZ occupancies separately. Suffolk is likely to have different occupancies to Essex due to the high level of meter penetration that has been predominantly achieved by customers opting for a free meter. This suggests that Suffolk has a very high proportion of low occupancy housing compared to Essex. However, with an identical overall occupancy to Essex, this does mean that the unmeasured households in Suffolk will have a significantly higher occupancy. The higher number of low occupancy households in Suffolk is thought to be partially due to the touristic nature of the area, attracting a larger number of second home owners than Essex. If a property is a second, or weekend only home then it is usually more financially beneficial to have a measured, rather than an unmeasured, property.

The overall occupancy for all households steadily declines from 2.29 in 2016/17 down to 2.22 in 2059/60. The occupancy forecast for different metered properties and unmetered properties are shown in Table 4.9.

Table 4.9: Suffolk forecasted occupancy

Year	2016/17	2020/21	2030/31	2040/41	2050/51	2059/60
New Homes	2.03	2.06	2.11	2.16	2.21	2.25
New Optants	1.76	1.81	1.91	2.01	2.11	2.20
Existing Measured	1.90	1.93	1.98	2.03	2.08	2.12
Measured	1.95	1.93	1.99	2.05	2.11	2.17
Unmeasured	3.05	3.11	3.06	2.86	2.66	2.47

New Homes:

The occupancy for new homes in both Essex and Suffolk reflects the overall lower occupancy, the results from the micro-component survey and the fact that in the recent few years there has been a significant increase in the number of single bedroom apartments being built. The occupancy is forecast to increase gradually through to the end of the planning horizon in line with an increase in overall occupancy.

New Optants:

The optant occupancy for both Essex and Suffolk has been taken from the micro-component survey results. We forecast a modest increase in optant occupancy as there will always be changes to family occupancy that will result in the remaining occupier opting for a meter. While the occupancy rate of optants remains relatively steady over the 25 years, the actual number of properties opting for a meter decreases as increased metering removes eligible properties.

Existing Measured:

The base year for what becomes the existing measured is all the measured groups used in the reported outturn year, rebased to take account of changes in overall population and information from occupancy surveys. This occupancy is reset every five years when the new WRMP is produced.

Measured:

The occupancy of the overall measured is calculated from all of the different metered components using their assigned occupancy and weighted by their forecast property numbers. Changes in this occupancy in the forecasts is influenced by the occupancy of the groups that dominate in the future e.g. new homes and optants.

Unmeasured:

The unmeasured occupancy is calculated by subtracting the population assigned to all of the measured groups from the total household population and dividing this by the remaining number of billed unmeasured properties. This would always be expected to be the highest occupancy class but over time the overall measured occupancy and unmeasured occupancy converge towards each other.

4.3.3 Properties

Base year property figures are taken from our billing database. The growth property figures for each of the forecasted years are provided by Edge Analytics, commissioned by us. In line with the WRPG requirement, we are using Local Plan housing growth evidence from all local authorities that are either wholly or partially included within the our operational boundary. Please refer to the Population, Household and Property forecast technical report (Edge Analytics, 2017) for detailed information.

4.4 Household Demand Forecast

The household demand forecast has been developed by considering the population in groups as follows:

1. Unmeasured customers
2. Meter Optants
3. New Homes
4. Existing Metered

These groups have been chosen because we believe their consumption characteristics are noticeably different. However, households already metered cannot sensibly be assigned to the separate metered groups, as the consumption of this group is known, so it makes sense to regroup the metered customer base into a single category, which we call “Existing Metered” every five years.

4.4.1 PCC

For the unmeasured, new homes and existing metered groups we have forecast PCCs using a new improved micro-component model, which has been populated for the base year using data collected from an appliance survey.

For the meter optant group we have determined its future PCCs as a percentage reduction relative to the unmeasured PCC, maintaining the previously accepted and agreed assumptions. A further percentage reduction has been included from 2021/22 when smart metering is introduced. For more information please refer to section 5.2.

As a result of the introduction of water efficiency standards into Part G of the Building Regulations which came into force in April 2010, it is a requirement that all new homes are built to deliver consumption not exceeding 125 l/h/d. In 2017, we completed analysis of consumption in new homes built after 2012, the results showing that the PCC was lower than the 125 l/h/d standard. New homes start with a forecasted PCC of 118 l/h/d which decreases in 2021/22 with the introduction of smart metering.

Savings from the water efficiency target and smart metering have been included in the baseline and final PCC forecasts. Further details of these savings are provided in section 5 of the WRMP.

4.4.2 Water Use Survey

To ensure the latest source of information about our customers is included in the formation of a robust demand forecast a water use survey was created to collect occupancy, household appliance and water use information from our customers. An overview of the method is given below with detailed information available in the Micro-components Technical Report (Essex & Suffolk Water, 2017c).

Following the best practise for customer water use surveys in the UKWIR report (UKWIR, 2016c), a stratified sampling method was selected where the customer base is split into sub-groups which are presumed to have distinctly different water consumption characteristics. Customers were split into the sub-groups of measured and unmeasured properties. The measured group was divided by meter status (e.g. optant, selective) and then all these groups were further divided into ACORN³ categories. (Please refer to the Micro-components Technical Report (Essex & Suffolk Water, 2017c) for more detailed information on the sampling method).

A postal and online survey method was employed to collect responses from customers. The survey design is based upon the 'long survey form' in the UKWIR (2016) report to a follow consistent approach to water use surveying with other water companies which in the future can develop nationally consistent datasets for comparison and pooling of data.

The survey consisted of 31 detailed questions which began with household type, age and occupancy questions, followed by household water using appliance ownership, frequency and duration of use questions, and finishing with questions on outdoor water use. An example of the survey and letter are shown in the Micro-components Technical Report.

Previous surveys of this nature have generated a 20% response rate in our customer supply area and so based upon this expectation a total of 47,075 of our customers were mailed in January 2017 with the water use survey. 6,206 of these customers also received an email version as they had already supplied us an email address.

A sum of 10,004 surveys was returned from this initial mailing. Although this is a 21% uptake a few sub-groups did not reach their specified quota and therefore a subsequent mailing was necessary. A totally different set of customers was randomly selected for the second mailing following the same sampling techniques as the first. 6,085 customers were sent the second mailing in February 2017 with 819 of these also receiving the email version. In total 10,714 surveys were returned. Survey answers were then split into different micro-components for analysis.

4.4.3 Integration of Behavioural Change

Water companies are increasingly interested in the way customers use water and the effect their behaviour and habits have on the total demand for water and how to forecast changes in behaviour. The UKWIR (2016c) project developed a framework for water companies to integrate behavioural change into demand forecasting.

The report looked at customer survey and consumption data and from this discovered it was possible to explain about 50% of the variation in household demand by a particular property type or garden size and dishwasher ownership (hence why these questions are included in the water use survey). Therefore, the remaining 50% of the variation might be attributable to additional 'human factors' but frequency of use information is able to explain a further 30% of the variation.

Following the framework of the UKWIR (2016c) report a medium level of planning concern approach was followed for all WRZs. The framework recommends following the approach of the previous study's report (UKWIR, 2014) with the inclusion of scenario analysis allowing the sensitivity of the central demand forecasts to be tested.

Therefore the framework from UKWIR (2014) uses the standard micro-component approach inferring consumption from self-reported survey data using micro-component assumptions. This is detailed in the following section on the Micro-component Model. A lowest tier has been selected for the level of detail for analysis where segmentation of customers is by unmeasured / measured status and a further split by metered status (optant, selective). Segmentation by acorn data has been collected for future analysis but has not been utilised in the micro-component model.

This segmentation allows for sensitivity to external factors to be identified for each customer segment and included in the model to integrate behavioural change.

The information collected in the customer water use surveys helps understand the current behaviours and attitudes to water use of our customers and this is then reported and forecast through the micro-component model. For more information on the integration of behavioural change please refer to the Micro-component Technical report.

4.4.4 Micro-component Model

A micro-component model has been selected for estimating future household water consumption. This well-established model offers a more detailed logical approach as it quantifies the water used for specific activities (e.g. showering and toilet flushing) by combining values of ownership, volume per use and frequency of use to give a PCC figure (UKWIR, 2015). In the UKWIR (2012) report alternative approaches to household consumption forecasting were reviewed and this approach of using a micro-component model was recommended based upon the work of Paul Herrington (Herrington, 1996). From this report the highest tier for forecasting PCC has been selected for improved accuracy which forecasts trend using micro-components.

The model data sources are customer water-use surveys (please see section 4.4.2), Defra MTP reports (Defra, 2012) and the unmeasured individual household monitor (Environment Agency, 2017b).

The model used for PR14 has been updated and the base year is now 2016/17 which projects forward annually to the end of the demand planning horizon. The micro-components are split into the following sections as recommended by the Environment Agency (2012a):

- Toilet flushing
- Personal washing
- Clothes washing
- Dishwashing
- Outdoor use
- General use

These sections are subsequently split into sub-components to analyse ownership, frequency and duration of use in detail. Wherever possible ESW-specific data has been utilised and then reviewed alongside previous surveys and other available data sources to ensure that spurious results from small samples are identified and treated with caution.

For all micro-components the start position and rate of change is defined and applied to the duration of the planning horizon. For those components involving white goods, a range of models and their associated average volumes per use have been

identified. Along with this are stated the assumed model lifespan and the dates when lower-volume technologies are expected to be introduced. There is a separate model for Essex and Suffolk.

In the tables the values for micro-components are the values detailed in this section (normal year values) with dry year uplift and meter under-registration added on. The values also include any water efficiency savings. Metered values refer to metered existing properties only.

An overview how the micro-components make up PCC is given below but for more detailed information please refer to the Micro-component Technical Report.




Figure 4.11: Unmeasured micro-components




Figure 4.12: Measured micro-components

4.4.5 Overall Household Demand

The resulting PCC forecasts show an overall household PCC, for the normal year, final plan, reducing steadily over the planning horizon from 149.09 l/h/d in 2016/17 to 114.37 l/h/d in 2059/60.

4.5 Non-Household Demand Forecast

This section sets out the non-household demand forecasts for 2017/18 to 2059/60 for us. These forecasts show actual volumes up to 2016/17 and use our own non-household demand forecast methodology for 2017/18 and beyond.

The methodology used for forecasting non-household demand is set out and then the forecast results are discussed.

In April 2017 there was a major change to the water industry with the creation of a new non-household water market. This saw the separation of retail activities and the creation of wholesale companies and retail companies. This means that going forward for the non-household water market our primary 'customers' are the retail companies, who then in turn bill the end user or non-household customer. For simplicity, through this report the term 'customer' will still refer to the end user rather than retail companies.

While these changes to the industry will not affect the demand of water from non-households it does mean that, as a wholesaler, we will not have responsibility for the primary direct contact with end customers in the same way that it did in the past and that the only information held by us about end users will be the data that is available within the Central Market Operating System.

4.5.1 Methodology

We have developed our own forecast methodology for non-household demand for the 2020 WRMP and for use in Ofwat's PR19 price control process. This methodology uses trend data based on past actual use by customers to predict a profile of future demand.

The demand forecast methodology is based on a number of assumptions and a formula built on three elements. The customer base is split into two groups:

- Identified customers who use more than 10,000 cubic metres of water per year and for whom an individual forecast has been generated for each customer;
- Non-identified customers who use less than 10,000 cubic metres per year for whom an average volume per property is forecast, and their total demand is calculated by multiplying this average by the forecast number of properties.

The key assumptions made are:

- No new identified customers will open during the forecast period, and no closures will be forecast, unless robust, public domain information is available. Any new customers will fall into the non-identified group of customers;
- In general, demand for individual customers remains relatively stable unless there is an expansion or reduction on the customer's site, or if they fundamentally change how they use water. These events cannot be predicted and so it cannot be assumed that these events will happen unless they are already in progress;
- Demand will trend to a flat line over time if there are no changes to water use on site. Recent past data may show a decreasing trend due, for example, to water efficiency measures. However forecasting that reduction to continue at the same rate for 40 years is unrealistic. Therefore a forecast calculation that trends demand to a flat line over time has been used;
- It is extremely difficult to robustly forecast the economic climate 40 years in advance. Therefore the non-household demand forecast is not modified for the behaviour of the economy.

Over the years of producing WRMP's various methods have been used to forecast non-household demand. Economic forecasts used to produce non household water forecasts have proved unreliable and given to dramatic change even between the draft plan and draft final plan. Talking with large users has also proved fruitless as even if future closure is planned they do not inform us before their own workforce being informed at the appropriate time. Their forecasts of potential growth, based on future economic forecasts prove equally unreliable, certainly beyond a few years. The retailers are not mature enough for this year to produce reliable forecasts and they would meet with the same degree of uncertainty from their larger customers that we have found. We have used trend analysis for the previous two WRMP's and these have proved sufficiently accurate. The method used is described below.

Taking into account these key assumptions a formula was developed that uses a logarithmic trend as a base to forecast demand. This forecast is based on three sections:

- Trend data
- Step change adjustment
- Economic adjustment

Demand components used in the calculation of household demand are all weighted to average demand.

Trend forecast

The past ten years of actual demand is used to develop a profile of demand based on a logarithmic trend. Using trend data provides a more average look at demand over time, and should provide a central forecast of demand out to the future. Any abnormal demand, such as a single year of high demand caused by leakage, or

abnormally low demand as caused by a partial closure, will be smoothed out and will not overly influence the forecasts.

Step change adjustment

Over the past ten years, some customers may have made a step change in their demand, which means that demand in recent years should have more influence over demand than the demand from ten years ago. A pure trend analysis will not take full account of this step change, and therefore a calculation has been included that looks at the difference between demand early in the series of data and demand in the most recent years. The forecast based on the trend is adjusted by this difference, called the “step change adjustment”, to bring the forecast into line with actual demand experienced in the recent past.

Economic adjustment

This is a percentage multiplier to be factored in to the trend forecast, which is an assumption that allows for an adjustment to make future demand more or less positive than experienced in the past.

No adjustment has currently been made to this element of the formula because we do not believe there is sufficiently robust data available to forecast the economy out into the future. At the most it may be possible to indicate that the next few years may show lower demand than past trend data may indicate, however it is difficult to say by how much. In addition the various forecasts of the economy, for example from HM Treasury, change on a regular basis. We also believe that it is difficult to tie demand for water use to the strength of the economy. Implementation of water efficiency measures can offset any growth, and the opening or closure of one large customer can throw any forecast out of line with expectations. Therefore it is preferred not to use this adjustment on this basis at this time. This position may be reviewed.

The graph below illustrates how this demand methodology would predict demand for a customer.




Figure 4.13: Example of demand forecast (orange line would be used in the Company’s forecast)

This customer clearly had some abnormal demand in 2015/16. This influences the trend and so purely using the trend forecast would over forecast (for this particular customer). The most recent demand has been lower than the trend would indicate, and so the step change adjustment modifies the forecast downwards for this example customer, although not to the lowest ever demand, but to a position in line with recent demand. The “step change adjustment” would adjust upwards, should recent demand be higher than the trend data indicates.

Application of the methodology

The demand forecast applied an individual trend line for each identified customer. For all of the remaining non-identified customers an average demand per property has been derived and the same trend approach had been applied using the average demand per property. The forecast average per property is then multiplied by the forecast number of non-identified properties to generate a total forecast demand for the non-identified customers.

4.5.2 Non-Household Forecasting

Uncertainty

It is not possible to predict exactly what will happen in the future, as has been demonstrated with the change to the economic climate over the past five years and the uncertainty around the potential impact of Brexit on British industry. Customers can close at a moment's notice and, as there are no contracts with water customers, they can increase or decrease demand at any time. While good contact with customers can keep track of general changes, frequently significant changes are commercially sensitive, and are not communicated to us in advance.

The methodology used for our non-household demand forecast uses the real data available, and combines this with an overall view to result in a reasonable looking forecast. If there has been decreasing demand in recent years, and the economic climate seems to remain generally pessimistic, it seems reasonable to forecast decreasing demand in the next few years. It is unlikely that demand may suddenly surge, unless there is major growth in industry, but it is possible that a slight increase could occur, should the economy recover. On the other hand demand could collapse should current trends continue into the long term. Using a flat trend gives a forecast that arrives somewhere between these two scenarios. In reality, some customers will increase their demand and other will decrease, which in many cases will offset one another.

Sensitivity

Different ways of forecasting will produce different forecast volumes. The demand forecast based on individual trend forecasts for individual customers was tested against what the forecast would look like if trends based on sector or size were used instead.

These forecasts do not pick up step changes in single customer behaviour, they tend to be smooth. They also incorporate data for properties that have closed, therefore a sector or size trend tends to be lower than one based on individual trends. Such a trend could be viewed as valid, however it is counter to the starting assumption that all existing identified non-household customers will remain open, unless otherwise publicised.

The non-household demand forecast is most sensitive to assumptions in demand of the largest contributors to demand. These are the assumptions applied to the group of non-identified customers, and the demand profiles of the largest customers. The forecasts for the largest non-household customers have been reviewed individually to ensure that they take account of the latest information available, and that their forecast consumption is based on a centrally reasonable estimate. The following graph shows how demand for a large customer can be volatile year on year. Using the trend based approach ensures that the forecast demand is not based on the peak or lowest demand. In this case recent demand is slightly higher than the trend would indicate so the forecast used is adjusted slightly upwards by the “step change adjustment” as previously described.




Figure 4.14: Example demand forecast for variable demand at anonymous larger customer.

The forecast would be sensitive to demand for this customer if either the 2016/17 peak demand or the lower demand of 2014/15 were used. The trend gives a clear way to make a decision on where to pitch demand, and one that can be consistently applied across all customers.

Should information become available that this particular customer is making a step change to their demand, for example by a partial closure in the next year, or maybe that they intend increasing their production line which will increase their demand, this information can then be built into the forecast, by either reducing demand in the year stated for the partial closure, or by increasing demand by overwriting the “step change adjustment” to reflect the expected increase.

Having tested the forecast methodology in several ways, we feel confident that it provides a reasonable forecast that is based on sensible assumptions.

4.5.3 Potable Water Demand by Sector

At this stage demand has not been analysed by Standard Industrial Classification. This is because the methodology of looking at smaller customers as a group means it is not necessary to look at different types of smaller customers. Small customer demand is discussed in more detail below.

Each of the larger customers have been allocated to one of ten broad sectors, which have been aimed at grouping their demand into a small set of groups for which drivers of demand should be fairly similar.


Table 4.10: Non Household Customer sectors

	Title	Description	Examples
Small Customers	Non-Identified Customers	All customers who use less than 10,000 cubic meters of water per year.	
Large Customers	Heavy Industry		Mining, oil refinery, car manufacturers
	General Manufacturing	All industry that produces something physical	
	Food and Drink	Food and drink manufacturers	
	Utility	All utilities	Power stations, water services, water and sewerage companies.
	Public Sector	Organisations which are mostly funded by government and will be affected by the public finances.	Hospitals, schools, councils, prisons, police, fire services etc.
	Retail	Anything that sells to the general public.	Shopping centres and supermarkets.
	Leisure	All customers who are part of providing leisure and holiday activities to the general public.	Hotels, holiday parks, sports clubs.
	Agriculture		Farms, dairies, etc.
	Services	General service industries.	Finance, insurance etc.
	Teesside	A small group of large customers on Teesside in the North East.	Not relevant for Essex & Suffolk. Included to show consistency in the approach for the North East and Essex & Suffolk regions.

Defined industrial sectors

The graphs below illustrate the proportion of demand in each region from each of the sectors defined above. Small customers who use less than 10,000 cubic meters per year make up approximately 60% of measured non-household demand.

2016/17 Essex Volumes (MI/d)



2016/17 Suffolk Volume (MI/d)




Figure 4.15: Make-up of non-household demand in the Essex and Suffolk regions in 2016/17.

4.5.4 Essex Demand

Heavy industry is the largest area of identified customer use in Essex, being dominated by a few larger customers, one of whom has changed operation since PR14 and is using much smaller volumes of water than they had been historically. Food and drink and leisure are the largest areas of demand in the Suffolk region.

2016/17 Essex Volume (MI/d)




Figure 4.16: Breakdown of demand in the Essex Water Resource Zone for 2016/17.

Proportionally, demand in Essex is driven by households, with only 31% of demand coming from non-households.

Large customer historical demand

Since 2009/10 non-household demand has been quite stable in most sectors, and the changes in demand, particularly in the heavy industry category, as shown in Figure 4.17 are due to closures or changes in operations of specific properties.




Figure 4.17: Large non-household demand in Essex 2009/10 – 2016/17 – change in volumes.

Demand in all sectors is now lower than it was in 2009/10. Whilst the largest proportional reductions in demand are in heavy industry and agriculture, the changes in agriculture are against relatively small volumes. Non-household demand in Essex has been significantly affected by the closures or changes in operations of a few large customers in the heavy industry sector.

Small customer historic demand




Figure 4.18: Small Customer historic demand

Figure 4.18 above shows how demand from small non-households has changed year on year between 2009/10 and 2016/17 however, with a general decline over time. The step change seen in 2010/11 is partly due to the changes in reporting from systems.




Figure 4.19: Historic small non-household demand average per property in Essex

It is not possible to exactly determine the cause of the changes in demand however the higher consumption in 2010/11 and the subsequent reduction is a combination of leaks occurring during the harsh winter in 2010, subsequently finding and repairing these leaks and more attention being paid to water usage.

While these variations in average demand per property seem relatively small, accumulated over all small non-household properties this can add up to a significant change in total demand.

Forecast Demand

Overall Essex measured non-household forecast demand to 2060 is relatively flat, with a gradual increase over time to account for growth of non-household property numbers. This is due to the assumption built into the forecast methodology that individual customer demand will trend to a flat line over time. In the short term there is some uncertainty in the views from the government and HM Treasury on what the impact of Brexit will be on the UK economy in the coming years, and so the flattening of demand within this timescale seems reasonable.

It is unlikely that large increases in demand will be experienced, unless new large water users open. The forecasts do not assume that this will happen because assuming new demand is uncertain until the new site actually starts operation.




Figure 4.20: Forecast demand in Essex by sector – volumes are cumulative, so the gap between each line is the size of each sector.

Table 4.11: Change in measured non-household demand in Essex by sector between 2016/17 and 2059/60

Sector	Demand (M/d)		Change (M/d)	% Change	Notes
	2016/17	2059/60			
Small Customers	32.20	44.08	11.88	36.89%	Increase due to anticipated growth in small non-household customers, rather than increased demand from the current customer base.
Heavy Industry	4.32	4.30	-0.02	-0.27%	
General Manufacturing	2.54	2.53	-0.01	-0.27%	
Food and Drink	2.82	2.81	-0.01	-0.27%	
Utility	2.01	2.01	0	0%	
Public Sector	3.62	3.61	-0.01	-0.27%	
Retail	1.11	1.10	-0.01	-0.27%	
Hotels/Leisure	2.44	2.43	-0.01	-0.27%	
Agriculture	0.04	0.04	0	0%	
Services	2.95	2.94	-0.01	-0.27%	
Total	54.05	65.86	11.82	21.87%	

The largest change in the forecast is for small non-household customers, with the demand increasing due to anticipated growth in property numbers rather than an increase in average demand per customer.




Figure 4.21: Forecast demand in Essex – by sector

4.5.5 Suffolk Demand

Overall household demand is 53% of demand in Suffolk. Demand from small non-households and large non-households are evenly split, however due to the relatively small size of our Suffolk region, that large non-household demand is dominated by a few large customers.

2016/17 Suffolk Volume (MI/d)




Figure 4.22: Breakdown of demand in Suffolk Total 2016/17

As the graphs in the figure below show, demand in Hartismere WRZ is dominated by several large customers, whereas the proportion of household and non-household demand is comparable between the Central and Blyth WRZs.




Figure 4.23: Breakdown of demand in Suffolk Water Resource Zones for 2016/17

Large customer historical demand

Since 2009/10 non-household demand has been quite stable in most sectors, with no major decreases in demand.




Figure 4.24: Large non-household demand in Suffolk 2009/10 – 2016/17 change in volumes.

Demand in all sectors is now lower than it was in 2009/10, with the exception of food and Drink and Agriculture, which have seen slight increases in demand. Agriculture is a change on very small volumes, however the impact on food and drink is mainly due to an increase for one large customer.

Small customer historic demand

Figure 4.25 shows how demand from small non-households has seen a general reduction between 2010/11 and 2015/16, however in 2010/11 some changes to how data is reported from systems were made, which may have affected the increase in 2010/11.




Figure 4.25: Historic small non-household demand




Figure 4.26: Historic small non-household demand average per property

Forecast Demand

Demand in Suffolk is driven primarily by small non-household customers and the food and drink sector. The trends in these sectors will have a significant impact on the overall forecast.




Figure 4.27: Forecast demand in Suffolk by sector – volumes are cumulative, so the gap between each line is the size of each sector.

Overall demand has been reducing slightly since 2009/10, however has flattened somewhat in recent years.

Table 4.12: Change in measured non-household demand in Suffolk by sector between 2016/17 and 2059/60

Sector	Demand (MI/d)		Change (MI/d)	% Change	Notes
	2016/17	2059/60			
Small customers	8.79	10.17	1.38	15.74%	
Heavy Industrial	0.13	0.10	-0.03	-19.27%	
General Manufacturing	0.12	0.11	-0.01	-3.32%	
Food and Drink	4.03	4.03	0	-0.05%	
Utility	1.11	0.56	-0.55	-50.45%	
Public Sector	0.31	0.31	0	0	
Retail	0.06	0.04	-0.02	-33.09%	
Hotels/Leisure	2.02	1.97	-0.05	-2.43%	
Agriculture	0.19	0.26	0.07	39.07%	
Services	0.93	0.83	-0.10	-10.55%	
Total	17.69	20.38	2.71	15.32%	




Figure 4.28: Forecast demand in Suffolk – by sector.

4.6 Dry Year Forecast

4.6.1 Introduction

The historic record of weather versus demand has been examined to identify conditions of a dry year and the weighted average number of dry years expected has been calculated for us.

A dry year definition is required when a company decision is to be made for the June Return submission to Ofwat stating that the weather experienced during the period of the return has been a dry year or not. Simple criteria will be selected based on average maximum temperature and total rainfall for the return year. The supply and demand should be forecast under a dry year scenario reassuring people and organisations that the actions they will take under a dry year scenario will meet their level of service.

Guidelines from the Agency, Ofwat and NERA state that a dry year should be the basis of the demand planning process. A weighted average demand forecast is required as the basis of the company’s revenue forecast (Environment Agency, 2012b). In the planning horizon not all years will turn out to be ‘dry’. Typically the demand a company is most likely to be faced with will be a combination of demand from ‘normal’ years, ‘dry’ years or ‘wet’ years. The frequency of each type of year in the planning horizon and the demand associated with these types of years will be reflected in the weighted average forecast.

Temporary Restrictions on Water Consumption

Dry years should be based on a year of unconstrained demand, therefore years with periods of temporary restrictions on use or 'temporary use bans' need to be noted.

A temporary use ban was brought into operation in Essex at midnight on 12 June 1997 after a long period of exceptionally dry weather, which started in April 1995. By February 1997 the previous 21 months had been the driest of the 20th century with combined storage at Hanningfield and Abberton reservoirs only 55% compared to the previous year's figure of 70.3%. In addition many pipes burst as a result of the ground thawing and freezing at the beginning of the year resulting in a large increase in demand. The freezing weather also caused problems with the transfer of water into the reservoirs so that valuable recharge time was lost.

In the years 2006 and 2012 temporary restrictions on water use did occur in the majority of the water supply companies surrounding our customer supply area. Although we did not impose a temporary restriction on water use, the effect of the drought message was seen to decrease demand across our supply area as well.

Climate change

Please refer to section 5.8 for information on how climate change has been included in demand forecasts.

4.6.2 Dry Year Data Analysis

We have undertaken a project to review the dry year definitions available and also examine the relationship between weather and demand. The project also identified years of specific interest due to unusual weather and demand patterns with the peak summer period (June-September) which were examined in greater detail. This identified historic dry years in the Essex and Suffolk regions determined by the number of days above 25°C and yearly cumulative rainfall. It also determined the weighted average number of dry years which may occur in a 10 year period.

Various statistical analyses are available to apply to weather data to clearly define the weather conditions for a particular year or seasons of that year but there seems to be no universally accepted method to employ.

The decision to take into account the two variables of cumulative rainfall and number of days with maximum temperatures greater than 25°C offers a very simplistic but effective approach for the definition of a dry year.

Graphic representation of this data shows that the position of the year in a specific quadrant defines the year as either a wet, normal or dry year. Please refer to Figure 4.29 and Figure 4.30. The quadrants for the graph were drawn where the number of days greater than 25°C equalled 30, as this would loosely represent one month, and secondly that cumulative rainfall equalled 635mm, as rainfall less than 635mm would be classified by Met Office Writtle Weather Station as on the dry side of the average year in Essex and Suffolk. Thus the 'dry' quadrant would be where the number of

days greater than 25°C exceeded 30 and the cumulative rainfall was below 635mm and years placed within this quadrant would be defined as ‘dry years’.

The results from this graphic representation approach show that three years defined as dry years in Essex (1990, 1995 and 2006) and one year (1995) in Suffolk. The green lines indicate the average temperature and cumulative rainfall for the period 1987-2016. The axes indicate the split of quadrants which are named either ‘wet’, ‘normal’ or ‘dry’ according to the likely conditions experienced. As a comparison, data for the year 1976 is shown for Essex as this is a recognised year of severe drought in the UK.




Figure 4.29: The annual number of days greater than 25°C and the annual cumulative rainfall for the years 1987-2016 in the Essex region.




Figure 4.30: The annual number of days greater than 25°C and the annual cumulative rainfall for the years 1987-2016 in the Suffolk region

4.6.3 Dry Year Baseline Forecasts

The increases (from normal year to dry year) assumed for a dry year were applied to unmeasured and measured per capita consumptions, plus an increase for non-household consumption and leakage. These increases were reviewed in 2008 and it is now considered that only household demand is likely to increase in a dry year.

The household increases were based on analysis of the demands in 1995/96 and were modified for PR19 to take account of the changes to the base demands arising from metering.

The previous additional PCC has been applied to the 2006/7 populations to provide an estimate of the 1995/96 based dry year forecast for 2006/7. This methodology is still used for PR19 as there have been no further dry years since 2006/7. It is expected that as metering has increased, the current and future dry year impact on unmeasured households will have increased and the impact on measured households will have decreased. This is because the measured households are increasingly composed on meter optants, who are low users of water and selectively metered customers who will be seeking to restrain their bills. The remaining unmeasured households will have a strong element of customers who have deliberately chosen not to opt for a meter, and are high users.

The increases have been calculated as follows:

- Previous increase in measured PCC x 2006/7 measured population = 95/96 based additional dry year measured consumption for 2006/7
- Previous increase in unmeasured PCC x 2006/7 unmeasured population = 95/96 based additional dry year unmeasured consumption for 2006/7
- Sum the above to give total 95/96 based additional dry year consumption for 2006/7.
- Unmeasured population x revised PCC increase = 2006/7 rebased Dry Year unmeasured consumption
- 2006/7 rebased dry year unmeasured consumption - Total 95/96 based additional dry year consumption for 2006/7, divided by measured population gives 2006/7 rebased dry year measured consumption

The increases are as follows:

Table 4.13: Increases in PCC

	Unmeasured PCC l/h/d	Measured PC l/h/d
Essex	7.3	1.26
Suffolk	2.1	0.84

5.0 BASELINE WATER EFFICIENCY, METERING & LEAKAGE CONTROL



5.1 Water Efficiency

5.1.1 Water Efficiency Overview

Water efficiency has remained a key strand of our demand management undertakings throughout AMP6. Having initiated the first water efficiency retrofit programme in 1997, we are able to demonstrate the successful delivery of industry-leading projects, schemes and initiatives spanning over twenty years. These activities have resulted in quantifiable water savings, unrivalled customer experiences and a significant contribution to the water efficiency evidence base.

The strategy has, and continues to be, designed to create water efficiency programmes that make genuine savings in water as cost effectively as possible. A critical part of the programme is the monitoring of results to find out what the actual savings in water are and how sustainable they are, and customer surveys to gauge the effectiveness of the approach. Whilst this benefits our water efficiency planning and ultimately the high levels of demonstrable water savings achieved, it has and will continue to contribute significantly to the Industry's water efficiency evidence base, in turn aiding others in developing demand management and water efficiency strategies.

Particular achievements have been the increase in effectiveness of our water efficiency retrofit projects, the strong emphasis on the measurement of water savings (at more detailed levels than household meter readings which can easily mislead), interest in the sustainability of savings, a determined focus on the delivery of sustained behaviour change and proactive attempts to share and disseminate the results, experience and learning. We have also received recognition for our innovative and creative approach to delivering such a wide range of initiatives via a whole-town approach. Every Drop Counts is our largest ever water saving programme taking a wide-reaching and community-focused approach. It was awarded Water Resources Initiative of the Year in the 2017 Water Industry Achievement Awards and a The Green Apple Award for Environmental Best Practice in 2017.

5.1.2 Progress in AMP6 and Current Strategy

Following Ofwat's water efficiency targets in AMP5, we designed our water efficiency strategy in AMP6 based on the direction set out in Defra's Water for Life (precursor to the Water White Paper) and its Statement of Obligations for PR14, which emphasised the Government's expectation that water companies will deliver overall demand reductions via demand management measures, including water efficiency. Defra also clearly stated that it expected companies to show in their WRMP how they will reduce per capita consumption.

The Agency and Defra accepted our water efficiency proposals to annually reduce per capita consumption (PCC) by 0.26 l/h/d (equating to 0.49 Ml/d) by delivering water efficiency activities in AMP6; a target that we are on track to meet. Water savings have been achieved primarily through the delivery of household water efficiency activity, applied equally to unmeasured and measured customers. Water efficiency programmes were delivered to non-households prior to retail separation in April 2017, following which it has been deemed the responsibility of retailers.

The following section will highlight the key water efficiency activities that have been undertaken in order to deliver the water efficiency strategy in AMP6, in turn giving a background to some of the activities that will form the strategy in AMP7.

5.1.3 Every Drop Counts

Every Drop Counts is our largest ever water saving campaign, taking a truly innovative and wide-reaching approach by offering customers the chance to participate in a range of initiatives that are usually delivered at different times and places throughout the year.



EVERY DROP COUNTS

It uses a combination of targeted advertising and community-based marketing to maximise participation in the wide range of water efficiency projects to help communities not only save water, but energy and money too. Since the initial trial of the whole-town approach in 2014, we have completed 12,365 home retrofit audits and 64 business audits in four towns. The culmination of refining and improving the process annually has seen success in terms of customer participation increase each year.

Every Drop Counts offers water savings schemes, initiatives and solutions to households and schools within the targeted town. A key component of the campaign is the offer to householders of a free plumber-led home retrofit visit worth over £130. The water and energy saving visit includes the installation of a wide range of retrofit products alongside effective engagement with the householder to enact long-term behaviour change. The water efficiency retrofit project has formed a key component of our water efficiency strategy since 1997. A retrofit audit involves a plumber attending an appointment at a customer's property with a view to fitting and/or delivering a wide range of water saving products to ensure the household is water efficient. The customer is engaged in conversation and encouraged to spend time with the plumber whilst fitting the devices, to ensure that behaviour change messages are conveyed effectively.

Participating customers that have received an Every Drop Counts water efficiency retrofit visit are each saving on average 21.3 litres per day. This equates to an annual saving of 7,775 litres which in turn results in monetary savings of approximately £21 on each participating customer's water and sewerage bills. Each participating customer received a comprehensive plumber-led home water audit including water and energy saving products such as aerated or regulated showerheads, tap inserts, leaking toilet repairs, dripping tap repairs, water butts and dual-flush retrofit devices. The project to date is now saving 263,375 litres of water per day.

On an annual basis, we deliver the Every Drop Counts whole-town approach in a specific town selected for varying reasons. Each annual campaign is launched with a stakeholder engagement event in May, following which the home retrofits and school educational programmes are delivered throughout the summer. Activity concludes in

October, following which the autumn sees a period of customer research and data analysis, and throughout the winter the identification of recommendations and planning for the subsequent year.

A key component of Every Drop Counts is an overarching innovative marketing campaign. The campaign aims to generate a buzz around the community using bill boards, electronic panels, stunt marketing and newspaper/radio advertisements to raise awareness. We also worked with the environmental charity 'Groundwork' to deliver a series of customer engagement events that were tailored to provide opportunities for our customers to sign-up for a water saving retrofit in the local high street, at supermarkets, shows and festivals. By working in partnership with the community and environmental charities, we also able to engage community champions to deliver a series of customer engagement stands, utilising their understanding of the community to encourage wider participation.



5.1.4 Behaviour Change and Education

We fully understand the importance of engaging with customers to influence water using behaviour. The distribution and fitting of water saving products forms only part of the story. Influencing customer behaviour, through informing customers of how much water they use, how they use water and challenging the habitual nature in which they use water, in turn delivers quantifiable and sustainable water savings. We have understood this for many years and therefore behaviour change underpins all projects and initiatives.

Through each of our home retrofit projects, whether delivered internally, using contractors or trusted third-parties, the customer is fully engaged about their consumption, the links to energy and monetary savings and how the devices installed work. In 2015, we delivered a piece of research that aimed to establish the proportion of water savings achieved through the installation of products compared to those achieved through effective behaviour change engagement. The research was conducted in conjunction with a phase of home retrofits audits undertaken during the summer of 2015 in which 1,495 properties participated. The properties were randomly assigned to two groups; one receiving the full audit (product installation and customer engagement) and the other receiving a product-only audit (product installation but no engagement). Customers that received a full audit saved on average 24.9 l/p/d. Customers that received a product-only audit saved on

average 18 l/p/d, suggesting that behaviour change accounts for between a quarter and a third of water savings achieved through home retrofit projects.

We also recognise the importance of educating the younger generations, and in turn have implemented two highly energetic, engaging and creative programmes delivered to primary and secondary schools respectively:

- **Super Splash Heroes**

Between 2010 and 2015, we delivered an educational play and workshop named Little Green Riding Hood. Working with a local theatre company, the programme was delivered to 119,552 pupils through 619 performances in 456 schools. It was a successful project that resulted in sustained behaviour change in primary school aged children.

In 2016 Water Saving Week, we launched a refreshed programme named Super Splash Heroes. Based on the concept that the pupils themselves could become Super Splash Heroes, an educational play and workshop was created in collaboration with a national theatre company. An engaging, fast-paced and drama-based play is delivered to all pupils at participating primary schools. This is then followed by an educational workshop, led by the actors, with the aim of reinforcing the messages the pupils learnt during the play.



Super Splash Heroes visit 100 schools in our supply areas on an annual basis, engaging approximately 200 pupils at each play/workshop. The offering takes an entire morning or afternoon and leaves the pupils fully engaged about water conservation and why water is important. A full day workshop with additional activities is offered to schools within the Every Drop Counts target towns.

Alongside the primary school play and workshop, which forms the core of Super Splash Heroes, we created a picture book, smartphone/tablet based app game, trump cards, a children's kit and a social media marketing toolkit, all of which support the programme and are used at events throughout the year.



- **#WATERSAVINGSELFIE**

The #WATERSAVINGSELFIE project is a result of collaborative working with teenagers to identify a problem, create an innovative solution and then make

it a reality. The project is a ‘first of its kind’, blending water efficiency with social media. Using the platforms of Twitter, Facebook and Instagram, 1,690 students at The Gable Hall School in Corringham were encouraged to wear a t-shirt provided by us, take a creative selfie and post their picture along with a water saving hint, tip or pledge on their preferred social media site.



On 4th September 2015, the project was launched at The Gable Hall School. A tube, containing the t-shirt and a series of leaflets, was distributed to each student at an assembly and a subsequent stall held over lunchtime. With immediate effect students, adorned in their t-shirts, were posting selfies on social media, sharing water saving tips, messages, hits and pledges with their friends and family. The project will be delivered again in 2018 and then annually thereafter.

We also recognise the importance of providing advice and information to customers to ensure water is used wisely in the garden during the summer months. The Save a Bucket Load campaign was initiated in 2014 and aims to encourage customers to keep their gardens looking their best whilst using water wisely. The programme, which has evolved and adapted each year, aims to promote sustainable water use in the garden and generate long-term behaviour change. The BBC’s One Show horticulturist Christine Walkden was engaged to be the ‘face’ of the campaign. In 2016, three routes were employed to spread the message of ‘using water wisely’ in the garden. Firstly, Christine Walkden did four informative talks across our supply area to gardeners and allotment holders on the top ways to save water. The talks were located in Brentwood in Essex, Lowestoft in Suffolk, Wingrove in Newcastle and also at Howard Nurseries Ltd in Wortham in Norfolk. Howard Nurseries Ltd won the Waterwise 2016 UK Water Efficiency Awards where they received both the Farming and Horticulture Award and the Environment Agency Chairman’s award for their self-sufficient water management system. It was therefore a fantastic opportunity to be able to partner with Howard Nurseries Ltd and celebrate their achievement as a water efficient business. The talk at Howard Nurseries attracted over 100 attendees who alongside hearing great information on gardening from Christine also got to go on a tour of the nurseries. As a wholesale nursery, Howard Nurseries are almost unique in United Kingdom in offering an extensive range of field and container grown perennials, growing two million plants annually in over 1,500 varieties.

5.1.5 Water Saving Kits and Products

In 2009, we became the first water company to develop a water saving kit, aimed at providing customers with a variety of “easy-to-install” products and information about saving water in and around the home. The kit proved effective in providing customers with the tools to make their home more water efficient and also provided details about how the customers could purchase further water saving products for

elsewhere within the home. The water saving kit includes a five-minute shower timer, Save-a-Flush, in line shower regulator, twin-pack of tap inserts, universal plug and an information leaflet/questionnaire.

To date, 60,863 water saving kits have been distributed to customers, upon request, following introduction in 2009. Water Saving Kits are promoted on our website, at events and by Customer Advisors in our Call Centre.

We also offer customers the opportunity to request a selection of products for their home and garden in the form of a bespoke kit. When requesting water saving products from our website, customers have the option of requesting a 'standard' water saving kit or a 'bespoke' kit consisting of products selected from those mentioned previously and including a range of other products. The distribution of water saving kits to customers upon request has ensured that customers have enjoyed easy access to water saving products at no cost. It is believed that making such products available has made water efficiency applicable and available to a large proportion of customers.

5.1.6 Affordability and Vulnerability

Water efficiency can play an essential role in assisting vulnerable customers and those that struggle to pay their bills. We recognise this and have hence both incorporated vulnerability/affordability messages into the water efficiency retrofit visits and initiated a retrofit programme specifically targeted at customers that will benefit the most. AMP6 has seen closer ties develop between the Water Efficiency team and the Affordability and Vulnerability teams to ensure that our messaging, literature and programmes focus on both aspects in parallel. Also, as described in the 'Collaborating with Trusted Third Parties' section below, we have and will continue to collaborate with organisations such as National Energy Action and AgilityEco to tackle energy efficiency, water efficiency and fuel poverty more generally.

5.1.7 Research

We fully understand the importance of undertaking research in order to appreciate better the effectiveness of the projects we carry out and to help shape future strategies. We collect a vast amount of data whilst carrying out water efficiency projects. This data can be used to better understand a range of interests. To name a few, it is important that we better understand why customers do or do not participate in projects, the effectiveness of water saving products installed and/or delivered, the longevity of the water saving achieved, what influences the water savings achieved and how the initiatives have influenced customer behaviour. The following research projects were carried out in order to help us better understand some of the points of interest noted above. The results of all are made available to the wider industry.

- Behavioural economics

In 2014, we worked with leading professors in the field of behavioural economics to undertake research to understand how and whether financial

incentives would encourage participation. Using our home retrofit programme as a platform, our collaboration with Oxford University and the University of Chicago was split into two years. In the first year, the 15,000 customers invited to participate in Phase 9 of H2eco were split into seven groups, each offered different financial incentives. One group acted as a control, and the remaining six groups were offered different financial values, ranging from £5 - £15 for taking part, some of which were also tasked with recruiting a friend or neighbour to receive the incentive. The second stage of the research, delivered as part of Phase 11 of H2eco, was based on the programme's Recommend-a-Friend scheme. For many years, we have offered customers a £5 supermarket voucher for each friend or neighbour they recommend that then participates in the project. The research tested whether differing financial incentives, ranging from £10 for participating and recommending one friend, to £50 split by £10 per recommendee to a maximum of five. Again, the customer mailing list was split into groups, one as a control and the rest testing different financial incentives. The research provided some useful findings that have been applied to subsequent programmes. The collaboration with the two universities will also continue into AMP7.

- Home retrofit analysis

We commissioned Artesia Consulting Ltd to perform an independent in-depth statistical analysis of the datasets for Phases 1-9 of our H2eco retrofit project. The work involved compiling the raw data from the individual project databases into one large database in order to explore the complete dataset to determine how the water savings vary between phases and what factors explain the difference in water savings. A key objective of the research project was to apply a range of statistical analysis techniques to the device data (point of use measurements such as pre and post flow measurements and cistern measurements) along with the meter read data to quantify the impact each key device has on the volume saved. Among other factors, the research also explored the long term sustainability of water savings, the characteristics of a property able to have an ecoBETA fitted and the socio-demographics of participating properties against water savings. The outcomes and findings have contributed significantly to the development of our water efficiency programmes and also formed a key component to 'Water Efficiency Evidence Base; Review and Enhancement' (Environment Agency, 2012a) and the 'The Links and Benefits of Water and Energy Efficiency Joint Working' project (UKWIR, 2012b).

- Seasonal effects on measured water savings

We have routinely carried out water efficiency projects since 1997. As part of these projects, we have installed thousands of water efficiency devices and encouraged customers to embrace water saving habits through behavioural change campaigns. These initiatives are monitored through the collection of three separate meter reads; these are used to calculate overall study savings.

Through this process we have produced a measurable decrease in their customers' consumption. However, there is an understanding that the measured water saving resulting in a water efficiency project is subject, or at least influenced, by a variety of external factors. It was suspected that seasonal variations have an impact on the water savings calculated following the undertaking of a project. In order to explore whether any further value can be extracted by re-analysing the results, Artesia Consulting Ltd were employed in 2012 to analyse and report on the extent to which external factors influence demand during periods when water efficiency studies are undertaken. If external influences were found to be statistically significant a method of correctly adjusting for them was to be developed and reported upon in order that the analytical methods could be used for future studies. This study showed that, due to the nature of the project and the fact that audits are carried out over a number of months, the seasonal effect on the measured water savings was negligible.

5.1.8 Collaborating with Trusted Third Parties

We recognise the importance of delivering water efficiency in collaboration with trusted third parties. We have developed programmes that, even working alone, result in some of the highest levels of participation and engagement seen across the industry. That said, there are significant advantages to working in collaboration, whether it be to increase participation or deliver combined messaging and benefits to customers.

We are currently working with three organisations (Cenergist, AgilityEco and National Energy Action) on separate programmes that aim to deliver water saving advice and product installation in conjunction with energy saving initiatives already underway. We also have a long history of collaborating with housing associations to deliver water efficiency projects for their tenants. Based on a successful pilot with Flagship in 2011, we have since worked with Swan Housing to undertake water saving retrofits in their housing stock both through their refurbishment programme and as a distinct targeted project.

As part of the Broads Authority's draft Water Resources Management Plan (WRMP) consultation response, it confirmed that it is supportive of our water efficiency work and offered to work collaboratively on joint messaging. We welcome the Broads Authority's offer and support its proposal that water efficiency is considered through the Broadland Catchment Based Approach (CaBA) Catchment Partnership.

5.1.9 Customer-side Leakage

We have contributed to two industry-wide pieces of research which concluded that approximately 5% of toilets in the UK leak, each wasting on average 215 litres per day. Our evidence of measured savings to date indicates that the volume of wastage suggested in the industry-wide research is conservative. That aside, for us specifically this equates to approximately 37,000 properties with leaking toilets potentially wasting 7.96 Ml/d. In response to this finding, we have proactively

focused on the identification and repair of leaking toilets through its water efficiency retrofit programmes and in response to high consumption queries.

We deliver approximately 4,000 water and energy saving retrofits per year. At each of these visits, the plumber or technician will use leak dye capsules in each toilet within the home to identify any leakage from the cistern. Upon identification, a repair will be made whilst at the home if possible or at a remedial visit if specific materials are required to make a satisfactory repair. Going forward, we have identified a number of additional routes by which it will identify and repair leaking toilets.

5.1.10 Industry Sharing, Involvement and Recognition

In May 2007 we distributed the first edition of Water Efficiency News. Since then, we have produced a further nine issues. The purpose of this newsletter is to keep stakeholders and other interested organisations up to date with our work. Many projects are in progress at any one time and there is now too much material to be able to rely on others to spread the word for us. The latest issue was produced in 2017 and focused on the key water efficiency and demand forecasting projects being undertaken by us. It is hoped that Water Efficiency News will be able to be used to disseminate results and also to draw attention to key issues or aspects that have not received sufficient attention and to provoke discussion and new research ideas.

We remain actively involved in the water efficiency arena taking a lead wherever possible. We remain active contributors to the WaterUK Water Efficiency Network having chaired the network since 2005, providing the opportunity for companies to exchange ideas and experiences and to jointly meet with suppliers, regulators and others. We also actively support Waterwise (a not for profit organisation), continue to sit on and contribute to the Water Efficiency Strategy Steering Group and is also influential in scoping and seeing to fruition the development of the Collaborative Fund. Lastly, our Customer Director sits on the newly formed Leadership Group for Water Efficiency and Customer Engagement.

We have received industry recognition through receipt of numerous awards. Below is a list of awards that we have received since 2015.

- Winner of Water Resources Initiative of the Year at the 2017 Water Industry Achievement Awards for the Every Drop Counts campaign.



- Winner of Business and Industry Award at the 2016 Waterwise UK Water Efficiency Awards for the Bourne Leisure Holiday Home Retrofits programme.

- Highly Commended in Sustainability & Society Award of the UK Excellence 2017 submission and awards
- Winner of Community Engagement Campaign of the Year at the 2018 PR Moment Awards
- Winner of the Research & Evaluation Award at the 2016 Waterwise UK Water Efficiency Awards for the H₂eco Research and Analysis.
- Winner of the Innovation Award at the 2016 Waterwise UK Water Efficiency Awards for the #watersavingsselfie project.
- Gold in the Utility category at the 2017 Green Apple Awards, demonstrating environmental best practice through the Every Drop Counts programme.
- Bronze in the Built Environment and Architectural Heritage category at the 2015 Green Apple Awards for the Swan Housing retrofit programme.
- Winner of a Sustainable Water Industry Group award in 2015 for Every Drop Counts.

5.1.11 Water Efficiency Strategy for the remainder of AMP6

We will continue to deliver projects and initiatives similar to those documented in the preceding sections for the remainder of AMP6. The Every Drop Counts whole-town approach will form the core activity in 2018 and 2019, within which water efficiency programmes will be delivered on an annual basis at a similar scale to that detailed above. This community-focused approach will ensure that we are able to maximise its effectiveness in terms of participation and water savings in target areas. The home retrofit programme will continue to be offered to a minimum of 4,000 domestic properties per year, acting as a cornerstone to the strategy as a means of ensuring the existing housing stock is as water efficient as possible whilst delivering behaviour change. The Super Splash Heroes programme forms an effective means by which we are able to engage with future generations and will be delivered to a minimum of 100 schools per year. We will continue to focus on housing associations, develop stronger links with our affordability strategy and focus on identifying and repairing internal plumbing losses. The majority of the aforementioned initiatives will be underpinned by a new digital engagement platform and an enhanced marketing strategy. This will enable us to offer our water saving initiatives, including water saving products, in a more personalised and bespoke way.

The strategy will continue to be designed to create water efficiency programmes that make genuine savings in water as cost effectively as possible. The programme will continue the detailed monitoring of results to find out what the actual savings in water are and how sustainable they are, and customer surveys to gauge the effectiveness of the approach.

We will continue to actively contribute to the industry's efforts to improve the water efficiency evidence base, through chairing the WaterUK Water Efficiency Network, sitting on numerous industry-wide steering and working groups and making the results of projects and initiatives available to the industry.

5.1.12 Water Efficiency Strategy for AMP7

In AMP7, water efficiency will be more important than ever. In addition to recognising the underlying and founding principle that water efficiency is a key tool for managing demand and therefore supporting the supply/demand balance, we have considered the numerous and varying drivers for water efficiency that now exist. In response, we will deliver a water efficiency programme between 2020/21 and 2024/25 that is even greater in scale and ambition than delivered previously. We will also commit to reducing personal water consumption in the long term with a programme of activities designed to meet a goal by 2040. With more than twenty years' experience in the delivery of water efficiency programmes, we are best placed within the industry to develop a strategy that will deliver quantifiable water savings and sustained behaviour change. This section will detail the drivers that we deem important in developing the water efficiency programme for AMP7, highlighting the projects that we will deliver and the anticipated water savings resulting from such activities.

5.1.13 Drivers for Water Efficiency

In Ofwat's draft PR19 methodology (Delivering Water 2020: Consulting on our methodology for the 2019 price review, July 2017), four key themes are emphasised that will focus on benefitting customers; namely great customer service, resilience, affordable bills and innovation. It is arguable that water efficiency plays a key role in the delivery of all four outcomes. Delivering an effective, engaging and ambitious water efficiency strategy has the ability to provide unrivalled customer service, manage demand such that we are more resilient in the future, provide support to vulnerable customers who are struggling to pay and demonstrate innovation through the use of new technologies and approaches. Further to this, Ofwat has proposed a new common performance commitment based on per capita consumption. Alongside an effective metering strategy, this common performance commitment emphasises the importance of demand management in general, and more specifically water efficiency.

The Government's 25 Year Environment Plan ('A Green Future: Our 25 Year Plan to Improve the Environment', 2018), calls for water companies to take bold action to reduce water demand, both now and for the future. It states that it will work with water companies to set ambitious personal consumption targets and agree cost effective measures to meet them. It also commits to working with the industry and the Leadership Group for Water Efficiency and Customer Participation

The National Infrastructure Commission, in their 'Preparing for a Drier Future' (2018) report, highlight their central finding as being that government should ensure increased drought resilience, requiring a twin-track approach including demand management programmes to reduce PCC to 118 litres per person per day.

'Water Resources Long-Term Planning Framework (2015-2065)' (WaterUK, 2016) suggests that more action is needed to protect against the growing risk of drought. The report emphasises the role that water efficiency at a greater scale can play in mitigating some of the risks. The Blueprint for Water's Blueprint for PR19 also

emphasises the importance of using water wisely by reiterating Ofwat's suggestion that companies need to go much further on metering and leakage reduction, as well as working with customers to help them reduce consumption. Waterwise has also published a national water efficiency strategy that calls for greater ambition and collaboration in water efficiency.

5.1.14 What Customers Have Told Us

On average, our customers estimated that average consumption was half of what it actually is. This suggests that they see consumption levels as 'high'. Customers also told us that they expect us to do more to encourage water efficiency in future. This gives us clear direction to do more to encourage water efficiency and reduce consumption.

The majority of customers believe they are already doing what they can to be water efficient. Most of our customers see themselves as being responsible for their consumption, not their water company. They do not want us being 'pushy' about reducing their consumption. Some customers are even distressed by the thought of intrusive attempts to get them to change their behaviour.

We are mindful that plans to reduce consumption rely on customer participation and being too ambitious could lead to putting unwanted pressure on customers to change their behaviour.

Our position is therefore to commit to sustained gradual reductions in consumption which will enable us to put customer experience first. The reductions we are proposing will require significant investment in both existing and new approaches to incentivising water efficiency and we will be looking to innovative new approaches to deliver the long term targets we have set.

5.1.15 Our Commitment

We are able to demonstrate our commitment to encouraging our customers to use water wisely through a long history of delivering effective water efficiency strategies and programmes. The drivers (regulatory and other) detailed above add further emphasis to the importance of water efficiency for varying reasons.

In turn and in conjunction with the smart metering proposals outlined in section 5.2.12, we will commit to

- deliver a programme of water efficiency activities that will reduce PCC from 145.2 litres per person per day in 2019/20 to 136.0 by 2024/25, representing a 6.3% reduction and equating to 9.2 litres per person per day;
- and reducing PCC to 119.0 in our operating area by 2040, representing an 18% reduction.




Figure 5.1: Effect of Water Efficiency and Smart Metering on Baseline Overall PCC

5.1.16 Options Appraisal

The Water Resources Planning Guideline and the Water Resources Management Plan (WRMP) Direction 2017 requires water companies to complete an appraisal of options to ensure security of supply whilst protecting the environment at a cost acceptable to customers.

We do not have a supply deficit in any of our Water Resource Zones (WRZ). However, we are required by our regulators to reduce per capita consumption. Appendix 5 provides the demand management options appraisal. The output from it has identified the options which should be included in water efficiency strategy.

We will achieve the ambitious demand reductions stated above through a continuation of the range of activities currently delivered (detailed in sections 5.1.3 – 5.1.9) although at a far greater scale. In addition, we will install smart meters (see section 5.2.12) and deliver two further programmes that were selected through the options appraisal:

- Work with developers to require new properties to be built to the Building Regulations Part G Optional Requirement, where possible and appropriate.
- Introduce a high efficiency toilet rebate scheme.

Central to the water efficiency strategy in AMP7 will be the Every Drop Counts programme, taking a community-focused and wide-reaching approach to saving water through the delivery of all of our activities in one town at one time. The whole-town approach ensures that we are able to maximise our effectiveness in terms of participation and water savings in target areas. Home water efficiency retrofits will remain a cornerstone to the strategy as a means of ensuring the existing housing stock is as water efficient as possible whilst delivering behaviour change. The Super Splash Heroes programme forms an effective means by which we are able to engage with future generations. We will continue to focus on housing associations, develop stronger links with its affordability strategy and focus on identifying and repairing internal plumbing losses. Each of the activities discussed previously will be delivered in AMP7 at a greater scale.

5.1.17 Other Considerations for Water Efficiency in AMP7

As part of the Mayor on London's draft WRMP consultation response, the Mayor suggested that our WRMP should set out a plan for reducing non-household demand. Following the introduction of retail competition to 1.2 million business, charities and public sector organisations in 2017, it was perceived that water efficiency would act as a key benefit for such customers and an opportunity for retail water companies. As a supporter of Waterwise, we agree with their finding in 'Assessing water efficiency services offered by water retailers; March 2018' which was that there is a wide variation in the number and types of services being offered by retail water companies. We also agree with their recommendation and proposal of a Water Efficiency League Table for retailers, given the lack of water efficiency services being offered and the issues with collaboration between wholesalers and retailers. We perceive that such a league table, and the creation of retail water efficiency forum, will ensure retailers deliver more water efficiency services. We commit to working with Waterwise and the retail water efficiency forum to push this forwards.

It is important to highlight that the water efficiency scene is changing, which in turn will influence the strategy as time progresses through AMP7. There will be three key priorities for water efficiency in the coming decade.

- There will be a transition whereby the importance of behaviour change grows exponentially.
- The delivery of home retrofits will need to become more targeted towards only those homes that will truly benefit from the programme. Our research and statistical analysis tells a story suggesting a limited lifespan of the home retrofit project as the stock of existing inefficient water using appliances is replaced with those that are more efficient. We are able to demonstrate that product installation rates associated with the home retrofit programmes are declining on an annual basis, in turn diminishing the cost-effectiveness of the projects.
- The use of smart metering/technologies will be deemed beneficial to water companies and an expectation of customers.

In response, we will implement an innovative digital engagement platform that will underpin and assist in the delivery of these priorities whilst further supporting its drive to deliver unrivalled customer service. Linked to the digital engagement platform will be two additional themes. An innovative incentive scheme, building on the behavioural economics research we undertook in conjunction with Oxford University and the University of Chicago, will be implemented to intelligently incentivise customers. We will also deploy a series of smart technologies allowing more frequent and circular customer conversations around water efficiency.

5.2 Metering

5.2.1 Current Strategy

In Essex and Suffolk separate metering strategies have been run since 2003/04.

In Suffolk we have been “optant” only metering, as required by legislation since 2000. Although in Essex and Suffolk we had been offering free meter installation to some customers from 1997 as part of its demand management strategy. Optant metering is where a customer requests a meter from the company and, assuming the meter can be installed at reasonable cost, the company is required to install a meter free of charge. The customer then pays for their water and sewage on a measured basis. They also have a choice of reverting back to an unmeasured charge for two years of the meter being installed. A meter means a customer only pays for the volume of water used, which in low occupancy, high rateable value properties usually reduces their annual water bill. All unmetered customers continue to be charged according to the rateable value of their property. All new properties, and properties that have had significant alteration or installed large water using apparatus e.g. a swimming pool, are metered.

In Suffolk by the end of 2019/20 meter penetration is estimated to be 68.9% of domestic properties.

In Essex exactly the same optant, new property and high water users’ strategy has been in place. However in the early 2000s it was obvious that opting for a meter was far more popular in Suffolk than it was in Essex. The exact reason for this is unknown but the greater proportion of second homes in Suffolk, which are therefore only partially occupied, could account for it as they generally will have a low annual consumption. Historically there has also been a higher cost of water in Suffolk than Essex which may have made having a meter more financially attractive. Whatever the reason, the outcome was that the more water stressed area of Essex, compared to Suffolk, had a significantly lower meter penetration level. Looking at the declining trend in the annual number of optants in Essex, meter penetration was unlikely to increase sufficiently to support our demand management aspirations if only optant metering was available.

From 2003, initially in a pilot area, metering on change of property occupier (selective) metering was introduced. Selective metering is allowed under current

legislation where, if the occupier of a property has never received an unmeasured bill for water to that property, then the company is allowed to install a water meter and charge the customer on a measured basis. In reality this means that we can meter a property when it changes hands by either being purchased or having a new tenant.

This additional form of metering to the Essex strategy has meant that by 2019/20 64% of domestic properties will be metered. In Suffolk this figure will be 69%.

However, we now believe that selective metering in Essex has probably achieved as much as it can. Whilst we recognise that as more properties became measured the chance of a new occupier moving in to an unmeasured property decreased, after the first two years the numbers decreased markedly.

Initially selective metering in Essex started in 2005 and saw a peak of 14,235 selectively metered properties in 2006/7. However the financial crash in 2007 saw house moving plummet from 2008 onwards, with the number of selective meters falling to an average of 5,500 for the next five years. As house moves picked up we did not see the expected increase in selective meters coming through and have actually seen a steady decline in numbers from 5,300 in 2011/12 to 3100 in 2016/17 against the 6,000 forecast at PR14. These numbers are far below that forecast and far below the numbers expected if approximately 10% of properties change occupier per annum. What we have now come to understand is that even when the number of house moves returns to normal, a high proportion of the houses coming on to the market are those that have been sold within the previous 10 years. This reduces the opportunity to selectively meter dramatically as most properties have been selectively metered previously. Equally in the rented sector tenancies tend to be fairly short duration meaning most of these properties will already have been selectively metered on their first change of occupier.

However, because we want to meter above the “natural” optant rate in Essex, area metering will be introduced as described below.

Purpose of metering properties

A number of diverse reasons drive the move from an unmeasured water supply, where the occupant is charged according to the rateable value of the property, to a metered supply. All new properties are metered as the only way of charging for water and sewage services as assigning new rateable values ceased in 1989.

Customers who live in low occupancy premises with a high rateable value, tend to opt for a meter to lower their water and sewage bills. Other customers who opt perceive themselves to be low water users and again would financially benefit from paying by meter. Recent customer research shows the predominant reason for electing for a meter is financial.

Environmentally, meters are seen to be beneficial by lowering the demand for water. This uses the principle that if you pay for only what you use you are more likely to use less, thus leaving more water in the environment. In addition less energy, hence

less carbon dioxide emissions, is used to pump and treat the water and less energy is needed to pump and treat the waste water.

There is also the question of equity. As more customers become metered, although the cost of the remaining unmeasured customers increases more than the measured, profligate unmeasured users are having the cost of their water subsidised by the metered customers.

Selective metering of large domestic water users

All water companies in England and Wales have powers to meter domestic properties that are deemed large water users. This does not refer to occupancy of a property but is mainly associated with customers who want to use a garden sprinkler, or similar non-handheld watering device, or properties where potable water is used to fill a swimming pool or pond greater than 10,000 litres capacity. There are a few other uses that could be selectively metered but these tend to be internal uses of water such as certain power showers and water softeners that we would rarely have knowledge of. We inform customers that if they wish to use a garden sprinkler, or install a swimming pool or pond above the stated capacity they will need to have a meter installed. The majority are then classed as optants. If we discover an unmetered property using a sprinkler or having a swimming pool / large pond, in the first instance, we advise them of the need to have a meter. Most comply and are counted as optants. The few that do not, are selectively metered.

We believe the vast majority of its customers who are large users of water are, after over 20 years of the rules being in place, now metered.

In AMP7 we have estimated that eight customers per annum will be selectively metered because of their high use of water. Any demand savings would only come from them being more careful with their other water use and in total is negligible.

5.2.2 Customer Consultation

We operate in an area classed as Seriously Water Stressed by the Environment Agency. As such the Secretary of State can give permission for the introduction of compulsory metering in our customer supply area. However, given that none of our water resource zones are forecast to be in supply demand deficit over this period, meaning compulsory metering would not defer a new water resource scheme, we must seek our customer's approval for the introduction of compulsory metering.

Most customers' perceptions of how beneficial having a meter would be for them depend on how much lower their bills would be as a result (CCWater, 2016a). Our 2010 metering research indicates that our customers are motivated to request a meter in the hope of saving money, by the recommendation of a family member or friend, or because we told them about the benefits. Customers can be disappointed if the efficiency measures they take after having a meter fitted are not enough to reduce their bill (CC Water, 2013). Customers want information about the fitting and billing process and the financial impact, tailored to the type of tariff they are currently

on (CCWater, 2016a). A bill forecast helps customers to have realistic expectations of their new bill (CCWater, 2013).

In water stressed areas where the first large scale universal metering programmes have been undertaken, most customers regarded universal metering as a progressive necessity, an efficient way to record usage, resulting in fair billing (CCWater, 2016a). Some also have a general sense that there would be a positive impact on the environment because of the water saved, but customers could not identify what these specific benefits would be (CCWater, 2013).

5.2.3 Overall acceptability

A YouGov survey completed in 2010 showed that 63% of customers agree that metering is an acceptable way to charge for water – leaving a significant minority unconvinced (ICSconsulting, 2010). In 2017, we therefore wanted to investigate attitudes towards choice, and how customers' views changed when they were informed of the wider context of metering.

A survey of our customers in 2017 analysed the views of 257 customers who had not chosen to have a water meter, as they had moved into a home with a meter already installed. Of these, only 11% said they disliked having a water meter. Nearly half actively liked it and 38% said it did not bother them. This contrasts with the views of customers who do not yet have water meters, where almost three times more (32%) are actively against having a meter installed. This contrast suggests that customers' experience of having a water meter is usually better than (or not as bad as) they expected (Northumbrian Water Group, 2017).

5.2.4 Vulnerability and meters

While customers see metering as fair for the many, they fear it can be unfair for individual households (CCWater, 2013). They perceive that both metered and unmetered tariffs could unfairly penalise various groups in society, and do not like the concept of a tariff being used to influence their water usage (CCWater, 2013).

When informed of the financial and practical support we offer to customers in vulnerable circumstances that are relevant to metering (the Priority Services Register and tariffs like SupportPLUS and Watersure), two thirds of customers think this offers enough protection for people who might struggle to pay their bill if they were on a water meter. However one in ten (13%) felt this still wasn't enough protection for vulnerable customers (Northumbrian Water Group, 2017). Our 2016 research into customer support for a social tariff (up to a 50% discount on bills) showed that the majority of customers supported a 75p annual cross subsidy to help customers genuinely struggling to pay their water bills, which will enrich our offer for vulnerable customers (Northumbrian Water Group, 2016).

Vulnerable customers who took part in our 2017 deliberative events were positive about the support available. However, we know from our Vulnerability Research in 2016 that awareness of the extra support available is very low in our customer base,

so its support may not be reaching customers who need it most. Only 6% of customers surveyed in 2016 were aware of Watersure and additional services that are available, which reflects the average level of awareness across the industry (CCWater, 2017). Therefore, any metering programme needs to ensure that customers are informed about the extra support, should they require it.

We are committed to eliminating Water Poverty in our supply areas by 2030. Many water companies to date have looked at the issue of affordability and have generally focussed on social tariffs as being the only solution to help customers who struggle to pay their bills. Our approach is different and leads the industry to look at the causes of water poverty, not just the end problem of affordability of the bill. Social tariffs remain a significant feature of this and we involved our customers in the design and creation of tariff solutions to support those in financial need. Our customers have told us they support a cross-subsidy to expand our social tariff, enabling us to now offer up to 50% discounts for customers who are genuinely struggling to pay their water and wastewater bills. Whilst still in the first few months, we are pleased with the significant take up of this tariff – seeing an improved response from those in need as a result of a solution designed by customers for customers.

Developing an up to date Priority Services Register is a key priority, but it is also recognised by CCWater and others that customer needs change daily. We have therefore begun training our staff to actively support those who may experience challenges to sign up to our Priority Register directly and empower our staff who see vulnerability to act by signing those customers up to the list – as well as training them to be responsive to issues that appear when an issue that requires extra support arises – making sure the list is as up-to-date as possible at all times.

5.2.5 Reversion

Very few customers in the 2017 research were aware that they can revert to an unmeasured tariff within two years of having a water meter installed. This is consistent with CCWater's finding that only 28% of unmetered customers are aware of the trial period (CCWater, 2016b). Low awareness may partially explain why so few customers revert to unmeasured tariffs (only 1-2% of optants). However, our reversion rates do also indicate that most optants are happy with their measured tariff.

The majority of customers were pleasantly surprised by and supportive of the idea of the government's reversion policy. In the 2017 deliberative research, it was observed that those who were initially completely against metering noticeably softened towards the idea of going on a meter when told about the right to revert to an unmeasured tariff. However, in our survey it was possible to observe that fewer of those who inherited water meters (55%) supported reversion than optants (67%) or unmetered customers (73%). Some customers in the deliberative events suggested that the option to revert to unmeasured billing should be extended to customers who had not chosen to have water meters (Northumbrian Water Group, 2017).

Customers often want to revert because they are disappointed by increased bills or find that other household members do not cooperate with the water efficiency measures they introduce (CCWater, 2013). Indeed, customers suggested we remind them of this right before the 24 month reversion period comes to an end (Northumbrian Water Group, 2017).

5.2.6 Meter location

We know that customers in England and Wales prefer being able to access their own meter to read it, and some cannot (CCWater, 2013). We also know from research into the experience of having a meter fitted that the main issue causing customers to drop out of the process was the location of an internal meter (Northumbrian Water Group, 2010).

In a survey of our customers in 2017, meter location preferences were as follows:

Table 5.1: Meter location preferences

Location	Current location	Preferred Overall	Preferred by Metered	Preferred by Unmetered
Outside their home in the pavement (or road if there is no pavement)	34%	26%	33%	17%
Outside their home in the ground (in the garden or driveway)	25%	30%	34%	24%
Inside their homes (e.g. under the kitchen sink)	21%	15%	12%	19%
Outside their home on the wall (in a box)	15%	19%	17%	23%
Don't know	5%	9%	4%	17%

76% of our customers preferred external options, with only 15% opting for an internal meter and 9% not knowing. Those already on meters were most likely to stick with their current option when asked their preference. However, those with internal meters were more likely to prefer external locations and only half would choose to have them there again, which suggests that their experience of having an internal meter has not been good (Northumbrian Water Group, 2017).

Of the external options, customers were equally likely to choose a meter in the public highway as to choose to have it on their land (a third each). Not as many would choose to have one on their external wall. In view of the costs and delays associated with installations in the public highway we tested the acceptability of offering customers incentive payments for installations on customers' land. More than half (53%) of our customers agreed with this in the survey, with a further quarter (23%) neither agreeing nor disagreeing. Agreement was dependent on the amount of

incentive that would be offered. Customers were less supportive of charging the additional cost of highway installations, with 42% disagreeing and 32% agreeing this would be a good idea.

Interestingly, many customers expressed that they would not expect to be given a choice and would expect to simply be told where the meter was going (Northumbrian Water Group, 2017).

5.2.7 Reading and billing

Customers' preferences for how often they would want to read their own meters, ranged from monthly to yearly in the 2017 research. For most, this was an issue of managing their outgoings and customers are much better equipped to manage their finances if readings are required and bills are issued more frequently. Some also said leaks could be better detected through more frequent billing. Many customers prefer submitting meter readings online, with some already accustomed to not having to submit readings at all due to having a smart (energy) meter.

5.2.8 Meter capability desired

Awareness of smart meters was high across all customers reached in 2017 and about a quarter already had a smart energy meter. Appetite for smart water meters was high and about 60% of our customers surveyed were in favour of getting one. A further fifth were neutral about it. Older customers were most likely to be against getting smart meters which could be due to a distrust of technology (Northumbrian Water Group, 2017). However, most (two thirds) said they would not be willing to see bills rise at all to cover the cost of rolling out smart water meters.

The level of interest found among customers was higher than national research has shown. Customers are more likely to be supportive (31%) than oppose (15%) the roll out of smart meters, but most have no opinion about it. Only around half of UK metered customers were satisfied with the appointment and the fitting processes, suggesting that these are important things to get right or there is a risk of an impact on overall satisfaction scores (DECC, 2014).

5.2.9 Impact of meters on consumption

Surveys attempting to measure the savings achieved through metering scientifically have shown various levels being achieved. According to some customer research, the majority of customers with meters take action to reduce consumption, but for many this predates the meter being installed (CCWater, 2013). Most water customers in England and Wales believe that they do not change their behaviour drastically when they have a meter installed. Optants are slightly more inclined to make modifications to their behaviour than non-optants (CCWater, 2013). Most of our customers said they want to reduce their usage but don't want to change their lifestyle. It was also noted that some vulnerable customers simply can't reduce their usage, even if they wanted to (Northumbrian Water Group, 2017).

Some customers who are not metered are reducing their water consumption anyway. Two thirds of customers in England and Wales have made a conscious decision in the last three years to reduce their water consumption while only half are metered. This was an increase of 7% in one year while meter penetration increased by just 2% (CCWater, 2016a). A recent global survey also found that 72% of citizens surveyed say they would change their water consumption if they were given better information about their usage (ECU, 2015).

5.2.10 Limitations of metering for reducing consumption

Customers who were motivated by financial or environmental reasons to get a meter, initially made efforts to save water, but they failed to maintain this behaviour if their expected financial savings did not materialise (CCWater, 2016a). The receipt of a new bill renews interest in saving water for a while (CCWater, 2013) but our customers are only guaranteed to receive a bill based on a reading once a year.

The average customer underestimates their consumption by 50%. Metered customers' estimates of consumption were not much better than unmetered customers showing that a meter by itself will not necessarily make a customer more conscious of how much water they use. Only bill payers are financially motivated to save water and can express frustration with family / household members who do not (Northumbrian Water Group, 2017).

In 2017, customers told us that their strongest motivators to saving water would be saving money and water shortages, although there was significant scepticism about the need to save water in both NWG regions. Across our deliberative workshops in 2017, there was so little support for stepped or seasonal tariffs to increase the financial incentive that the subject was dropped from the survey (Northumbrian Water Group, 2017). Willingness to reduce consumption falls when customers are aware of the amount of water lost through leakage or if they experience a burst.

5.2.11 Attitudes to compulsory metering

In our 2017 research, the freedom to choose whether or not to go on a water meter was considered an important 'right' by the majority of customers, before they were informed of the wider context of water metering. Nearly two-thirds (63%) of our customers agreed that people should be able to choose whether or not to have a water meter, whilst 38% agreed that we should make it compulsory for all households to have a water meter. However, as more information about the benefits and safeguards for metering was provided, many customers' attitudes changed and the proportions of customers supportive of compulsory metering increased by 15%, as shown in the table 5.2 below.

Table 5.2: Attitudes to compulsory metering

	Unmetered customers	Metered customers	Combined metered and unmetered
Uninformed customers (at beginning of research)	22%	49%	38%
Informed customers (at end of research)	37% (+15%)	63% (+14%)	53% (+15%)

(Northumbrian Water Group, 2017)

The survey from which these figures are taken was only conducted with customers in our Essex and Suffolk supply areas because the operating area is designated 'seriously water stressed' and could qualify for compulsory metering. Although a small majority of informed customers were supportive of compulsory metering overall, we do not consider that this justifies a programme of compulsory metering in view of the majority of unmetered customers being opposed to it, especially when uninformed.

At the end of our 2017 online survey, our customers allocated £10 across five potential water resource management investment options, in order to understand participants' perceived priorities. Increasing supplies and reducing leakage were seen as priorities over metering options, but metering had much more support than it did at the outset of the research. The option for compulsory metering was invested in just as much as simply providing information to customers on optional metering.

Table 5.3: Customer investment priorities (Northumbrian Water Group, 2017)

Option	Total amount 'invested' by all respondents (£)
Build more reservoirs, treatment works and pipes	802
Reduce leaks	795
Reduce water usage and inform customers about optional meters	237
Reduce consumption with compulsory water meters at all customers' homes	232
Install water meters whenever someone moves house	209

We were able to calculate from this exercise that 53% of customers put some money against compulsory metering (63% of metered and 37% of unmetered customers).

From this customer information we deduce that the introduction of compulsory metering in to the Essex & Suffolk area is not supported by customers. This information was given to the CCWater committee and Water Forum (Customer Challenge Group) who agreed we had no customer mandate for the introduction of compulsory metering.

Their views also support our move away from selective metering on change of occupier in Essex to Area Metering.

5.2.12 Changes to Draft WRMP metering strategy for 2020 – 2025

Essex

In Essex we will continue with the current strategy of optant metering but will no longer continue with selective metering on change of occupier of a domestic property. Instead we are going to introduce Area Metering which we predict should add a further 5,000 meter optants per annum to the forecast number of “natural” optants that are expected.

Area Metering is the name given to a new programme of installing meters in to existing empty meter chambers, the customers will remain unmeasured but over a two year period will be sent a “water bill” showing what they would have paid had they opted for a meter.

As a result of our mains renewal programmes over the last 30 years, including a significant replacement of mains during the 1990s for quality reasons (Section 19 Quality Programme), there are a large number of empty meter chambers. This has arisen because when water mains are renewed we have also taken the opportunity to renew the communication pipe (the pipe between the main and the customer’s curtilage) and install a meter chamber. We estimate that there are currently approximately 70,000 empty chambers and will continue to add to this number as mains are renewed.

Our proposal is to drop meters in to these chambers, at the rate of 10,000 per annum, and inform the customer that whilst they remain an unmeasured customer we will send them “dummy bills” over a two year period showing what their water bill would be if they were metered. From customer research we forecast that over the two year period 5,000 of these customers will opt to go on to a measured bill. Some very early on and others when they see that financial savings are sustainable and not a single aberration. Once they opt for a meter they have a further two years in which to revert, potentially giving customers up to four years of measured bills before they become permanently metered. Equally any change of occupier to these properties, at any time, will automatically become metered. Even for those properties that chose not to become measured, or changed ownership, we believe knowing that the property has a meter will have a ‘Hawthorn’ effect on their use, certainly reducing wasteful use.

Moving to this area metering at the start of AMP7 (April 2020) would mean far less than 5,000 new optants from Area Metering in the first year of installing the 10,000 meters pa, as we expect the 5,000 optants over the two years. Therefore we propose to begin the 10,000 meters per annum from April 2018, meaning that by the first year of AMP7 the first 10,000 customers will be at their two years of “dummy” bills and a further 10,000 reaching one year of “dummy” bills. We intend stopping

selective metering (except on high users) at end of March 2018 as the number of optants from Area Metering in the last two years of this AMP is likely to exceed the number of new measured properties from continuing with selective metering.

With our planned level of mains renewal for the remainder of AMP7 and during AMP7, it is forecast there will be sufficient empty meter chambers to continue Area Metering through AMP8.

Table 5.4: Number of optants and area metering optants for AMP 7

	2020/21	2021/22	2022/23	2023/24	2024/25
Optants	4,000	3,750	3,500	3,250	3,000
Area Metering Optants	5,000	5,000	5,000	5,000	5,000
Totals	9,000	8,750	8,500	8,250	8,000

Following the above figures used in the draft plan we have taken account of the customer research that showed there was still a significant number of customers who remained unaware that they could request a meter free of charge. Although it is advertised on our website and within billing literature it was not being seen as widely as possible. Our customers thought that we should advertise free meters more widely. In addition our ambition to remove all customers from water poverty, detailed within our Business Plan, where metering will play a part in this. As such there is likely to be an increase in the number of meter optants over AMP 7. To cater for this we have increased the number of optants each year by 25%.

This gives the following revised number of optant meters

Table 5.5: Revised number of optants and area metering optants for AMP 7

	2020/21	2021/22	2022/23	2023/24	2024/25
Optants	5,000	4,688	4,375	4,062	3,750
Area Metering Optants	5,000	5,000	5,000	5,000	5,000
Totals	10,000	9,688	9,375	9,062	8,750

At the end of each AMP the Essex meter penetration is forecast to be as below:

Table 5.6: Essex meter penetration forecast

AMP6	AMP7	AMP8	AMP9	AMP10	AMP11
63.99%	72.56%	78.74%	81.24%	82.98%	84.59%

Water saved by optant metering

From studies we have calculated that households that opt for a meter tend to be lower users of water than the average unmeasured. Their average use before being metered is 88% of the average unmeasured PCC and then a meter causes a further 5% reduction in use.

Therefore, using 2016/17 baseline figures the following water savings for optant metering have been calculated.

Table 5.7: Water savings for optant metering in Essex

Water savings for optant metering	
Average unmeasured PCC (l/h/d)	161.12
Average pre-switching consumption (l/h/d) (88% of unmeasured PCC)	141.78
5% further saving (l/h/d)	7.09
Average occupancy over AMP7	1.91
Total number of AMP7 meter optants	46,875
AMP7 Water Savings (MI/d) (occupancy x meters x saving)	0.635

This assumes the daily consumptions and occupancies remain constant over the AMP7 period which for ease of calculation is a reasonable estimation.

AMP7 Costs

The cost of installing a meter varies according to where on the property we can fit the meter. There are four possible locations with five different costs. All proposed meters will be AMR with Walk by / Drive by reading capability. Our intention is to always install a meter in the cheapest practical location. These locations are:

- Drop in (to an empty existing meter chamber)
- Internal
- External private (new chamber installation in customers ground)
- External public (new chamber installation in public footpath /road)

The total costs for optant metering using the 2016/17 prices are as follows.

Table 5.8: AMP7 total costs for optant metering in Essex

	Price per installation	Target %age split between meter installation location	Total number of meters	Cost (£m's)
Whole Area Metering				
Drop In (by area)	£75.89	(100% external)	50,000	£3.795
Optants				
Drop In (Single Optant)	£129.88	36.4%	7963	£1.034
Wall box	£265.81	40%	8750	£2.326
Internal	£198.90	11.8%	2581	£0.513
External private	£561.62	11.8%	2581	£1.450
Total AMP7 capex (£m's)				£9.118

Suffolk

In Suffolk we will continue with the current strategy of optant metering. With approximately 69.24% of properties being metered by 2020, the number of new optants coming forward will decline to a lower level than experienced in AMP6. The number of meters forecast to be installed in each of the 5 years is:

Table 5.9: Number of optants for AMP7

	2020/21	2021/22	2022/23	2023/24	2024/25
Optants	675	650	600	550	500

Changes from the draft WRMP

Following the above figures used in the draft plan we have taken account of the customer research that showed there was still a significant number of customers who remained unaware that they could request a meter free of charge. Although it is advertised on our website and within billing literature it was not being seen as widely as possible. Our customers thought that we should advertise free meters more widely. In addition our ambition to remove all customers from water poverty, detailed within our Business Plan, metering will play a part in this. As such there is likely to be an increase in the number of meter optants over AMP 7. To cater for this we have increased the number of optants each year by 25%.

This gives the following revised number of optant meters

Table 5.10: Revised number of optants for AMP7

	2020/21	2021/22	2022/23	2023/24	2024/25
Optants	844	812	750	688	625

At the end of each AMP the Suffolk meter penetration is forecast to be as below:

Table 5.11: Suffolk forecasted meter penetration

AMP6	AMP7	AMP8	AMP9	AMP10	AMP11
69.00%	73.34%	75.60%	76.66%	77.60%	78.45%

Savings in water use from metering

From studies we have calculated that households that opt for a meter tend to be lower users of water than the average unmeasured. Their average use before being metered is 88% of the average unmeasured and then a meter causes a further 4% reduction in use.

Therefore, using 2016/17 baseline figures the following water savings for optant metering have been calculated.

Table 5.12: Water savings for optant metering in Suffolk

Water savings for optant metering	
Average unmeasured PCC (l/h/d)	147.91
Average pre-switching consumption (l/h/d) (88% of unmeasured pcc)	130.16
4% further saving (l/h/d)	5.21
Average occupancy over AMP7	1.83
Total number of AMP7 meter optants	3,719
AMP7 Water Savings (Ml/d) (occupancy x meters x saving)	0.035

This assumes the daily consumptions and occupancies remain constant over the AMP7 period which for ease of calculation is a reasonable estimation.

AMP7 Costs

The cost of installing a meter varies according to where on the property we can fit the meter. There are four possible locations with four different costs. All meters will be AMR with Walk by / Drive by meter reading capability. Our new location policy will enable us to make significant efficiencies in metering and has been developed through consideration of a number of key factors including cost, customer impact, suitability for smart metering, and calculating/identifying PCC and leakage. The order of preference is:

1. Drop in
2. Wall box
3. Internal
4. External private

We will no longer carry out installations in the public highway as this is becoming extremely costly and causes delays to the installation process – reducing customer satisfaction with the service.

The total costs for optant metering using the 2016/17 prices are as follows.

Table 5.13: AMP7 total costs for optant metering in Suffolk

	Price per installation	Target %age split between meter installation location	Total number of meters	Cost
Drop In	£143.68	26.1%	971	£0.139
Wall box	£277.54	40%	1488	£0.413
Internal	£210.63	16.95%	630	£0.133
External private	£498.74	16.95%	630	£0.314
Total AMP7 capex (£m's)				£0.999

Compulsory Metering

All Water Resource Zones (WRZs) in our customer supply area are within areas classed as seriously water stressed by the Environment Agency. As such, with customer and Secretary of State support, we could compulsory meter the whole area. Our customer research clearly shows this is not supported, and has therefore not been proposed, but we have examined this as an option.

All WRZs have been considered as a single area for the purpose of producing this option using the following assumptions which are considered suitable for this purpose:

- Universal metering in our customer supply area has been assumed to be 87% of all domestic properties being metered by 2024/25
- From the starting point of 2020/21 this equates to 129,849 properties to be metered by 2024/25
- The programme will be completed over the 5 years of AMP7 with 26,000 properties being compulsorily metered per annum
- All meters will be installed externally in the highway either by dropping in to an existing empty meter chamber or installing a new external meter chamber
- The cost of drop in and installation has been chosen as the lower Essex cost for 2016/17
- Water saved per compulsory meter has been assumed to be our previous 8%
- Compulsory metering with Smart meters is an additional £25 per meter and an additional 3% saving in water

- The averaged Essex and Suffolk unmeasured PCC for 2020/21 of 155.82l/h/d has been used to calculate the AMP7 water saving.

Therefore, using 2020/21 forecasted figures the following water savings and costs for compulsory metering have been calculated.

Table 5.14: AMP7 water savings for compulsory metering in ESW

Water savings for compulsory metering	
Assumed percentage reduction in water use (dumb meter)	8%
Assumed percentage reduction in water use (smart meter)	11%
Average unmeasured PCC (l/h/d)	155.82
Average compulsory saving (dumb) (l/h/d)	12.47
Average compulsory saving (smart) (l/h/d)	17.14
Average unmeasured occupancy over AMP7	2.55
Total number of AMP7 compulsory meters	129,849
AMP7 Water Savings (MI/d) (dumb)	4.123
AMP7 Water Savings (MI/d) (smart)	5.669

Table 5.15: AMP7 total costs for compulsory metering in ESW

	Price per installation	%age split between meter installation location	Total number of meters	Cost (£m's)
Drop In (dumb)	£50.89	25%	32,462	£1.65
Drop In (smart)	£75.89	25%	32,462	£2.46
External public (dumb)	£438.79	75%	97,387	£42.73
External public (smart)	£463.79	75%	97,387	£45.17
Total AMP7 cost (dumb) (£m's)				£44.38
Total AMP7 cost (smart) (£m's)				£47.63
Cost per MI water saved (dumb) (£m's)				£10.77
Cost per MI water saved (smart) (£m's)				£8.40

Assessment of Impact of Compulsory Metering on Customers

In order to numerically assess the impact of compulsory metering on customers' bills we looked at the impact that switching to a meter has had on bills historically. We have looked at this in two ways by using historical billing data and evidence from customer research.

Billing data

It would not be appropriate to look at the impact switching to a meter has had on optants' bills because customers who voluntarily switch to a meter will usually see a financial benefit. Those who would be metered under compulsory metering would include a much larger proportion of customers who would not benefit financially. The change of occupier metering programme in Essex gives the best available indication of the impact compulsory metering would have on individual household bills. The most reliable 'before and after' billing data we have for a full year's change of occupier installations is for 2015/16. Data from the following years has been affected by the introduction of our new billing system in 2017/18 and also our decision to stop the change of occupier metering programme at the end of the same year.

We installed 4772 meters under the change of occupier programme in Essex in 2015/16. For the purpose of analysis we have taken the average rateable value and removed results outside of one standard deviation to reduce the sample size to just under 3000 properties. After taking account of leak allowances, our findings are that:

- 20.4% of households (605 properties) saw their bills increase.
 - 72 households' bills more than doubled – which is about 2.5% of the sample.
- 12.7% of households (377 properties) did not see a significant change (i.e. their measured bill was 91% to 109% of their unmeasured bill).
- 66.7% of households (1970 properties) saw their bills decrease.
 - Some of these households will have gained financially from being on a meter simply because the property was not occupied throughout the full year. There are some clear examples where households paid almost nothing above the fixed rate and so although classed as 'occupied' the homes were in fact largely vacant. It is difficult to establish what proportion of properties this applies to but based on the amount households were billed in terms of the volumetric charge for actual usage over a year this could be true of 15-20% of these properties.

Overall, this evidence suggests that at best two thirds of customers may benefit financially from switching to a meter. However, we have to account for the significant proportion of households which used very little water throughout the first year of being on a meter. It is likely that this is related to rental properties being frequent candidates for the change of occupier metering programme. It would not be uncommon for rental properties to have a period of vacancy between occupants which would of course reduce the annual bill. If we exclude 12.6% properties with very low consumption from the group of those who gained from switching to a meter this reduces the proportion of customers who benefitted to 54.1%.


Evidence from customer research

Our customer research from our *Metering & WRMP research* in 2017 supports and sheds further light on these numbers. We carried out a survey as part of this research which included 443 ESW customers who are on a meter. A minority (40%) of the metered participants had switched to a meter by their choice; the remainder inherited a meter or had one installed when they moved in to their home. We asked these customers whether they thought their bill had increased, decreased or stayed about the same since changing to a measured bill. The results are consistent with our historic billing analysis for change of occupier meters in that 19% of customers felt their bill had increased. However, only 46% of customers thought their bill had reduced. 24% thought their bill was about the same and the remaining 11% were unsure.

We note from our research that there is a clear divide in the way customers from different age groups are affected by switching to a meter. Older customers are much more likely to save financially by switching to a meter than younger people – who are actually slightly more likely to see an increase to their bill than a decrease. This reflects the tendency for customers with families to be adversely impacted by switching to a meter. It could also be a reflection on generational differences in behaviour around water usage. If this is the case, the number of customers benefitting from switching to a meter could reduce in future.

Perception of metered bills

(Total Base: All Respondents on a water meter (443))



Q06) Do you think your water bills are higher, lower or about the same as they would be if your home wasn't on a water meter?

↑ = sig diff than at least 2 other age bands

Likely impact of compulsory metering on bills

We conclude from these two sources of evidence that it is likely that around half of customers would benefit financially from switching to measured charges under a compulsory metering programme. For up to half of customers, compulsory metering would not benefit them financially and for about 20% there would actually be a noticeable increase to their bill.

How we would manage the impact of compulsory metering on bills

If we were to be required to universally meter our customers on a compulsory basis we would build on the experiences of other water companies who have delivered such programmes and work with CCWater to ensure the experience for our customers was as positive as possible.

This would include giving customers a transition period of two years following meter installation before moving the household on to a measured bill. Where customers' measured bills worked out lower or about the same we would automatically switch customers to measured charges. We would also make the customer aware that they still had the option to remain on unmeasured charges for two years if they chose to take advantage of the transition period for reasons we might not have foreseen. Where we identified that customers would see an increase to their bill we would encourage and support them to use their two year transition period to reduce their consumption and ensure their bill is affordable for them.

Our particular concern would be for those customers who are already struggling with financial hardship or whose circumstances make them vulnerable. We would aim to use the programme to help towards identifying customers who need additional support and could benefit from the services we can offer. For example, we may identify customers who would qualify for the WaterSure tariff or be able to recommend another of our new tariffs designed to help people out of water poverty.

5.2.13 Long Term Metering Plan

The costs of our metering programme for Essex and Suffolk through the full planning period are summarised below in 2017/18 prices. The capex costs are for meter installations only and do not include the cost of meter replacement. The opex costs are cumulative and reflect the escalating opex costs associated with all the meter installations made from 2020 onwards.

Table 16: Essex meter installations costs to 2045

	AMP7	AMP8	AMP9	AMP10	AMP11
Installation numbers	67,500	36,500	10,000	7500	7500
Capex £'m	£10.066	£10.877	£3.014	£2.423	£2.423
Opex £'m (cumulative)	£0.297	£0.603	£0.860	£0.969	£1.064
TOTEX £'m	£10.364	£11.480	£3.875	£3.392	£3.487

Table 17: Suffolk meter installation costs to 2045

	AMP7	AMP8	AMP9	AMP10	AMP11
Installation numbers	2975	1450	250	250	250
Capex £'m	£1.344	£0.428	£0.074	£0.075	£0.075
Opex £'m (cumulative)	£0.035	£0.051	£0.060	£0.064	£0.069
TOTEX £'m	£1.379	£0.479	£0.135	£0.140	£0.144

Note: Our capex costs in Essex increase from AMP7 to AMP8 despite the fact that the number of installations we make will significantly reduce. The reason for this is that we are taking the opportunity to boost our meter penetration in AMP7 by filling empty boundary boxes in whole areas at very low cost. The knock on effect will be that the number of drop in installations we make for optants in subsequent years will be significantly reduced, increasing our costs overall.

Smart Metering

Our PR19 plan includes a proposal to install smart meters with every new meter installation from April 2020. The long term strategy is to reach a position where all our meter stock is smart by 2035, which means that replacement meters from 2020 will also be upgraded to a smart meter. The primary purpose of the smart metering strategy is to improve customer service. Smart meters will enable us to introduce a greater selection of tariffs and enable quicker resolution of issues like customer side leaks. Our customers also want better visibility of their usage so that they can save water and save money. From the small amount of data available from the industry on the benefits of smart meters, we are assuming an additional 3% water saving on top

of that gained from a dumb meter installation. Further details will be provided in the WRMP Annual Updates as the programme evolves.

5.3 Leakage Forecast

5.3.1 Background

Water companies have been working together, co-ordinated by Water UK, to improve the consistency of reporting of definitions of key measures of performance, so that performance can be compared between companies more easily. This work is supported by Ofwat, the Environment Agency, Natural Resources Wales and the Consumer Council for Water.

Companies need to make changes to their current reporting to align with the new, more consistent, reporting definitions, and for some of these changes it will take some time to have robust data. One of the measures of performance this applies to is leakage. Each company's draft WRMP explains how the company is implementing the new reporting definition for leakage and the extent to which it might impact on their future plans for balancing supply and demand for water. The change in reporting of leakage is purely a change in reporting; it does not affect the actual amount of water lost through leakage.

Each company will be making different changes to their current reporting to come into line with the more consistent definition, and so the impact will be different for each company. For us, the changes and their potential impact are explored below.

5.3.2 Summary of Approach

In the course of preparing the WRMP, we have considered the outputs of the report on Consistency of Reporting Performance Measures (UKWIR, 2017). Some of the elements have been readily implemented but others require detailed studies or significant investments which are likely to take two to three years to complete. The impact of each of these elements has been assessed and an overall range of outputs derived.

The Sustainable Level of Leakage (SELL) model used for PR14 has been updated with new company-specific input data. The minimum achieved leakage levels (MAL) within District Metered Areas (DMAs) have been referenced to the range of industry "Frontier" values.

The 2016/17 base year has been derived and a number of scenarios forecast to reflect the potential range of impacts from the consistency projects. For each of these starting values, future profiles of leakage levels have been projected forward to 2045.

5.3.3 Adoption of Consistency of Reporting Measures

The 2017 UK Water Industry Research (UKWIR) report contains a compliance checklist containing sixteen components. The checklist requires each element to be assessed using a Red / Amber / Green scale and any reasons for non-compliance to be documented.

We have further divided this checklist into sub-criteria and assessed each element individually. The output of this work identifies a number of enhancements to the current reporting methods which are categorised into two main areas:

- a) Changes to the calculation method
- b) Improvements to the data quality.

Work is under way to ensure that we are fully compliant with all aspects by the commencement of the AMP7 period.

Changes in Calculation Method

The calculation changes have been incorporated within the corporate leakage analysis software (Netbase). A second database has been constructed adopting these changes to enable the effects to be monitored alongside the existing reported values.

The key changes are:

- a) Weekly leakage values calculated from a seven-day mean rather than median value.
- b) The minimum night flow period is calculated from a fixed hour rather than a minimum rolling one hour period.
- c) Individual daily leakage values are allowed to be lower than zero rather than fixed at zero.

The effect of these improvements is, therefore, fully accounted for in our “bottom-up” pre-MLE value of leakage.

Improvements in Data Quality

The improvements in data quality require significant investment in terms of time and money and it is not possible to predict the effect of these accurately.

The key requirements are:

- a) Implementation of Fast Logging Technology – The report identifies a requirement to calculate leakage values from all 52 weekly values. In areas where seasonal demands are encountered, fast logging techniques will be used to derive dynamic household night use values.

- b) Large Metered Customer Logging – All customers with a daily consumption of a minimum of 24 – 48 m³/hour will be continuously logged using telemetry loggers.
- c) Study of Plumbing Losses – A company specific study will be undertaken to understand the magnitude of customer plumbing losses. These company values will replace the generic industry values currently used.
- d) District Metered Area (DMA) Coverage – Additional DMA's will be created to ensure that a minimum of 95% of properties are within reporting areas.
- e) Non-Household Seasonal usage – A study will be undertaken to identify customers with significant seasonal usage patterns. A sub-set of these customers will be permanently logged and the seasonal profiles defined will be applied to other customers with a similar demand type.
- f) Night Flow Interpolation of Missing Data – The report identifies a requirement to treat missing and corrupted data differently. This requires a change to the analysis routines within Netbase and will be incorporated in the next software release.

These data improvements will be delivered within a three year period and, as each individual element is delivered, the effect on leakage will be incorporated into the second Netbase database. This will ensure that the effects of all changes are fully understood and incorporated prior to the AMP7 reporting period.

5.3.4 SELL Review

Overview of SELL Model

In 2007 we introduced a new SELL model to replace the earlier LIMES model. The model is based on the natural rates of rise of leakage, with the economics of active leakage control being optimised at DMA level. It was conceived and designed in 2007 by in-house experts but has been completely rebuilt for the PR19 submission. It is fully compliant with the recommendations of the Tripartite Report of 2003, and therefore conforms to best practice.

We have also complied with most of the recommendations of the Strategic Management Consultants (SMC) report “Review of the calculation of sustainable economic level of leakage and its integration with water resource management planning” commissioned by Defra, Environment Agency and Ofwat (2012). Specific actions we have taken include:

- We have considered all operational leakage options to reduce leakage. We have also included a stand-alone optimisation of pressure management. However we have not considered other capital options such as mains renewal as we have not constructed a least cost plan for any of our resource zones, as none are expected to be in deficit within the planning period.
- We have included the environmental, social and carbon costs of leakage and leakage management, using company or catchment-specific values where appropriate.

- The study on “Factors Affecting Minimum Achieved Leakage Levels” (UKWIR, 2016d) found that it is not currently possible to forecast minimum achievable leakage levels. However we have used the methods presented in this report to calibrate our minimum achieved levels against those of other UK companies to demonstrate that they are appropriate for a company with relatively low leakage.
- We have not considered the economics of operating slightly above or below the SELL, as our proposed performance commitments for leakage are substantially below the SELL.
- In the derivation of our leakage cost curves, we have assumed that we will achieve substantial future improvements in the efficiency of our active leakage control processes.
- We are actively investigating and trialling opportunities to reduce leakage by the use of innovative techniques.
- Since 2010 we have routinely carried out leakage assessments at sub-DMA level prior to implementing leakage-driven mains renewal schemes, and as a result have achieved efficiencies in our renewal programme by renewing parts of DMAs where appropriate.

The SELLS are calculated at DMA level, and these are then simply summed to give the overall Economic Level of Leakage (ELL) at company level. The model is applicable to a system in steady state.

A water undertaker has a choice of two operational options in response to increasing levels of leakage:

- i. Increase the volume of water put into supply
- ii. Increase the level of effort on active leakage control (ALC).

Figure 5.2 illustrates the trade-off between the two options. Increasing the volume of water put into supply results in increased production costs (i.e. cost of water), which follows a linear relationship. The cost of increasing effort on active leakage control (ALC) is non-linear and shows diminishing returns. The total cost curve is the sum of the marginal supply cost curve (the cost of water lost) and the manpower cost curve (the manpower costs incurred in undertaking ALC). It is at a minimum when the gradients of the two component curves are equal and opposite.




Figure 5.2: Leakage cost curves behaviour of leakage in a DMA




Figure 5.3: Hypothetical profile of leakage in a DMA

At time zero on Figure 5.3, an intensive leak detection and repair campaign has just been completed, and leakage has been reduced to the background level. Thereafter leakage rises at a gradient equal to the natural rate of rise. Eventually another leakage reduction campaign is undertaken, and leakage is again brought down to the background level. The shaded triangle represents the volume of water lost above the background level between interventions, i.e. water lost due to unreported burst leakage. It can be shown that the total cost to the company is a minimum when the value of the water lost between interventions is equal to the cost of the

intervention. The intervention frequency will then be the economically optimum intervention frequency.

The average leakage level in the medium or long term is at half the height of the triangle as shown, and this is the economic level of leakage for the DMA. The ELL for the company is then calculated by summing the ELLs for the DMAs.

The output of this calculation process is the short-run SELL, which represents the optimum balance between the manpower costs of active leakage control and the marginal operational costs of water (power and chemicals). For zones which are in supply-demand deficit at some time within the planning horizon, additional leakage control options must be considered, along with other demand management options and possible new resource schemes. However none of the resource zones in our customer supply area are expected to be in deficit within the planning horizon.

In keeping with the 2012 SMC report, a separate economic optimisation of pressure management is carried out as a stand-alone option even in zones without resource deficits. Detailed analysis has shown that there is very little scope for additional pressure management schemes to be implemented economically. Further work will continue, however, to optimise all existing schemes to ensure that the benefit of pressure management is maximised.

Data Updates

Background leakage levels and Natural Rate of Rise values have been updated with new data values representing the five years since the PR14 submission. These elements were completed within separately commissioned studies.

All other elements of data for the model were collated and updated in-house, incorporating Netbase data outputs, Active Leakage Control (ALC) team records and marginal cost of water values.

External costs of leakage have also been updated, the most notable being the carbon cost of leakage. This utilises an emission factor of 0.44 kg of CO₂ per kWh and a non-traded cost of carbon of £14 per ton of CO₂. The resulting cost was £0.71/MI.

Background Leakage Frontier levels

For each of the DMAs with observed MAL values, the MAL values and other DMA characteristics data were used to calibrate the “MAL explanatory factors relationships” developed by RPS.

An equation was calibrated for each of the four mains material cohorts. The equation is of the form:

$$\text{MAL (l/hr)} = (\text{L/N})^a \cdot \text{AZNP}^b \cdot \text{R1}^c \cdot \text{D1}^d \cdot \text{R2}^e \cdot \text{D2}^f \cdot \text{kJ}^g \cdot \text{Age}^h$$

Where:

L/N = Network Density (m/prop)

AZNP = Average Zonal Night Pressure (m)

kJ = size (joints in thousands)

R1 = Reported customer-side repairs (CSP) per year per 100 properties

R2 = Reported company-side repairs (mains, communications pipe and ancillary leaks) per year per kJ

D1 = Detected customer-side repairs (CSP) per year per 100 properties

D2 = Detected company-side repairs (mains, communications pipe and ancillary leaks) per year per kJ

Age = Average DMA age based on mains pipe age weighted by length (years).

a to h are exponents determined through regression performed on the MAL₅₀ values.

These relationships were then utilised to derive additional frontier level values in the range MAL₁₅ to MAL₅₀. The background levels derived were then compared to these reference values as follows:

Table 5.18: MAL reference values

MAL (m ³ /d)	MAL ₅₀ (m ³ /d)	MAL ₄₅ (m ³ /d)	MAL ₄₀ (m ³ /d)	MAL ₃₅ (m ³ /d)	MAL ₂₅ (m ³ /d)	MAL ₁₅ (m ³ /d)
34.39	43.97	39.63	35.72	31.85	24.45	16.74

This work shows that the calculated background level of leakage of 34.39 m³/day is equivalent to an industry value of approximately MAL₃₉. In other words, the overall level of minimum achieved leakage levels in our customer supply area is equivalent to the 39th percentile of values achieved at UK national level. This is appropriate for a company with lower than average leakage levels.

Results of ALC Modelling

The resulting leakage-cost curves for active leakage control are shown in Figure 5.4.




Figure 5.4: ALC cost curve for Essex and Suffolk

Figure 5.4 shows that the current SELL is 75.35 MI/d. This SELL is a short-run economic level, and is considerably higher than both the current leakage level and the current target. This is because at all previous periodic reviews the Essex zone was in supply-demand deficit. This meant that the economic level of leakage was a long-run SELL which resulted in leakage targets which were substantially lower than the current short-run SELL. The completion of the Abberton Reservoir scheme means that Essex is no longer in deficit, which leads to a short-run SELL which is now much higher. However we accept that performance commitments for leakage cannot rise.

Figure 5.4 shows that the point representing the current position, i.e. the current leakage level and the current annual expenditure, lies on the ALC curve. For this purpose, the calculation of current expenditure is consistent with the unit rates used for the derivation of the ALC cost curve itself, i.e. it includes all marginal costs relating to the active leakage control process. The current leakage level is the reported value for 2016/17, as for a given level of expenditure the actual leakage level will vary with weather conditions

Previous submissions and current position

The most recent submissions on the SELL analyses and leakage targets were made as part of the Strategic Business Plans and WRMP for AMP5 and AMP6. It was demonstrated that the SELL for AMP5 was 68.5 MI/d and for AMP6 was 81.81 MI/d. The stepped increase was due to the completion of the Abberton scheme and the resulting need to change from a long run to short run marginal cost adoption. The leakage targets since AMP5 have always been below the SELL value.

The following leakage targets through the AMP5 and AMP6 periods were agreed with Ofwat.

Table 5.19: Leakage targets for AMP5 and AMP6.

Annual Reporting Period	Leakage Target (Ml/d)
2010/11	66.0
2011/12	66.0
2012/13	66.0
2013/14	66.0
2014/15	66.0
2015/16	66.0
2016/17	66.0
2017/18	66.0
2018/19	66.0
2019/20	66.0

5.3.5 Future Profiles of Annual Leakage

Scenario Approach

The ongoing consistency programme creates a new problem for this WRMP submission. Whilst the reported value of leakage for 2016/17 has been calculated, audited and submitted, this value will change as the individual projects are completed and the effects incorporated into the calculation. A further complication is that the changes will be made to the value of bottom-up leakage, hence all of the outputs from the MLE water balance process will also change.

At this stage we have taken the reported 2016/17 values to be equivalent to the base year. In parallel, a further number of scenarios have been calculated which will represent a range of leakage outputs including one value which is considered to be the most probable outcome. All of these scenarios are based on the incorporation of calculation method changes which are fully understood. Each of the bottom-up scenarios will be separately input into the MLE water balance process to output each of the other associated parameters.

Leakage Reductions during AMP7

Leakage reductions have been proposed for AMP7 and are calculated as a percentage reduction below the existing 2019/20 performance commitment value. The absolute values for leakage performance commitments within AMP7 will, therefore, be calculated as:

$$\mathbf{2019/20\ Perf.\ Commitment \pm Consistency Adjustment - AMP7\ Reductions\ \%}$$

With the current leakage calculation method, the Performance Commitment (PC) for 2019/20 is 66 MI/d. Following the changes to be made for compliance with the Leakage Consistency report, we estimate that the most probable value of this Performance Commitment will be 62.6 MI/d. However our scenario analysis shows that the actual value of this PC could range from 67.6 to 57.5 MI/d. For AMP7, the planned percentage reduction over 5 years is 17.5%. Therefore the range of Performance Commitments through the 5-year period for the three scenarios is as shown in the following table.

Table 5.20: Performance commitments through AMP7

AMP	Year	Leakage Performance Commitments (MI/day)		
		Most Probable	Upper Scenario	Lower Scenario
AMP6	2019/20	62.6	67.6	57.5
AMP7	2020/21	60.4	65.2	55.5
	2021/22	58.2	62.8	53.5
	2022/23	56.0	60.5	51.4
	2023/24	53.8	58.1	49.4
	2024/25	51.6	55.7	47.4

These leakage reductions will be achieved during the remainder of the AMP6 and throughout the AMP7 periods by a combination of the following measures:

- Optimisation of all existing pressure management installations
- Additional pressure management installations with flow controllers where appropriate.
- Increased efficiency within the active leakage control process, especially through the use of noise loggers. We already make use of temporary noise logger deployments, but from 2018 onwards we intend to invest heavily in the latest generation of correlating noise loggers for permanent or semi-permanent installation.
- Increasing the level of committed resources for leak detection and repair.
- A programme of leakage driven mains renewals.
- Other innovations (see Section 5.3.6)

Leakage Reductions beyond AMP7

For each of the four periods of five years, we propose a further 10% reduction on the performance commitment for the final year of the preceding AMP period. Over the 20 year period 2025 to 2045 this will equate to a further 34% reduction on the PC for 2019/20. The proposed PCs for the final year of each of the four AMPs, for the three scenarios, are listed in the following table.

Table 5.21: Performance commitments beyond AMP7

AMP	Final Year	Leakage Performance Commitments (MI/day)		
		Most Probable	Upper Scenario	Lower Scenario
AMP6	2019/20	62.6	67.6	57.5
AMP7	2024/25	51.6	55.7	47.4
AMP8	2029/30	46.5	50.2	42.7
AMP9	2034/35	41.8	45.1	38.4
AMP10	2039/40	37.6	40.6	34.6
AMP11	2044/45	33.9	36.6	31.1

By the end of the AMP7 period it is envisaged that all opportunities for pressure management, including the optimisation of all existing schemes will have been completed. Throughout AMP7 we will seek to identify innovative techniques and further customer focussed activities. It is envisaged that these initiatives will deliver leakage savings and each will be analysed to understand individual and combined costs and benefits. Beyond these initiatives, the only remaining option is to replace sections of the distribution network. This option is both costly and is seen as the least favourable to the environment. It is important, therefore, to maximise the benefits of all other initiative before adopting a large scale programme of mains renewals.

5.3.6 Innovations for Leakage Management

In addition to the measures listed above in 5.3.3 and 5.3.5, we will invest in the following innovative initiatives for leakage management during the latter part of AMP6 and into AMP7.

- Sophisticated data science analytics to seek new insights into leakage and leakage management. This will be a direct follow-up to the very successful Innovation Festival we held in Newcastle in 2017.
- Detailed review of operational leakage survey strategy to understand the most efficient balance of techniques, including designating specific tasks for the most experienced technicians.
- Investigations into the impact of pressure transients.
- Trials of new leak detection equipment and pressure management flow controllers.
- The use of drones and satellite technology, particularly to identify leaks in rural locations and on long trunk main lengths.
- The development of customer plumbing loss evaluation technology.
- The potential use of leakage sniffer dogs.

We will also continue to take the lead role in UKWIR’s “Zero Leakage by 2050” research programme.

5.3.7 Benchmarking

International benchmarking typically utilises values derived using the ILI “Infrastructure Leakage Index.” This is a relatively crude index based on the derived leakage value, the number of connections, the length of mains and the system pressure. This allows data for various companies internationally to calculate a notional ILI value. The World Bank presents the results in four sections A (0-2 best) to D (8-10 worst). The industry last calculated all company’s data in 2011/12. At that time all UK companies (except Thames) fell within categories A and B with ESW and NWL both in category A. This situation will not have changed significantly in recent years. The main deficiency in the process is that the index makes no allowance for the age, condition or material of the mains network.

The 2016 UKWIR study on “Factors Affecting Minimum Achieved Leakage Levels” (Report No. 16-WM-08-58) was far more detailed and allowed ESW and NWL to benchmark their performance within the UK industry alone. This provides a much better indication of the condition of the network and is considered a much better benchmark for comparison purposes.

5.3.8 Co-ordination of Mains Renewal and Burst Repair

In his response to our WRMP consultation, the Mayor of London noted the disruption caused by mains renewal schemes, bursts and their subsequent repair and encourages us to work closely with Transport for London (TfL), the London Boroughs and the City of London Corporation to improve co-ordination and data sharing.

For planned water main renewal schemes, we attend quarterly coordination meetings run by the all of the London Borough authorities within our area of supply. At these meetings, TFL are also present and we present our planned programme of schemes for the year ahead and discuss these as necessary. In addition to these quarterly meetings, we also provide interim programmes of work and organise/attend any necessary scheme specific consultation and stakeholder meetings.

For emergency work, we work closely with TFL to ensure that any emergency works are carried out with as little disruption as possible. We liaise with TFL and when working on traffic sensitive roads will endeavour, where possible to carry out our work outside of traffic sensitive times.

6.0 CLIMATE CHANGE



6.1 Introduction

This chapter outlines how we have assessed the risk and possible impact of climate change on the deployable output (DO) of current sources of water and on customer demand. The assessment has been undertaken following guidance set out in the Water Resources Planning Guideline (WRPG) (Environment Agency, 2017a) and is presented in the following sections:

- Vulnerability to climate change;
- Method selection;
- Presentation of climate change assessment results (scenarios);
- Scaling method used to factor in any climate change that has already happened; and
- Allowance for climate change in the headroom assessment

6.2 Vulnerability to Climate Change & Method Selection

6.2.1 Climate Change Vulnerability Assessment


A climate change vulnerability assessment is required to understand how vulnerable each Water Resource Zone (WRZ) is to changes in DO as a result of climate change and therefore which method should be used to assess the effect of climate change on WRZ deployable output.

We have undertaken a climate change vulnerability assessment which was based on:

- A magnitude versus sensitivity plot of DO change from previous climate change assessments; and
- A table summarising the information which will be used to determine the final vulnerability of a resource zone to climate change;

6.2.2 Magnitude versus Sensitivity Plot

A Magnitude versus Sensitivity Plot (Figure 6.1 below) covering all four of our WRZs was prepared using data from our PR14 WRMP assessment of climate change on DO. It shows the change in DO for the “mid” climate change scenario plotted against the uncertainty range, where the latter is calculated as the difference between the “wet” and “dry” scenarios.



<5%	Low	Medium	High
6% to 10%	Medium	Medium	High
11% to 15%	High	High	High
>15%	High	High	High

Figure 6.1: Magnitude versus Sensitivity Plot

The above plot is based on the following data:

Table 6.1: PR14 Climate Change Data - %age Change from Baseline DO

	Essex	Waveney	Bure
without climate change	-	-	-
with climate change (Driest)	-6	-10.1	-1.08
with climate change (Mid)	4	-7	-0.31
with climate change (Wettest)	10	-3.7	0.61

Using the Magnitude versus Sensitivity Plot approach as an initial climate change vulnerability assessment tool, it is possible conclude that:

- The River Bure DO has a low vulnerability to climate change;
- The Essex WRZ as a whole has a medium vulnerability to climate change; and
- The River Waveney DO has a high vulnerability to climate change.

However, the WRPB states that the methods a water company uses to assess the effect of climate change on DO should be proportionate to the risks presented by climate change to each water resource zone.

Early draft PR19 supply demand balance calculations indicated that all four WRZs will have a supply demand balance surplus across the full planning horizon. Consequently, climate change poses a lower risk to security of supply than otherwise would have been the case.

Additionally, our surface and groundwater sources have historically performed well during drought.

For groundwater, lowest pumped water levels in all sources have always remained significantly above deepest advisable pumped water levels. For surface water, Ormesby Broad, Lound Lakes and Fritton Lake have always quickly recharged during the winter.

Additional investment, namely Hartismere Borehole 1, a new treatment works in Hartismere WRZ and the Abberton Scheme in Essex WRZ mean that both WRZs will be more robust during future droughts compared to those in the 1990s and therefore less vulnerable to climate change.

Tankering of treated water was required between the Northern, Central and Hartismere WRZs in 1997. However, subsequent investment in a new groundwater source and treatment works at Bedingfield would mean that tankering would now not be required should a similar drought be experienced with similar customer demand.

Although Chalk groundwater levels in Hartismere Borehole 6 were slightly more susceptible to drought than elsewhere in our operating area, even here, groundwater levels in the 1997/98 drought remained well above the defined deepest advisable pumped water level. This would also indicate that climate change poses a lower risk to security of supply within the Hartismere WRZ which historically has been most affected by drought.

Taking account of the above, we consider that it is reasonable and appropriate to use medium or low vulnerability methods for its four WRZs. The chosen methods are detailed in section 6.3 below.

6.3 PR19 Climate Change Assessment Method

6.3.1 General Approach

The impact of climate change on supply has been considered in terms of:

- the explicit effect on DO; and
- the uncertainty of the effect on DO as described in target headroom (using triangular distributions defined by minimum, best estimate and maximum scenarios)

In line with the WRP, we have estimated the impact of climate change on DO using the following four stage approach:

Stage 1: Calculate river flows and/or groundwater levels for a water resource zone in the 2080s, under the number of climate projections appropriate to the level of assessment being carried out.

Stage 2: Calculate DO for the water resource zone in the 2080s under each climate projection being assessed.

Stage 3: Scale the impacts of climate change by determining the change in DO for each year of the planning period and input these figures into the water resources planning tables.

Stage 4: Determine the uncertainty associated with climate change for inclusion in target headroom.

6.3.2 Essex WRZ Surface Water Climate Change Assessment Method

The previous guidance (Environment Agency, 2012b) for estimating deployable output for river flows under climate change has been superseded by a new approach, outlined in *Estimating the impacts of climate change on water supply* (Environment Agency, 2017c). An important difference is that this updated approach uses the 2080s time period, which ensures that the climate signal is identified over natural variability, resulting in greater consistency between different sources of climate information.

Three tiers of analysis are presented for calculating river flows for input into a water resources model:

- Tier 1 analysis for if the vulnerability is low and there are no rainfall runoff models
- Tier 2 analysis for if the vulnerability is medium or there are available rainfall-runoff models
- Tier 3 analysis for where there is high vulnerability

As we have rainfall-runoff models for our Essex System surface water catchments, it was agreed that Tier 2 analysis should be used for the Essex System. The Tier 2 approach involves using the 11 climate data scenarios from the UKCP09 Spatially Coherent Projections to generate monthly climate change factors for precipitation and potential evapotranspiration (PET) in the 2080s, to carry out rainfall-runoff modelling and create flow sequences to be used in water resource modelling.

An additional advantage of having rainfall-runoff models, and using future climate data sets which may include a drought worse than that currently on record, is that we are able to assess resilience “from baseline through to the end of period of interest”, as specified in the WRP.

Each of the 19 Essex System sub-catchments selected for the climate change analysis (Table 6.2) were attributed to a UKCP09 SCP grid cell, and monthly climate change factors were obtained for each relevant grid cell in the form of monthly percentage change in rainfall and temperature. Rainfall and PET time series are required for input into the rainfall-runoff models, so the monthly temperature climate change factors were converted into a monthly percentage change in PET. The baseline rainfall and PET time series for each sub-catchment were then perturbed using the monthly climate change factors, and rainfall-runoff model input files were created containing the perturbed rainfall and PET time series.

The input files were run through the rainfall-runoff models to obtain 19 river flow time series for the Essex System sub-catchments. These river flow time series were then aggregated and factored to produce the four river flow time series to be input into the Essex System Aquator model. This process was repeated for each of the 11 climate change scenarios.

In total, 44 perturbed time series were imported into the model, 11 for each river flow time series, and the appropriate time series were assigned to catchment components for each of the 11 climate change scenarios. The components that are assigned a river flow time series sequence in the model are listed in Table 6.3.

Table 6.2: The nineteen sub-catchment river flow time series used to create the four river flow time series for input to Aquator model

Ely Ouse @ Denver	Little Ouse @ Abbey Heath Lark @ Temple Wissey @ Northwold Stringsides @ Whitebridge Lea Brook @ Beck Bridge Rhee @ Burnt Mill Cam @ Dernford Snail @ Fordham Swaffham Lode @ Swaffham Bulbeck Quy Water @ Lode
Chelmer @ Langford	Chelmer @ Springfield Can @ Beach's Mill Ter @ Crabbs Bridge Sandon Brook @ Sandon Bridge
Blackwater @ Langford	Blackwater @ Appleford Bridge Brain @ Guithaven Valley
Stour @ Stratford	Stour @ Langham Box @ Polstead Brett @ Hadleigh

Table 6.3: Components Assigned a River Flow Time Series Sequences

Catchment Model Reference	Catchment Name	Assigned Time Series
CM2	Upper Stour Kedington	Stour @ Stratford
CM3	Roman River	Blackwater @ Langford
CM4	Upper Blackwater	Blackwater @ Langford
CM5	River Chelmer	Chelmer @ Langford
CM6	Hanningfield Inflow	Chelmer @ Langford
CM7	Abberton Inflow	Stour @ Stratford
CM8	Lower Stour Stratford	Stour @ Stratford
CM9	Upper Stour Wixoe	Stour @ Stratford
CM10	Lower Stour Langham	Stour @ Stratford
CM11	Upper Stour Westmill	Stour @ Stratford
CM12	Lower Stour Lamarsh	Stour @ Stratford
CM13	Lower Blackwater	Blackwater @ Langford

Catchment Model Reference	Catchment Name	Assigned Time Series
CM14	Ely Ouse	Ely Ouse @ Denver
CM15	Cut off Channel	Ely Ouse @ Denver

6.3.3 Suffolk Northern Central WRZ Surface Water Climate Change Assessment Method

We do not yet have rainfall-runoff models for surface water resources in Suffolk, namely the River Bure and Waveney, which constrains the range of potential options available. Tier 1 analysis is required, which involves the use of Future Flows Hydrology monthly change factors.

Climate change factors were required for the following Suffolk catchments:

Table 6.4: Gauging station flows required for climate change analysis

River	Station	Station No.	Period of Record	Catchment Area (km ²)
Waveney	Ellingham Mill	34013	1972-2001	670.0
Bure	Ingworth	34003	1959-2011	164.7

Neither of these catchments is a Future Flows (FF) catchment with derived perturbed time series, therefore it was necessary to estimate factors from catchments that do form part of the FF database.

Proximal FF catchments were identified, and their characteristics were assessed. The proximal catchments for each location are:

Table 6.5: Proximal Future Flows Catchments to Waveney at Ellingham Mill and Bure at Ingworth

ESW River	FF Station No.	FF River	FF Station	FF Catchment Area (km ²)
Waveney	34006	Waveney	Needham	370
Bure	33019	Thet	Melford Bridge	316
	33044	Thet	Bridgham	278
	33063	Little Ouse	Knettishall	101
	34002	Tas	Shotesham	147
	34011	Wensum	Fakenham	162
	34014	Wensum	Swanton Morley	398
	34018	Stiffkey	Warham All Saints	88

For the River Bure, the Thet at Melford Bridge (33019) was identified to be a more favourable selection than the other options based on its Nash-Sutcliffe statistic of 0.80, a measure of whether the modelled time series describes the observed time series better than the long-term average (a value of 1 means perfect agreement). The decision was therefore made to use this catchment to derive the climate change factors for the Bure.

The FF monthly change factors were obtained for FF stations 34006 (Waveney at Needham) and 33019 (Thet at Melford Bridge) and used to perturb the baseline flows for the Waveney at Ellingham Mill and the Bure near Wroxham, to obtain a river flow time series for each of the 11 FF climate change scenarios.

6.3.4 Groundwater Climate Change Assessment

Background

The WRPG states that a water company's previous assessment of climate change as used for WRMP14 can be used. This PR19 WRMP has used the PR14 WRMP groundwater climate change assessment output to define groundwater deployable outputs with the effects of future climate change. This is because:

- i. The CP09 climate projections have not been updated in the intervening period. The CP18 climate projections will not be published until late 2018;
- ii. The Environment Agency's regional model, which was used for the PR14 assessment, remains the model of choice for East Anglia; and
- iii. There have been no known changes to borehole performance that could be related to dry weather and climate change.

Therefore, the effect of climate change on groundwater DO for this PR19 WRMP remains the same as that reported in the PR14 WRMP. Nevertheless, the effect of climate change has been applied to the latest PR19 groundwater source deployable output assessments.

PR14 Method

The PR14 climate change assessment for our groundwater sources was undertaken in 2012 by consultants Amec. The PR14 method used the Environment Agency's regional groundwater model and a targeted sample of the UK CP09 data set that was chosen following drought indicator analysis. The method was very similar to the PR19 Tier 2 approach outlined in the Environment Agency's supplementary guidance entitled, "Estimating the Impacts of Climate Change on Water Supply (Environment Agency, 2017c).

This two staged process involved undertaking a drought indicator analysis to determine the sensitivity of the system to water availability in drought conditions and then using the drought indicator to sample climate change projections.

In order to avoid running a large number of projections that were not the focus of interest for water resources planning, the PR14 WRPB stated that where a water resource zone was confirmed as being sensitive to drought, then the UKCP09 data set should be sampled in two stages:

- First using Latin Hypercube Sampling (LHS) to develop a minimum of 100 climate projections;
- Secondly, creating a sub-sample of this data set of a minimum of 20 scenarios, based on the drought indicator that selects sufficient dry samples in addition to achieving a representative spread of projections across the full sample.

Selecting a Sub-Sample of 20 UKCP09 Scenarios

This work was completed by HR Wallingford for Anglian Water Services (AWS), who like us, operate in the Anglian River Basin. LHS was employed to select a sub-sample of 100 UKCP09 scenarios of monthly climate change perturbation factors for precipitation and temperature. Factors for PET were then derived from the temperature data using the Oudin *et al* (2005) approach (Anglian Water Services, 2012).

The range and likelihood of projected changes for the 100 scenarios were consistent with scenarios from individual UKCP09 grid squares across the area of interest. Consequently, HR Wallingford concluded that the 100 scenarios are representative of the Anglian River Basin (Anglian Water Services, 2012).

HR Wallingford then undertook further analysis and reduced the sub-sample of 100 scenarios down to 20 scenarios for groundwater modelling purposes (Anglian Water Services, 2012).

To do this, AWS initially intended to use hydrometric data from a number of key monitoring points to derive a suitable drought indicator such as annual aridity. This indicator would have then been used to characterise the sensitivity of an aquifer to climate variability and to guide sampling of the UKCP09 projections. However, this was not possible given the complexity of the hydrogeology and also due to the limited data and drought events within the data. There was reasonable correlation between annual precipitation and groundwater level at three AWS groundwater sources. However, AWS and HR Wallingford concluded that using precipitation alone to sample UKCP09 scenarios would carry the risk of sampling a set of unrepresentatively hot or cool scenarios (Anglian Water Services, 2012).

Consequently, HR Wallingford concluded that temperature should also be included in the process as changes to temperature in the future will significantly affect future evapotranspiration and soil moisture deficit. Given the above, HR Wallingford used the following methodology to reduce the sub-sample of 100 scenarios down to a sub-sample of 20:

- LHS was employed to provide an initial sub-sample of 100 scenarios from the full UKCP09 ensemble of 10,000 projections of rainfall and temperature. This considered the covariance across eight dimensions (precipitation and temperature for four seasons);
- A comparison of the sub-sample of 100 scenarios was made against the full ensemble of 20,000 in terms of changes to annual and seasonal precipitation and temperature;
- The 100 samples were then ranked using a FAO-56 based lumped recharge model to derive relative estimates of changes to average annual recharge;
- From the ranked 100 scenarios, ten scenarios were then selected that produced the greatest reductions in average annual recharge. A further ten scenarios were then selected that were evenly distributed over the full range of estimated changes to average annual recharge (the split sample);
- A comparison of the split sample against the 100 LHS scenarios and the full UKCP09 ensemble of 10,000 scenarios was then made in terms of changes to annual and seasonal precipitation and temperature; and
- Sample weights were then derived based on average annual recharge to avoid introducing bias in the interpretation of the projected impacts on groundwater levels due to the split sampling approach (Anglian Water Services, 2012).

HR Wallingford confirmed that the sub-sample of 20 scenario perturbation factors should be applicable for the whole of the NEAC and Essex groundwater model areas which cover all of our WRZs.

Modelling Approach

We commissioned AMEC to assess the potential impacts of climate change on groundwater levels in the aquifers from which it abstracts. AMEC used two existing groundwater models, the NEAC model for the Suffolk sources and the Essex model for the Essex sources, together with the selected 20 UKCP09 perturbation factors to predict the change in groundwater levels expected under future climate change. In addition, a number of demand restriction scenarios were conducted.

This project utilised model output from runs undertaken by AMEC for AWS on a parallel project. The project extracted results from two existing suites of 20 model runs of the NEAC and the Essex models (respectively) based on perturbed climate. The perturbation factors were derived by HR Wallingford for AWS.

The project work was split into a number of tasks as follows:

- Review of baseline model representation and calibration;
- Climate change scenario model runs – non demand restriction
- Climate change scenario model runs – demand restriction
- Summary of model output and predicted change in groundwater levels under climate change.

Review of Model Calibration

AMEC reviewed the model representation and calibration in the vicinity of our sources by comparing abstraction return data to how the abstractions were represented in the groundwater model. A further check was also undertaken to review regional groundwater heads in the vicinity of the sources. The sources were grouped geographically by model area and a hydrogeological context diagram for each source was produced that included solid geology and surface water features as well as the abstraction and observation locations. Model refinement would have been evoked if review of the model representation had identified significant differences between modelled and real abstraction or modelled and observed heads. However, this was not the case and the model representation was considered fit for purpose.

Climate Change Scenario Model Runs

The predictions of future rainfall and temperature, which form the basis of the scenario runs, were taken from the UKCP09. A key feature of UKCP09 compared with earlier climate projections such as UKCIP02 is that the projections are probabilistic, i.e. they describe a range of possible future climates with associated probabilities.

The potential impacts of climate change on groundwater levels were assessed using the North East Anglian Chalk (NEAC) groundwater model and the Essex groundwater model. This model system, developed by AMEC for the Environment Agency, comprises two separate models: a 4R (Rainfall, Runoff, Routing, and Recharge) model, which simulates recharge to groundwater, and a MODFLOW 96 VKD regional groundwater flow (Amec Foster Wheeler, 2013).

The 4R model estimates spatially and temporally distributed recharge to groundwater as a function of landscape data (soils, topography, geology, and land use), artificial influences (surface water abstractions and discharges) and meteorological data (rainfall and evapotranspiration). The model produces daily output on a regular 200 m grid. The output from the 4R model is then used with the Modflow model to simulate groundwater levels and surface water flows (runoff and base flow).

To simulate the potential impact of climate change on recharge to groundwater, and hence on groundwater levels, the 4R model was run a number of times with “perturbed” meteorological input data. The perturbed input data were derived by applying multiplication factors to historical time series of rainfall and potential evapotranspiration (PE), which represent the change in rainfall and PE relative to a 1961-1990 baseline which is predicted to occur under climate change. The perturbation factors are based on the UKCP09 climate projections (Murphy, 2009UKWIR), and were derived by HR Wallingford. Twenty perturbed model simulations were then carried out for each model, together with a baseline simulation using historical time series of rainfall and PE. These models used an historical representation of abstraction and discharge. Each perturbed simulation used a

different set of perturbation factors representing one possible future climate scenario. All model runs covered a period of 50 years, although the first ten years of each model run is regarded as “spin-up” during which time the output can be significantly influenced by choice of initial conditions, and model output from this period was discarded, leaving a time series of 40 years of output from each simulation.

A total of 20 model runs were performed to cover the entire range of predicted changes in recharge for both the NEAC and Essex models. The groundwater recharge for each scenario varies with one extreme representing 75% of the baseline recharge amount (the driest scenario) to 120% (the wettest scenario).

To assess the potential impact on groundwater levels, a comparison between groundwater levels during the drought period in the 1990s in the baseline run and in a selection of scenario runs at representative groundwater sources was been carried out.

Figure 6.2 shows an example of the output for Blyth Borehole 2. There is generally a consistent pattern across the results which are as AMEC expected (i.e. modelled water levels in the wetter scenarios are higher than those in the drier scenarios). The differences of the modelled water levels are generally between 0.5 and 2 m lower for the driest scenarios and 0.3 to 1.5 m higher for the highest water levels.




Figure 6.2: Modelled Blyth Borehole 2 Groundwater Levels

At a few of the sources there are very low impacts (e.g. Northern Central Borehole 3 and Colchester Borehole 1). This is a result of local factors, for example a very thick confined layer above the Chalk insulating the deep Chalk water levels from changes in recharge. There are a number of anomalously large drawdowns at a number of

sites for the driest scenarios, i.e. at Hartismere Borehole 6. These are not thought to be 'real', but are artefacts of certain parts or layers of the model drying up in the driest scenarios. Conversely there appears to be a significant increase in modelled groundwater levels at Blyth Borehole 6 which again is a facet of the model layers wetting up in the high recharge scenarios compared to the baseline, and these recoveries are not thought to be 'real'.

AMEC Conclusions

The results of the AMEC assessment can be summarised as follows:

- An initial review of the calibration in terms of heads and the abstraction representation in the NEAC Model and the Essex model lead to the conclusion that the representation was fit for purpose.;
- The NEAC and Essex regional groundwater models have been used to predict the potential impact of climate change on recharge and groundwater levels by the 2030's;
- The predictions were carried out using estimated perturbations to rainfall and potential evapotranspiration taken from the UKCP09 climate projections, for the medium emissions scenario;
- Twenty climate change scenarios were selected from the UKCP09 projections, covering the range of predicted changes in recharge compared with the 1961-1990 baseline period;
- The perturbations were applied to the historic rainfall and PE time series used with the model;
- Under the driest recharge scenario, drought groundwater levels are predicted to drop by between about 2.5 m and 0.03 m at source locations;
- Under the wettest recharge scenario, groundwater levels are predicted to rise at all source location, by between 0.08 m and about 1.5 m;

Effect of Climate Change on PR19 Groundwater Source Deployable Output

The head differences between baseline and climate change model runs identified in the above AMEC assessment have been used to establish whether climate change effects source DO.

A baseline (without climate change) DO assessment for each groundwater source has been undertaken using the 1995 UKWIR methodology (see section 3) (UKWIR, 1995a). A groundwater source performance graph has been prepared for each source which plots the following information:

- Observed groundwater levels; and
- Constraints (including deepest advisable pumped water level, pump intake depth, annual average daily licence and treatment works capacity).

The head difference between the baseline model run and the mean of the 75% and 119% recharge scenario was then applied to an observed groundwater level on the initial DO assessment groundwater source reliable output graph. Figure 6.3 below provides an example and is the assessment for Northern Central Borehole 6.




Figure 6.3: Groundwater Source Reliable Output with Climate Change Perturbed Bounding Curve

The chosen observed groundwater level was always one which intersects the drought bounding curve. A new drought bounding curve has then been created by dropping the initial curve so that it intersects the climate change perturbed groundwater level. The first constraint the new climate change perturbed bounding curve intersects is then used to define DO (with climate change).

For all of the Suffolk groundwater sources, the annual average daily licence remains the constraining factor and climate change does not cause groundwater levels to drop below the deepest advisable pumped water level (DAPWL). Consequently, DO in both the base year (2016/17) and in 2039/40 remain the same.

The same conclusion can be drawn for all of the Essex groundwater sources with the exception of South Essex Well 2. For this, DO is reduced from 3.4 Ml/d (base year) to 3.3 Ml/d in 2035. DO has been profiled across the planning horizon in line with the WRPG.

6.4 Presentation of climate change assessment results (scenarios)

6.4.1 Essex WRZ Surface Water Climate Change Assessment

The DO of the Essex System under each of the 11 UKCP09 SCP scenarios is shown in the table below, along with the associated change in DO relative to the baseline.

Table 6.6: Planned Levels of Service Deployable Output

Planned LoS Scenario: Essex System		Essex System Deployable Output (MI/d)	Change from Baseline (MI/d)
Baseline (no climate change)		390	
UKCP09 SCP Climate Change Scenarios	Scenario 1	393	+3
	Scenario 2	401	+11
	Scenario 3	403	+13
	Scenario 4	403	+13
	Scenario 5	403	+13
	Scenario 6	403	+13
	Scenario 7	379	-11
	Scenario 8	390	0
	Scenario 9	401	+11
	Scenario 10	394	+4
	Scenario 11	395	+5
Minimum climate change scenario DO		379	-11
Average climate change scenario DO		397	+7
Maximum climate change scenario DO		403	+13

The greatest loss of DO from the baseline scenario under climate change is 11 MI/d, and the greatest gain of DO is 13 MI/d. The average change is an increase of 7 MI/d.

Generally, the climate change scenarios have a greater number of high flow days and a greater number of low flow days compared to the baseline, reflecting the predicted change in rainfall patterns with drier summers and wet winters. The Essex System is relatively insensitive to reductions in summer river flow because under the baseline scenario during the design drought, river water availability is already extremely low. However, the model is relatively sensitive to increases in winter river flow because there is capacity within the system’s infrastructure to take advantage of these higher flows by abstracting the river water, and putting it into storage in the reservoirs.

The impact of climate change on the DO of the Essex System is included in the supply demand planning tables. The minimum, average and maximum DO figures calculated from the 11 climate change scenarios will be used.

The uncertainty of climate change impact on DO of the Essex System is included in target headroom. The required triangular distribution for the headroom uncertainty calculation will use the minimum, average and maximum loss to DO.

6.4.2 Suffolk Northern Central WRZ Surface Water Climate Change Assessment

River Bure Results

The results of the FF climate change assessment for the River Bure are as summarised in the table below.

Table 6.7: River Bure Deployable Output

ESW River Bure Intake		Deployable Output (MI/d)	Change from Baseline (MI/d)	
Baseline (no climate change)		26.7		
Future Flows Climate Change Scenarios	1	FF-HadRM3-Q0_afgcx	25.9	-0.8
	2	FF-HadRM3-Q3_afixa	26.0	-0.7
	3	FF-HadRM3-Q4_afixc	25.0	-1.7
	4	FF-HadRM3-Q6_afixh	25.9	-0.8
	5	FF-HadRM3-Q9_afixi	25.9	-0.8
	6	FF-HadRM3-Q8_afixj	24.5	-2.2
	7	FF-HadRM3-Q10_afixk	24.5	-2.2
	8	FF-HadRM3-Q14_afixl	25.2	-1.5
	9	FF-HadRM3-Q11_afixm	25.9	-0.8
	10	FF-HadRM3-Q13_afixo	25.4	-1.3
	11	FF-HadRM3-Q16_afixq	25.5	-1.2
Minimum climate change scenario DO		24.5	-2.2	
Average climate change scenario DO		25.4	-1.3	
Maximum climate change scenario DO		26.0	-0.7	

The minimum, average and maximum climate change scenario DO values are all significantly higher than the 17.84 MI/d baseline DO that we are reporting for this draft WRMP, therefore climate change would not constrain DO for the River Bure.

River Waveney Results

The results of the FF climate change assessment for the River Waveney are as summarised in the table below.

Table 6.8: River Waveney Deployable Output

River Waveney		Deployable Output (MI/d)	Change from Baseline (MI/d)	
Baseline (no climate change)		20.5		
Future Flows Climate Change Scenarios	1	FF-HadRM3-Q0_afgcx	20.5	0
	2	FF-HadRM3-Q3_afixa	20.5	0
	3	FF-HadRM3-Q4_afixc	13.8	-6.7
	4	FF-HadRM3-Q6_afixh	20.5	0
	5	FF-HadRM3-Q9_afixi	20.5	0
	6	FF-HadRM3-Q8_afixj	13.8	-6.7
	7	FF-HadRM3-Q10_afixk	13.8	-6.7
	8	FF-HadRM3-Q14_afixl	20.5	0
	9	FF-HadRM3-Q11_afixm	20.5	0
	10	FF-HadRM3-Q13_afixo	20.5	0
	11	FF-HadRM3-Q16_afixq	20.5	0
Minimum climate change scenario DO		13.8	-6.7	
Average climate change scenario DO		18.7	-1.8	
Maximum climate change scenario DO		20.5	0	

The effect of the climate change scenarios on the baseline DO ranges from a reduction of 6.7 MI/d to no change. The average change is a reduction of 1.8 MI/d.

Ormesby Broad and Lound Ponds Results

There is not an obvious method for assessing the impact of climate change on DO of a groundwater-fed lake. For this draft WRMP, a 2085 climate change factor was estimated by taking an annual average percentage change in rainfall for the area using the UKCP09 SCP factors, and applying it to the baseline DO of both Ormesby Broad and Lound Ponds as a percentage change in DO in 2085 under a minimum, maximum and average climate change scenario. The results are presented in Table 6.9 and Table 6.10.

Table 6.9: Ormesby Broad Deployable Output

Climate change scenario	Annual average change in rainfall (%)	2085 DO (MI/d)	Change from baseline (9.6 MI/d)
Minimum	-8.1	8.8	-0.8
Average	1.1	9.7	0.1
Maximum	11.2	10.6	1.0

Table 6.10: Lound Ponds Deployable Output

Climate change scenario	Annual average change in rainfall (%)	2085 DO (MI/d)	Change from baseline (8.1 MI/d)
Minimum	-8.1	7.4	-0.7
Average	1.1	8.2	0.1
Maximum	11.2	9.0	0.9

We will discuss with the Environment Agency whether there is a more appropriate approach for WRMP24. For example, all of these lakes are predominantly groundwater fed and so a similar approach to the groundwater climate change assessment could be used. An assessment could be made by comparing the climate change perturbed groundwater level against the lake bed level to establish whether base flow could still be maintained in worse case drought years. This approach will need a water balance model to be developed for each of the lakes. It is our intention to develop such a model for Fritton and Lound lakes over the coming year.

6.4.3 Suffolk Blyth and Hartismere WRZ Climate Change Assessment

Blyth and Hartismere WRZs are supplied by groundwater abstracted from Chalk and Crag aquifer boreholes.

6.5 Scaling method used to factor in any climate change that has already happened

Once a range of DO scenarios for the year 2085 have been calculated, the results then need to be scaled back to enable definition of climate change impact for any year of interest, and to account for uncertainty for inclusion in the target headroom assessment.

The WRMP19 supplementary information (Environment Agency, 2017c) defines a new scaling equation, to be applied for every year from the start of the planning period of (2016/17, in this case) to 2084/85:

$$\text{Scale factor} = \frac{\text{Year} - 1975}{2085 - 1975}$$

The WRMP14 guidance (Environment Agency, 2012b) recommended the use of two separate scaling factors – one to be applied before 2029/30, and one to be applied after. The WRMP19 equation supersedes the WRMP14 equations based on the following:

- The inclusion of year 2085 in the equation is necessary for the calculation of impact in the 2080s;
- The gradient of the climate change impact is reduced;
- The equation results in a loss of DO by the start of the planning period, therefore accepts that some climate change will have already occurred; and

- Initial impacts are brought forward, but within ten years the paths of the WRMP14 and the WRMP19 equations converge (Figure 6.4).




Figure 6.4: Impact of climate change on deployable output scaled using the WRMP14 guidance equations and the revised equation for WRMP19 (Environment Agency, 2017c)

6.6 Allowance for climate change in the headroom assessment

An allowance for the uncertainty of climate change is taken into account in the headroom assessment on both the supply and demand side, by means of components S8 uncertainty of impact of climate change on source yields and D3 uncertainty of impact of climate change on demand.

Further information can be found in section 7.2 of this report and in our PR19 Headroom Calculations Report (Essex & Suffolk Water, 2017a).

6.7 Effect of Climate Change on Water Resource Zone Supply

6.7.1 Essex WRZ

The effect of climate change on Water Available For Use (WAFU) in the Essex WRZ is illustrated in Figure 6.5 and summarised in Table 6.11 below.

Essex Water Resource Zone
Water Available for Use Climate Change Scenarios




Figure 6.5: Essex WAFU – With and Without Climate Change

Table 6.11: Essex WAFU – With and Without Climate Change

	2016/17	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
WAFU without climate change	435.2	430.2	434.2	433.2	433.2	453.0	453.0	453.0
WAFU with climate change	437.9	433.0	437.3	436.7	437.0	457.1	457.4	458.4

6.7.2 Blyth WRZ

Climate change does not affect WAFU in the Blyth WRZ. This is because all sources in Blyth WRZ are groundwater sources and there was no effect of climate change on groundwater sources.

6.7.3 Hartismere WRZ

Climate change does not affect WAFU in the Hartismere WRZ. This is because all sources in Hartismere WRZ are groundwater sources and there was no affect of climate change on groundwater sources.

6.7.4 Northern Central WRZ

The effect of climate change on WAFU in the Northern Central WRZ is illustrated in Figure 6.6 and summarised in Table 6.12 below.




Figure 6.6: Northern Central WAFU – With and Without Climate Change

Table 6.12: Northern Central WAFU – With and Without Climate Change

	2016/17	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
WAFU without climate change	80.16	80.16	80.16	80.16	80.16	80.16	80.16	80.16
WAFU with climate change	79.54	79.50	79.43	79.35	79.28	79.20	79.13	78.91

6.8 Effect of Climate Change on Demand

6.8.1 Background

The impact of climate change on demand has been considered in terms of:

- (1) The explicit effect on distribution input. This has been defined for two scenarios; the most-likely and least likely (maximum) scenarios. The most-likely scenario has been chosen as the central scenario to be included within the DO in the supply demand balance.

- (2) The uncertainty on the effect on distribution input as described in target headroom (using triangular distributions defined by zero, best estimate and maximum scenarios)

The above assessment can also enable definition of an envelope of climate change. Such an envelope can be defined for each weather scenario considered in demand forecasts (principally dry and normal).

The above information has been used to illustrate the effect of climate change on demand in each resource zone both in tabular and graphical format. The following sections give a brief synopsis as to how climate change has been considered followed by this summary information of the results.

6.8.2 Methodology

The UKWIR 'Impact of Climate Change on Water Demand' project (UKWIR, 2013) results have been used to calculate forecasts of climate change impacts on household water demand for this WRMP. The report associated with this project has been used as an updated reference source that quantifies the impact of climate change on demand.

In summary, this UKWIR project used statistical analysis on five case studies looking at household and micro-component water consumption and non-household water consumption. The weather- demand relationships developed from the case studies have been used in combinations with UKCP09 climate projections to derive algorithms for calculating estimates of the impact of climate change of household water demand for each UK region in the format of look-up tables (UKWIR, 2013). These look-up tables present the estimated future impacts of climate change on household demand for any river basin between the years 2012-2040 and for a range of percentiles to reflect the uncertainty of the UKCP09 climate projections (UKWIR, 2013). Please refer to the report for a complete description on the methodology in creating the look-up tables' used (UKWIR, 2013).

A look-up table is provided for each UKCP09 river basin areas and the associated area. Within each area look-up table demand factors, describing the percentage change in household demand, are for two case study relationships (Thames Water and Severn Trent Water) and three demand criteria (annual average, minimum DO and critical period). The changes in household demand are provided for the 10th, 25th, 50th, 75th and 90th percentile to reflect the uncertainty in UKCP09 climate projections.

Due to the planning scenario selected for us the annual average demand criterion is the only one that applies to us, therefore this is the only set of rows that have been employed.

The table below shows the river basin area and case study relationship chosen for each area.

Table 6.13: River basin and case study relationship

Area	River Basin look-up table selected	Case Study relationship selected
Essex	Thames	Thames
Suffolk	Anglian	Severn Trent

The Severn Trent case study relationship was selected for Suffolk as the Severn Trent area is more rural than Thames and provides a better representation of Suffolk. The Essex area is believed to be closer in similarities to the Thames area than the Anglian area which is the reason why the Thames river basin and case study relationship have been chosen for the Essex area.

Different percentiles have been selected to give the most-likely and least likely (maximum) effects of climate change on demand across the planning horizon. For the most-likely effects of climate change the 50th percentile has been chosen (a one in two chance of occurrence). To determine the least likely (maximum) effect of climate change of demand the 90th percentile was selected (a one in ten chance of occurrence). This approach allows the different probabilities of climate change occurring to be examined over the next 25 years.

The look-up table values give the percentage change in demand between 2012 and 2040. As these look-up tables were not updated for PR19 the projections were extended along the same trajectory until 2060 to cover the demand forecasting horizon. This has been applied to the total micro-component consumption to give the most-likely and least likely (maximum) forecasts of climate change impact. The report has advised that the same percentage change in demand can be assumed for both measured and unmeasured properties (UKWIR, 2013). Therefore within the micro-component model the total PCCs have been adjusted by the overall percentage change in demand as found in the look-up tables. It has been assumed that household demand is the only component of demand affected by climate change. Non-household demand is not expected to be effected by climate change. The report also stated that where necessary to allocate the effects of climate change across components of household demand, it would be reasonable to assume that all additional water consumption in hotter or drier weather is for external water uses (UKWIR, 2013).

6.9 Impact on Supply Demand Balance

The impact of climate change on the overall supply demand balance and the sensitivity to climate change scenarios can only be evaluated at the appropriate point in the water resources planning process, after the initial supply demand balance has been constructed. Accordingly the impacts of climate change on the supply demand balance have been described at the end of section 8 on baseline supply demand balance.

6.10 Carbon Emissions from Current Operations

We report annually on the volume of greenhouse gas for which we are responsible and have done so since 2008. The trend in these emissions is a falling one though there is some year on year variation in this, mainly due to the impacts of weather and our response to it.

This fall reflects a structured approach to emissions reduction through the implementation of a carbon management plan, initiated in 2009. This Plan has the ambition to reduce emissions by 35% by 2020 against a 2008 baseline. If the emissions linked to grid electricity were to fall as projected by government at that time this should result in a total reduction of 50% in the company-wide operational emissions by 2020.

The plan is based on a combination of actions to improve efficiency in the use of energy and the displacement of grid electricity by the development of renewable energy. This includes hydroelectric generation and solar and in particular the use of biogas from sewage sludge in our Northumbrian area where NWL provide wastewater services.

The latest estimate of GHG emissions for operational carbon as a result of providing drinking water to customers in the Essex and Suffolk operating area is 44,550 tonnes CO₂e (2017 figure in Table 6.14). The emissions intensity of the provision of water services is 284kg CO₂e/MI. This is significantly higher than the emissions intensity of our operations in the Northumbrian operating area. However, it is good in comparison with our neighbours in the lower lying southern half of the country. This emissions intensity is lower than Affinity Water, Anglian Water, Severn Trent, Southern, South West and Wessex Water. Only Thames Water of the larger companies within the south has a lower emissions intensity.

Table 6.14: Drinking Water Emissions Table

Date	2008	2017	2025	2045
Tonnes CO ₂ e	59,962	44,550	21,500	12,200


We expect emissions to continue to fall, partly as a result of our own efforts, and partly as a result of falling emissions linked to grid electricity. Most of our emissions result from our use of grid derived power. The proposed closure of the UK's coal powered generation plant by 2023, combined with a growing capacity of renewable energy, means that grid emission factors are likely to fall by half by 2025, then halve again by 2045. The future emissions projections reflect this.

We have no projects for the further development of water resources in our Plan, and no consideration of options or the carbon emissions resulting from them has been necessary.

6.11 The Impact of our Planned Actions on Carbon Emissions

We have provided elsewhere in this plan a descriptive account of the environmental impacts of our planned actions, including those relating to carbon emissions. Here we set out the impact in quantitative terms.

Overall we expect to see our emissions increase over the period of the plan as a result of the actions we propose. How the emissions relating to plan will change over the period through to 2045 is shown in the chart below. Savings are viewed as positive; the negative figure indicates an increase in emissions. This will peak in 2027-28, then fall thereafter.



The overall increase is small, peaking at a little more than 130 tonnes CO2-e annually. To understand the small scale of this increase, our emissions for the water service for ESW were around 45,000 tonnes in 2017-18. The impact of the plan proposals adds less than 0.3% on the same basis.

However, any increase in emissions might seem surprising given that the proposals will reduce demand and with it the volume of water we need to supply. As such the projected increase requires explanation.

The main reason for the rise is that from 2018-19 there will no longer be any emissions linked to our use of electricity. This follows a switch in our energy supplier to Orsted who provide all their power from renewable sources.

Our emissions have fallen considerably since we first started routinely calculating these in 2008. Whilst some of this fall is due to actions we have taken to be more efficient in our use of energy, or through the development of low carbon renewable energy, much of this reduction has come from lower emissions linked to our use of grid electricity.

Grid electricity use has to date been by far the biggest single component of our greenhouse gas emissions. In recent years the emissions value linked to each unit of electricity has been falling, as coal fired power stations have been replaced with cleaner gas and renewable power generation. This is set to continue and by the middle of this century the emissions linked to electricity use will be a small fraction of what they are today.

Some electricity suppliers are leading this switch to low emissions energy, which is a growing market in the electricity supply industry. In 2015, in order to encourage this growing provision, international and national reporting protocols were changed to allow purchasers of cleaner energy to reflect the lower emissions attached to it in their reporting, as long as the emissions were backed with certification of origin. We are in a position to adopt this approach going forward.

Our 2017-18 baseline emissions linked to the supply of drinking water within the ESW region we estimate to be 43,973 tonnes CO₂-e. This equates to 267 kgs CO₂-e for every Ml put into supply.

Most of these emissions are associated with the use of grid electricity. These are mainly Scope 2 emissions directly linked to the use of power in support of our operations, but include some Scope 3 emissions reflecting losses in the transmission and distribution of electricity to our sites.

In April 2018 we switched electricity supplier and are now supplied by Orsted, one of the companies leading the transition to a decarbonised energy sector. As a result our baseline emissions going forward reduce significantly.

We expect the emissions linked to the provision in water in ESW to be in the order of just 4,500 tonnes CO₂-e this reporting year (2018-19), then continue to fall through to 2027-28 when we expect to become net carbon zero. This is the point at which our operational activities no longer add to the problem of global warming. 4,500 tonnes will mean around 27 kgs CO₂-e for every Ml of water into supply.

This change has a major impact on our estimate of the emissions impact of our water resources plan. Although we have no supply side proposals in our plan, we will undertake a range of activities that will help to manage demand, under the three headings of leakage management, water efficiency and metering. For each of these areas we have assessed the impact of our proposed actions on the greenhouse emissions for which we are responsible.

Each of our proposed actions will deliver a saving in the volume of water we need to supply, and with that there will be a fall in emissions in the early years until we become carbon neutral. After that point any saving in water will not produce a reduction in emissions. Even in the early years of the plan the fall in emissions we will see will be a much smaller effect than had we continued to use the UK national grid emissions factor, because of the switch in our reporting approach.

Alongside this effect, with some of the actions there will be an increase in operational activity that might increase emissions. An example would be the employment of more technicians to find and fix leaks. Such staff will increase our emissions through their use of vehicles and vehicle fuel in carrying out their duties.

In each case the emissions linked to the action is changing over time. In the case of leakage technicians the development of cleaner vehicle technologies will mean that the emissions for a given level of activity will fall over time. We have made an assumption about the pace of this fall.

It is the effect in emissions terms of these two counter-acting factors that determines the projected emissions impact going forward, and results in the rise we expect to see. Had we continued to use the national grid factor our programme of work would have produced, in any year of the plan, a saving in grid related emissions of around twenty times the increase resulting from the work involved.

Emissions impact of each proposed measure

Within this overall context of the impact of our proposals on greenhouse gas emissions we can also quantify this for each specific measure proposed in our plan. There are no supply side proposals needed within the timeline of the plan. We do though have demand side proposals in the three areas of demand management, leakage management and metering. The way that these contribute to the overall carbon impacts previously set out is shown in the chart and table below.

The chart shows how each the proposed actions contributes to the change in overall emissions year by year. The table summarises this information for each future five year AMP period through to 2045.




Table showing impact on GHG emissions of each demand side proposal

	AMP7	AMP8	AMP9	AMP10	AMP11
	2020-2025	2025-2030	2030-2035	2035-2040	2040-2045
Leak management	-43.6	-454.6	-445.1	-382.2	-328.2
Water efficiency	-60.3	-131.1	-126.1	-108.3	-93.0
Metering	11.5	3.6	0.0	0.0	0.0
Combined net saving	-92.5	-582.1	-571.2	-490.5	-421.2

Valuing these carbon impacts

Alongside quantification of the impact in emissions terms we have also examined the economic impact of what we propose. Applying the latest projected carbon values published by UK government in line with the Treasury Green book there is a progressive rise in the carbon cost of the proposed programme of work. That said, by 2045 the carbon cost of the programme remains small, not even reaching £15,000 a year by the year 2045. Unsurprisingly, the value of carbon has no impact on decisions relating to the WRMP. This is true both in overall terms and for each of the proposed measures.

6.12 The Impact of Climate Change on the Proposed Measures

As well as examining how our proposals will impact on the greenhouse emissions that drive climate change, we have also considered what the implications for climate change might be on our proposed actions. We have looked at the potential impact on each of the demand side measures we propose on demand management, leakage management and metering.

Both for demand management and for metering we identify that any changes in climate will have no impact at all on our proposals. The actions we are taking are independent of any climatic effects.

Climate change may have an impact on future leakage, but no allowance has been made for this in this plan. The reasoning behind this assumption is set out below.

The predicted future climate is one of hotter drier summers and warmer wetter winters. More frequent and severe droughts are also expected. This has the potential to lead to changes in ground movement in clay based soils, which in turn can have an impact on burst frequency and leakage. In summer this movement is likely to increase burst frequency and leakage. Warmer winters will mean that freeze-thaw events causing ground movement will be less frequent. This means that burst frequency and leakage in winter is likely to fall.

This understanding is based on work undertaken in 2009 (Making the Earth Move: Modelling the impact of climate change on water pipeline serviceability by Goodchild, Rowson and Engelhardt). This established a relationship between burst frequency and actual evaporation, daily rainfall, minimum grass temperature, and soil moisture deficit. A change in burst frequency implies similar changes in leakage.

However, this relationship only holds for asbestos cement and cast iron pipes in clay and loam soils. This pipe/soil combination is seen only across a small proportion of our network, a figure that is falling as these older pipes are replaced. With other combinations of pipe and soil there is no established effect.

The quantification of these impacts that act in opposite directions across the seasons is not straightforward. In the short run the changes in temperature and their impact on soils will be too small to have a significant impact. It is only towards the end of the plan period that the potential effect will be greater, though even here this impact will be mitigated as the proportion of polyethylene pipe in the network grows as cast iron and asbestos cement pipe is replaced.

The analysis undertaken suggests that in the Essex and Suffolk region there would be a net increase in bursts. The projected decrease in winter bursts is more than balanced by an increase in summer.

In this plan we have not included for this impact. Instead we have assumed that leakage will not be affected by this climate driven effect. There are two reasons for this.

Firstly, as yet we are also unable to quantify the impacts of two other proposed actions to lessen leakage. These are the development of innovative techniques and customer-focused activities, which are neither defined at this stage, or their impacts quantified. We have allowed for no impact of either of these planned actions in reducing leakage, and have made the assumption that they will not be affected by the changing climate.

This assumption feeds into the second reason in that the Ofwat target for leakage is no longer based on an assessment of what is an economic level of leakage where the marginal cost of additional management actions equates to the value of water saved. Instead a fixed target is set. We intend to meet this target by a range of actions. With two of these – the deployment of new pressure management schemes and the installation of new semi-permanent correlating noise loggers – we are able to estimate the impact. However, this is not the case with either innovative techniques or customer-focused activities.

Any further leakage reduction to achieve the Ofwat target that exists after taking these actions will be met by a change in the rate of mains replacement. This is scheduled to take place from AMP 8. The impact of changes in the climate will be one underlying driver that affects the scale of replacement work needed. The success of the innovative techniques and customer-focused actions is another.

However, the leakage levels seen will not change. Instead we will vary the amount of mains replacement needed, to the extent required to hit the leakage target. As a result we are able to assume that the level of leakage will not be impacted by climate change, although our responses in terms of mains replacement may be. This also means that there is no wider impact on supply and demand.

7.0 TARGET HEADROOM



7.1 Background

Actual headroom is the difference between the supply and demand forecasts of the supply demand balance (i.e. the difference between the Water Available For Use (WAFU) and the constrained dry weather demand forecast). A water company would ideally like WAFU to be greater than the demand forecast to allow for uncertainty and ensure it can meet demand.

The 'ideal' amount of actual headroom that a prudent water company should retain is called target headroom. Target headroom can be thought of as a security margin, or more accurately a means of assessing uncertainty in the supply demand balance.

The Agency's WRPG (Environment Agency, 2008 and Environment Agency, 2013) define target headroom as:

"the threshold of minimum acceptable headroom, which would trigger the need for total water management options to increase WAFU or decrease demand"; and

"a buffer between supply and demand designed to cater for specified uncertainties. Water companies should adopt a well-informed approach to determining target headroom. This should balance the costs and risks to customers and the

environment of a low headroom allowance against those of a high headroom allowance”.

An alternative definition provided by UKWIR and the Agency in 1998 (UKWIR, 1998) for target headroom is: “the minimum buffer that a prudent water company should allow between supply (including raw water imports and excluding raw water exports) and demand to cater for specified uncertainties (except those due to outage) in the overall supply-demand balance. Introducing this buffer into the overall supply-demand balance will help to ensure that the Company’s chosen level of service can be achieved”.

A probabilistic approach to determining target headroom in all four of our resource zones was adopted for the PR09, utilising the industry standard methodology produced in 2002 (UKWIR, 2002). This probabilistic approach was used for PR14 and has been used again for the current periodic review in all four of our resource zones.

A description of the methodology, the results produced and their interpretation has been outlined in an internally produced report. The assessment has already been completed and is summarised below.

7.2 Methodology

The 2002 headroom methodology (UKWIR, 2002) introduces the concept of ‘headroom uncertainty’, which is defined as:

“a probability distribution that represents a likely range of values for headroom for selected years within the planning period”.

Inherent in the definition is the need to make choices from the probability distribution on the level of risk (or degree of uncertainty), that a water company is prepared to accept in relation to headroom. This is necessary in order to define a value for target headroom for each resource zone for each year across the planning horizon, suitable for incorporation in the supply demand balance. The calculation of headroom uncertainty is required over the planning horizon from 2016/2017 to 2059/2060. However, as headroom uncertainty is forward-looking, the calculation of headroom uncertainty has commenced in 2018/2019.

The basis of the 2002 methodology (UKWIR, 2002) is to apportion target headroom into two main areas; supply side and demand side. For all four resource zones these areas can then be subdivided into respective supply or demand side components indicated as follows:

Supply Side Headroom Components

- S3 Uncertainty of renewal of time-limited licences
- S4 Bulk imports

- S5 Gradual pollution of sources causing a reduction in abstraction
 - S6 Accuracy of supply side data
 - S8 Uncertainty of impact of climate change on deployable output
 - S9 Uncertainty of new sources
- Demand Side Headroom Components

- D1 Accuracy of sub-component demand data
- D2 Demand forecast variation
- D3 Uncertainty of impact of climate change on demand
- D4 Uncertainty of demand management measures

Two additional supply side components known as S1 (vulnerable surface water licences) and S2 (vulnerable groundwater licences) have not been included at the request of the Environment Agency, and as indicated in the WRP (Environment Agency, 2017a). This is because the Environment Agency has stated that no allowance should be included for uncertainty related to sustainability changes to permanent licences, as they will work with us to ensure that these do not impact security of supply (Environment Agency, 2017a).

An additional supply side component, S3 (uncertainty of renewal of time-limited licences), has been included since the last periodic review assessment. The Environment Agency has stated that an allowance for uncertainty related to non-replacement of time-limited licences on current terms may be included, which should be based on assessment of environmental risks (Environment Agency, 2017a), and that time-limited licences should be reviewed before they expire and any risks to replacement on existing terms assessed (Environment Agency, 2017a).

All components are associated with sources within our four resource zones, with the exception of the supply side component S4, which considers the bulk supply from Thames Water Utilities (TWU).

Supply side components generally require the identification of individual groundwater or surface water sources, which are likely to be impacted. The only exception is the accuracy of supply side data (S6), which groups sources according to the factor constraining DO of the source. Demand side components are considered on a holistic basis for each resource zone.

To formally document all the sources identified under each supply side component and all demand side components, the methodology makes use of 'Headroom Issues Proforma' spreadsheets, which contain details of each identified headroom component for a particular resource zone. The proformas allow each component to be uniquely identified and relationships between components to be defined.

Where a component is not independent, the UKWIR methodology (UKWIR, 2002) and Crystal Ball[®] allows for overlapping, correlated and dependent relationships to be included in the headroom calculation. These relationships are determined as follows:

- Overlapping or mutually exclusive relationships ensure that it is only possible for the DO of a source to be lost once. Each component is assessed independently before taking the largest value selected from two or more overlapping components.
- Correlating data allows a variety of relationships to be defined between two or more components. For example groundwater sources at different locations may abstract from the same aquifer and therefore face similar sustainability issues or risks from pollution. A correlation coefficient is applied to describe the relationship between the different sources.
- A dependent relationship occurs when a source's headroom uncertainty is dependent on the uncertainty at another source. No dependent relationships occur between any headroom components associated with us and consequently dependent relationships were not used in any of the headroom uncertainty calculations.

A summary of the assumptions used to assess the uncertainty for each supply side and demand side headroom component is provided below.

Supply Side Components

- S3 All of our time-limited groundwater sources have been reviewed and any risks to replacement have been assessed on existing terms. Consequently the time-limited groundwater sources to be investigated as part of the Water Industry National Environment Programme (WINEP), where the DO would be reduced should there be a sustainability reduction imposed, have been included in S3. This uncertainty has been included from 2027/28 onwards as this is the first year that any reduction in DO would apply.
- S4 The Chigwell bulk import was split into two sub-components. This was to enable the inclusion of two key points within the agreement between ourselves and TWU:
- Should TWU enforce a temporary water use ban but we do not, the quantity supplied to us is reduced by 25%;
 - Should both water companies have a temporary use ban in place and TWU enforces a drought order ban, a fair apportionment of supply would take place.

The levels of service for both water companies were used to determine the risk of loss of DO from the Chigwell bulk import, across the whole planning horizon.

- S5 All of our groundwater sources were included as being at risk from pollution, with the headroom uncertainty for each source separated into point and diffuse pollution. Catchment risk assessment work undertaken by us was used to determine the uncertainty of point and diffuse pollution at all of our groundwater sources. The calculation of the uncertainty of point pollution additionally made use of the number of petrol and diesel storage sites within the total groundwater protection zone of each groundwater source.

The uncertainty of dead storage in reservoirs and risk of saline intrusion was also accounted for within S5.

- S6 All of our groundwater and surface water sources and the Chigwell bulk supply were grouped according to the factor constraining DO. The accuracy of supply side data was determined for each of the following:
- aquifer constrained sources, using the combined accuracy of abstraction meters and water level transducers;
 - licence constrained sources, using the accuracy of abstraction meters;
 - infrastructure constrained sources, subdivided into pump capacity and Water Treatment Works accuracy, using accuracy of pumps and Water Treatment Works output meters, respectively.
- S8 The DO for all of our groundwater and surface water sources was assessed for the impact of climate change. All sources determined as being potentially impacted were included in the uncertainty of impact of climate change on DO. Further information on climate change can be found in chapter 6 of this report.
- S9 All potential new groundwater and surface water sources would be included to ensure sufficient resources within each resource zone over the planning horizon. This component was not relevant for our four water resource zones.

Demand Side Components

- D1 The accuracy of distribution meters was used to determine the accuracy of sub-component demand data for each of our resource zones, on a holistic basis.
- D2 Distribution Input (DI) was subjected to a statistical technique known as the Maximum Likelihood Estimation (MLE), which took into account the difference between recorded DI and the sum of all its components, with the aim to make these figures reconcile as closely as possible. The uncertainty surrounding the dry year distribution input for each of the four resource zones was used to determine the demand forecast variation.
- D3 The 'Impact of Climate Change on Demand' project results and report (UKWIR, 2013) were used to calculate forecasts of climate change impacts on household water demand and to quantify the impact of climate change on demand. The uncertainty of impact of climate change on demand was defined using 50th and 90th percentile to determine the best estimate and maximum values, and the minimum uncertainty assigned as zero. Further information on climate change can be found in chapter 6 of this report.
- D4 The uncertainty of demand management measures for each of our water resource zone was determined for each of the following:

- Delivering the meter strategy, using the number of meters forecast to be installed;
- Leakage, using historical data to determine the expectancy of meeting our leakage targets;
- Water efficiency, using the likelihood of our current water efficiency targets.

Further Elements of Methodology

Uncertainties have been assessed for every year within the planning horizon.

Once information on the sources of uncertainty for each headroom component had been collated, a probability distribution was defined for each of the components uniquely identified in the Issues Proforma spreadsheets. To define the probability distribution, information was sought from relevant reports, data and expert knowledge within our organisation as to the most appropriate type to best fit the data and situation.

Probability distribution profiles can be continuous or non-continuous. In many circumstances continuous distributions will be more appropriate for assessing headroom uncertainty. These allow any value between the stipulated values to be applied to the probability, whereas a non-continuous distribution only allows probability to be determined for the particular values stipulated.

An 'Input Proforma' spreadsheet was completed for each individual headroom component identified within the Issues Proforma spreadsheets, in order to allow the data, probability distributions and specific parameters to be documented and the decisions for these choices to be transparent and auditable. The sheets include specific sections to document meetings and discussions used to progress the particular component, relevant reports and data applied.

The individual headroom components were grouped on a resource zone basis and inserted into a purpose-built spreadsheet produced by Mott MacDonald as part of the UKWIR project (UKWIR, 2002). The probability distributions, parameters and relationships between components form the basis of the Monte Carlo simulation, which determines the overall Headroom Uncertainty by adding the individual headroom components together. The software package Crystal Ball (Release 11.1.2.4.850) was used within the spreadsheet environment to allow the Monte Carlo simulations to be run. When run, Monte Carlo randomly selects numbers from the probability distribution assigned to each component, effectively simulating a 'what if' scenario. The Monte Carlo simulation derives headroom uncertainty for each year within the planning horizon. The simulation was run through 10,000 iterations for each of our four resource zones, in order to gain a suitable level of consistency in the results.

The Monte Carlo simulation was re-run excluding the climate change components S8 (uncertainty of impact of climate change on DO) and D3 (uncertainty of impact of climate change on demand) for each of our four resource zones. The headroom

uncertainty figures with and without climate change were compared for every year within the planning horizon to analyse the significance of climate change.

The data and assumptions made for each of the elements of headroom are discussed further in our PR19 Headroom Calculations report (Essex & Suffolk Water, 2017d), and should be referred to for additional information.

7.3 Form of Output – Trend Charts and Sensitivity Analysis

The results from the Monte Carlo simulation are expressed in terms of percentiles for every year within the planning horizon, for each of the four resource zones.

7.3.1 Trend Charts

The percentile envelopes of headroom uncertainty can be plotted in Crystal Ball® as a ‘headroom uncertainty trend chart’, which indicates how the uncertainty in headroom varies throughout the planning horizon, under the analysis for each resource zone. The headroom uncertainty trend chart for the Essex WRZ is provided below by way of an example.




Figure 7.1: Headroom uncertainty trend chart for the Essex WRZ

When interpreting such Crystal Ball® trend charts it should be recognised that, as in the above example:

- Headroom uncertainty has been defined for all years within the planning horizon;
- The various certainty bands indicated are represented by all the range of values between and including the indicated upper and lower bounds;

- The certainty bands above are not the same as percentiles but are related as follows:
 - The 10% certainty band in red equates to the difference between the 45th and 55th percentile (i.e. 5% either side of the median value);
 - Similarly the junction between the yellow and blue shaded areas is the 80th percentile at the top of the chart and the 20th percentile at the bottom of the chart;
- Upper percentiles have been considered as choices for target headroom.

When determining which of the upper percentiles of headroom uncertainty should be used for target headroom, we have recognised that this choice is important given that it reflects the level of risk we are willing to accept. It should be recognised that this choice may directly affect investment decisions and the driving supply demand balance scenario. The upper percentiles reflect return periods as indicated in the following table:

Table 7.1: Upper percentiles and return periods

Percentile	Return Period
50	1 in 2
75	1 in 4
80	1 in 5
90	1 in 10
95	1 in 20
96	1 in 25
98	1 in 50

The return periods can be viewed as the probability for each year of headroom uncertainty not falling within a respective defined envelope.

We have chosen to adopt the 90th percentile until 2024/25 and then a decreasing percentile each year throughout the planning horizon to the 55th percentile in 2059/60. We therefore accept an increasing risk over the time period that required headroom falls outside the range of values indicated in the headroom uncertainty trend chart. This is in accordance with the Environment Agency’s 2017 WRP which states that water companies ‘should accept a higher level of risk further into the future than in the early years because as time progresses the uncertainties for which headroom allows will reduce’ and the water company will be able to adapt to any changes (Environment Agency, 2017a).

7.3.2 Sensitivity Analysis

The UKWIR methodology includes an inherent assumption that all components identified are of an equal weighting unless related through overlapping, correlations or dependency. The creation of sensitivity charts from the Monte Carlo simulation allows sensitivity analysis to be performed for each component through the use of correlation coefficients. An individual sensitivity chart has been created for the end of each AMP over the planning horizon, for each resource zone. The sensitivity chart for Essex WRZ in 2044/45 is presented below by way of an example.




Figure 7.2: Sensitivity 2044/45

The components (e.g. BS246) identified in the sensitivity charts in Crystal Ball® refer to the specific cell reference number in the Monte Carlo spreadsheet used for the particular resource zone being considered.

The UKWIR 2002 methodology (UKWIR, 2002) suggests the checking of headroom components contributing to over 25% of overall uncertainty, to ensure they are realistic. Where sensitivity analysis has highlighted such components, stringent checking has occurred and it has been determined that the parameters input to the probability distributions are realistic. Where a headroom component contributes over 50% to overall headroom uncertainty, the methodology suggests that further investigations to confirm or refine estimates may be justified. This does not apply to any of our four resource zones investigated as the sensitivity charts do not highlight any contributions over 46.1%.

The sensitivity charts created for the last year of each AMP (i.e. end of each five year period) throughout the planning horizon have been analysed for each resource zone. The ten most significant components in each sensitivity chart have been identified, and their variation in contribution across the planning horizon assessed. These results are displayed as tables within this section.

7.4 Headroom Uncertainty Results

The results of the headroom assessment for each resource zone are indicated on the following pages, along with explanatory text. In understanding this assessment the following should be taken into account:

- (i) The assessment of headroom uncertainty has been a major undertaking for us and represents a significant body of work.

- (ii) S1 (vulnerable surface water licences) and S2 (vulnerable groundwater licences) have not been included in the assessment. This is because the Environment Agency has stated that no allowance should be included for uncertainty related to sustainability changes to permanent licences, as they will work with us to ensure that these do not impact security of supply (Environment Agency, 2017a).
- (iii) To some extent the headroom assessment anticipates the likely water resource management options to be employed in the final planning scenario. This is unavoidable since element S9 of the headroom assessment specifically relates to quantifying uncertainty of new sources. We have previously identified this as a potential weakness of the current UKWIR headroom uncertainty methodology. However S9 was not relevant for the draft Final PR19 target headroom assessment as no water resource management options are anticipated within our four WRZs over the planning horizon.
- (iv) The following pages give a general overview, and our PR19 Headroom Calculations report (Essex & Suffolk Water, 2017d) should be consulted in order to obtain the complete picture.

7.4.1 Headroom Uncertainty Results – Essex Resource Zone




Figure 7.3: Essex headroom uncertainty

Explanatory Text

By reference to the upper 80%, 60% and 40% certainty bands:

- The gradual rise from 2018/19 to 2059/60 is largely due to the impact of demand forecast variation and also meter uncertainty.

Target Headroom Range

Using the chosen percentiles the target headroom accepted ranges from 33.48 MI/d in 2018/19 to 18.33 MI/d in 2059/60. This represents 7.63% and 3.98% of WAFU in 2018/19 and 2059/60, respectively.

Sensitivity Analysis – Essex Resource Zone

Essex: Percentage Significance of Components

Table 7.2: Essex Resource Zone Percentage Significance of Components

Component Reference	Component/Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
D2/1	Demand forecast variation	35.9	34.9	34.3	33.3	31.4	31.8	32.0
S6/2	Meter uncertainty for licence constrained sources	29.1	30.0	30.9	31.3	30.9	28.9	26.7
D1/1	Uncertainty of distribution input arising from meter inaccuracy	13.8	12.5	12.9	11.7	12.5	12.3	10.9
S4/1	Chigwell Bulk Supply (Temporary Use Ban)	5.8	5.6	5.7	6.7	5.7	5.0	4.9
S8/7	Uncertainty of impact of climate change on Essex System	1.6	2.0	2.6	3.0	4.1	4.5	6.3
D4/1(iii)	Uncertainty of impact of demand management - Water Efficiency	-1.5	-1.4	-1.2	-1.2	-1.4		-1.4
D4/1(ii)	Uncertainty of impact of demand management - Leakage	-1.5	-1.3	-1.4	-1.0	-0.9	-1.4	
D4/1(i)	Uncertainty of impact of demand management - Metering	-1.3	-1.6	-1.0	-1.1	-0.9	-1.2	-1.5
D3/1	Uncertainty of impact of climate change on demand	0.9	1.2	1.5	1.6	2.3	2.8	4.2
S8/1	Uncertainty of impact of climate change on Roding	0.5	0.4	0.8		0.9	1.2	1.5
S8/3	Uncertainty of impact of climate change on Stifford				0.6		-1.2	1.6

N.B. The ten most significant components in each year were analysed.

Key

<=5%	
>5 - 15%	
>15 - 25%	
>25%	

Explanatory Text

- Throughout the planning horizon demand forecast variation contributes the greatest proportion of overall uncertainty, with the significance of this component gradually decreasing from 35.9% in 2019/20 to 32.0% in 2059/60. It is considered realistic that demand forecast variation is a significant factor of uncertainty in the Essex resource zone.
- The significance of meter uncertainty for licence constrained sources varies from 29.1 MI/d in 2019/20 to 26.7 MI/d in 2059/60. This is considered realistic considering that the Essex System, which is licence constrained forms a significant proportion of the total Essex WRZ DO.
- The significance of the uncertainty of supply and demand climate change components gradually increases over the planning horizon. The uncertainty of the impact of climate change on the Essex System uncertainty increases over the planning horizon, from 1.6% in 2019/20 to 6.3% in 2059/60. This significance is considered realistic.

7.4.2 Headroom Uncertainty Results – Suffolk Blyth Resource Zone




Figure 7.4: Blyth Headroom Uncertainty

Explanatory Text

By reference to the upper 80%, 60% and 40% certainty bands:

- There is general trend of a small gradual increase in headroom uncertainty over the planning horizon. This is largely due to demand forecast variation and the risk of loss of DO due to gradual pollution.

Target Headroom Range

Using the chosen percentiles the target headroom accepted ranges from 1.28 MI/d in 2018/19 to 0.73 MI/d in 2059/60. This represents 9.74% and 5.54% of WAFU in 2018/19 and 2059/60, respectively.

Sensitivity Analysis – Suffolk Blyth Resource Zone

Suffolk Blyth: Percentage Significance of Components

Table 7.3: Suffolk Blyth Resource Zone Percentage Significance of Components

Component Reference	Component/Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
D2/2b	Demand forecast variation	34.9	35.4	31.4	33.0	32.1	31.8	33.7
D1/2b	Uncertainty of distribution input arising from meter inaccuracy	13.0	12.8	11.4	12.2	11.4	11.2	12.7
S5/15b	Risk of loss of DO due to diffuse pollution at Benhall	8.1	7.6	8.5	7.3	8.1	9.0	8.0
S5/20b	Risk of loss of DO due to diffuse pollution at Little Glemham	7.9	7.7	8.9	8.2	9.2	8.6	7.8
S5/20a	Risk of loss of DO due to point pollution at Little Glemham	4.0	4.1	4.6	4.1	4.3	4.5	4.0
S5/15a	Risk of loss of DO due to point pollution at Benhall	4.0	4.2	4.1	4.3	4.1	4.1	3.7
S5/18a	Risk of loss of DO due to point pollution at Coldfair Green	3.7	3.5	4.0	3.6	3.7	3.7	3.2
S5/14a	Risk of loss of DO due to point pollution at Walpole	3.6	4.0	3.6	3.8	4.1	4.0	3.9
S5/19a	Risk of loss of DO due to point pollution at Leiston	3.5	3.4	3.4	3.8	3.3	3.6	3.3
S6/6b	Meter uncertainty for licence constrained sources	2.7		3.4	2.9		3.1	2.8
S5/14b	Risk of loss of DO due to diffuse pollution at Walpole		2.6			3.0		

N.B. The ten most significant components in each year were analysed.

Key

<=5%	
>5 - 15%	
>15 - 25%	
>25%	

Explanatory Text

- Throughout the planning horizon demand forecast variation contributes the greatest proportion of overall uncertainty, with the significance of this component being 34.9% in 2019/20 to 33.7% in 2059/60. It is considered realistic that demand forecast variation is a significant factor of uncertainty in the Blyth resource zone.
- The combined uncertainty of risk of loss of DO due to gradual pollution is a significant component throughout the planning horizon. This is considered realistic due to the Blyth being purely a groundwater fed water resource zone.

7.4.3 Headroom Uncertainty Results – Suffolk Hartismere Resource Zone




Figure 7.5: Hartismere Headroom Uncertainty

Explanatory Text

By reference to the upper 80%, 60% and 40% certainty bands:

- Generally there is a small gradual increase over the planning horizon, which is largely due to the uncertainty of demand forecast variation, and also due to uncertainty of distribution input arising from meter inaccuracy and risk of loss of DO due to gradual pollution.

Target Headroom Range

Using the chosen percentiles the target headroom accepted ranges from 0.80 MI/d in 2018/19 to 0.46 MI/d in 2059/60. This represents 8.27% and 4.82% of WAFU in 2018/19 and 2059/60, respectively.

Sensitivity Analysis – Suffolk Hartismere Resource Zone

Suffolk Hartismere: Percentage Significance of Components

Table 7.4: Suffolk Hartismere Resource Zone Percentage Significance of Components

Component Reference	Component/Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
D2/2a	Demand forecast variation	44.9	46.1	44.6	42.8	44.3	44.2	45.2
D1/2a	Uncertainty of distribution input arising from meter inaccuracy	16.1	16.6	16.5	16.4	16.1	16.7	16.5
S5/13a	Risk of loss of DO due to point pollution at Bleach Green	4.8	3.5	3.8	4.2	3.8	4.0	3.6
S5/8b	Risk of loss of DO due to diffuse pollution at Wortham	4.6	5.0	5.5	5.3	5.6	5.4	5.0
S5/10a	Risk of loss of DO due to point pollution at Syleham	4.2	3.8	3.9	5.3	4.2	3.9	3.7
S6/5a	Infrastructure constrained sources - Uncertainty for WTW capacity	3.7	3.6	3.3	2.9	2.9	3.3	3.3
S5/8a	Risk of loss of DO due to point pollution at Wortham	3.7	4.1	4.4	4.3	4.2	4.2	4.0
S6/6a	Meter uncertainty for licence constrained sources	3.2	2.6	3.1	2.9	3.2	3.3	3.1
D4/2a (iii)	Uncertainty of impact of demand management - Water Efficiency	-2.0		-1.9	-1.9			-1.8
D4/2a(i)	Uncertainty of impact of demand management - Metering	-2.0	-1.8		-2.1	-2.1	-2.2	
D4/2a(ii)	Uncertainty of impact of demand management - Leakage		-2.2	-1.8		-2.1	-1.8	-2.3

N.B. The ten most significant components in each year were analysed.

Key

<=5%	
>5 - 15%	
>15 - 25%	
>25%	

Explanatory Text

- Throughout the planning horizon demand forecast variation contributes the greatest proportion of overall uncertainty, with the significance of this component remaining fairly constant at 44.9% in 2019/20 and 45.2% in 2059/60. It is considered realistic that demand forecast variation is a significant factor of uncertainty in the Hartismere resource zone.
- The significance of uncertainty of distribution input arising from meter inaccuracy and risk of loss of DO due to gradual pollution remains almost constant over the planning horizon.
- It is considered realistic that the components mentioned above are the most significant factors of uncertainty in the Hartismere WRZ.

7.4.4 Headroom Uncertainty Results – Suffolk Northern Central Resource Zone




Figure 7.6: Northern Central Headroom Uncertainty

Explanatory Text

By reference to the upper 80%, 60% and 40% certainty bands:

- There is a step increase in 2020/21 due to the inclusion of uncertainty surrounding saline intrusion at Northern Central Borehole 11 from this year onwards;
- From 2021/22 to the end of the planning horizon there is a gradual increasing trend, partly due to the increasing significance of the uncertainty of the impact of climate change on supply and demand.

Target Headroom Range

Using the chosen percentiles the target headroom accepted ranges from 4.81 MI/d in 2018/19 to 3.99 MI/d in 2059/60. This represents 6.82% and 5.64% of WAFU in 2018/19 and 2059/60, respectively.

Sensitivity Analysis – Suffolk Northern Central Resource Zone

Suffolk Northern Central: Percentage Significance of Components

Table 7.5: Suffolk Northern Central Resource Zone Percentage Significance of Components

Component Reference	Component/Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
D2/2c	Demand forecast variation	35.1	32.5	28.7	26.6	25.0	23.1	19.0
D1/2c	Uncertainty of distribution input arising from meter inaccuracy	12.5	12.5	10.8	8.7	8.7	8.9	6.9
S8/36	Uncertainty of impact of climate change on Waveney	9.3	11.1	14.0	15.5	16.0	17.2	21.0
D3/2c	Uncertainty of impact of climate change on demand	6.3	6.4	8.7	9.7	10.9	11.2	13.9
S8/33	Uncertainty of impact of climate change on Ormesby	3.1	4.0	5.2	5.7	6.3	6.1	8.6
S8/35	Uncertainty of impact of climate change on Lound	3.2	3.8	5.1	5.3	5.7	6.0	8.1
S5/26a	Risk of loss of DO due to point pollution at Barsham	3.2	2.8	2.6	2.5	2.8	2.7	2.4
S5/28a	Risk of loss of DO due to point pollution at Barsham Hall	2.6	2.6	2.4	2.8	2.5	2.8	2.1
S5/31a	Risk of loss of DO due to point pollution at Shipmeadow (Nunnery Farm)	2.2	2.1	2.3	1.9	1.9	2.0	2.1
S5/27a	Risk of loss of DO due to point pollution at Puddingmoor		2.0		1.8	1.7	1.7	1.4
S6/6c	Meter uncertainty for licence constrained sources	2.1		1.8				

N.B. The ten most significant components in each year were analysed.

Key

<=5%	
>5 - 15%	
>15 - 25%	
>25%	

Explanatory Text

- At the beginning of the planning horizon demand forecast variation contributes the greatest proportion of overall uncertainty, at 35.1%. The significance of this component gradually decreases over the planning horizon, to 19.0% in 2059/60;
- The significance of the risk of loss of DO due to gradual pollution generally decreases between 2019/20 and 2059/60;
- The contribution of uncertainty of impact of climate change on supply and demand gradually increases over the planning horizon. For example, the significance of uncertainty of impact of climate change on the River Waveney increases from 9.3% in 2019/20 to 21.0% in 2059/60.
- The larger significance of the uncertainty of impact of climate change on the River Waveney when compared to the Draft WRMP assessment is due to the River Waveney DO being recalculated and increasing following the Draft WRMP.
- It is considered realistic that the components mentioned above are the most significant factors of uncertainty in the Northern Central WRZ.

7.5 Sensitivity Analysis of Climate Change

The difference between the headroom figures with and without climate change components was found to be less at the beginning of the planning horizon than at the end in all WRZs. This is as expected due to the increasing impact of climate change throughout the planning period.

In the Essex and Northern Central WRZs the difference between the headroom figures with and without the climate change components in 2059/60 was found to be 6.04 Ml/d and 1.13 Ml/d, which equated to 32.93% and 28.29%, respectively, of the target headroom figure with the climate change components. This is due to the increasing impact of climate change on source yields in the WRZs over the planning horizon.

In the Blyth and Hartismere WRZs the difference between the headroom figures with and without the climate change components was found to be much lower than in the Essex and Northern Central WRZs. In 2059/60 the difference between the headroom figures with and without the climate change components in the Blyth and Hartismere WRZs was found to be 0.05 Ml/d and 0.04 Ml/d, which equated to 7.25% and 8.06%, respectively, of the target headroom figure with the climate change components. This is due to there being no impact of climate change on source yields and a small impact of climate change on demand.

The impact of climate change on the baseline supply demand balance is explained in more detail in chapter 8.

7.6 Comparison with 2009 Periodic Review (PR09)

The following table provides comparison between the above results (for PR19) and those determined for PR14:

Table 7.6: Comparison of Headroom Uncertainty PR14 and PR19

Zone	Headroom Uncertainty (Ml/d)				
	PR14 base year	PR19 base year	PR14 end of planning horizon	PR19 2044/45	PR19 end of planning horizon
Essex	29.52	33.48	33.02	22.50	18.33
Blyth	1.33	1.28	1.39	0.86	0.73
Hartismere	0.62	0.80	0.66	0.56	0.46
Northern Central	4.10	4.81	5.70	4.38	3.99

The target headroom in the base year for each resource zone is higher for PR19 than PR14 for all water resource zones except Blyth WRZ. The target headroom determined at the end of the 25-year planning horizon (2044/45 for PR19) is higher for PR14 than PR19 for all WRZs.

The target headroom has changed between PR14 and PR19 due to completing a new calculation for each resource zone, which included different sources of uncertainty and assumptions. In addition we have chosen a reducing percentage percentile profile across the planning horizon to allow for increasing risk across the planning horizon, in accordance with the WRP (Environment Agency, 2017a).

7.7 Options for Reducing Uncertainty in Planning Period

We believe that our approach to catchment management (see Section 3.11) will help reduce uncertainty in the planning period. Working in partnership with others, we believe it can reduce the risk of gradual pollution in the vicinity of our groundwater sources.

We will always use the latest information and data when preparing our supply and demand assessments.

Climate change remains a significant uncertainty. We will use the recently released PR24 guidance for completing our PR24 WRMP climate change assessments.

Demand variation is largely due to customer behaviour. However, our ambitious water efficiency programme aims to reduce per capita consumption (PPC) over AMP7 and beyond and further improve our already excellent understanding of water use.

8.0 BASELINE SUPPLY-DEMAND BALANCE



8.1 Background

The baseline dry year supply and demand data determined in the previous chapters has been used to produce a Baseline Dry Year Supply Demand Balance for each of the four Water Resource Zones (WRZ). All the known changes to Water Available For Use (WAFU) and the known baseline demand management policies have been included in these calculations.

The baseline supply demand balance calculation is to identify whether a WRZ is predicted to have a supply deficit at any point over the planning horizon. For each WRZ, as supply demand balance graph has been prepared. The key features on each of the graphs are:

- The 'target headroom' profile which has been added to the constrained dry weather demand forecast. Target headroom is calculated using the 90th percentile until the end of AMP7, which then reduces to the 55th percentile by 2060. Consequently, target headroom declines over the planning horizon;
- The demand forecasts include the assumptions on water efficiency savings from our baseline demand management; and

- Climate change has been built into the supply, demand and target headroom forecasts as outlined earlier in this document.

The initial supply demand balance graphs for each WRZ are presented in the following sections along with commentary on the key features of interest.

8.2 Essex Resource Zone

Figure 8.1 below presents a baseline supply demand balance for the Essex WRZ. The Abberton Scheme, delivered in AMP5, provided an increase in deployable output in the Essex WRZ of 67 MI/d. This has provided sufficient water supplies to ensure a supply surplus is maintained until 2060.

The supply demand balance graph below shows a gentle increasing trend in WAFU. This is due to climate change which may increase winter rainfall and therefore river flows and the ability to store this extra water in the now enlarged Abberton Reservoir.




Figure 8.1: Essex WRZ baseline supply demand balance

The balance of supply in MI/d is illustrated in Table 8.1 below and can be summarised as follows:

Table 8.1: Essex WRZ balance of supply

Essex WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	45.92	49.47	50.92	50.99	67.27	61.52	38.27
Balance of Supply (including headroom)	12.73	16.33	21.43	24.52	42.95	39.02	19.94

The balance of supply with target headroom ranges from 12.73 MI/d at the end of AMP6 to 39.02 MI/d at the end of the statutory 25 year planning period (2045). This increase is due to a bulk raw water export agreement with Thames Water ending. Balance of supply then reduces to 19.94 MI/d by 2060 due to an increase in customer demand.

Given the supply surplus, no supply schemes will be required. We have offered other water companies a temporary trade of 5 MI/d until 2035 and then up to 25 MI/d from 2045 to 2060. This is discussed further in section 10 of this report (Final Water Resources Planning Strategy).

8.3 Suffolk Blyth Resource Zone

Figure 8.2 presents a baseline Supply Demand Balance for the Blyth WRZ.

Suffolk Blyth Water Resource Zone
Draft Final WRMP - Baseline Supply Demand Balance




Figure 8.2: Suffolk Blyth WRZ baseline supply demand balance

WAFU remains constant while DI increases slightly over the planning horizon. The balance of supply for in MI/d is summarised as follows.

Table 8.2: Suffolk Blyth WRZ balance of supply

Blyth WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (exc. headroom)	4.02	3.95	4.03	4.06	4.02	3.96	3.63
Balance of Supply (inc. headroom)	2.74	2.69	2.93	3.09	3.10	3.10	2.91

The balance of supply with target headroom ranges from 2.74 MI/d at the end of AMP6 to 3.10 MI/d at the end of the 25 year planning horizon and 2.91 MI/d at the end of the 40 year planning horizon.

Given the supply surplus, no supply or demand schemes will be required.

8.4 Suffolk Hartismere Resource Zone

Figure 8.3 below presents a baseline supply demand balance for the Hartismere WRZ.




Figure 8.3: Suffolk Hartismere WRZ baseline supply demand balance

WAFU remains constant over the planning horizon while DI increases slightly over the planning horizon. The balance of supply in MI/d is illustrated in Table 8.3 below and can be summarised as follows:

Table 8.3: Suffolk Hartismere balance of supply

Hartismere WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	2.16	2.08	2.05	2.02	1.95	1.86	1.53
Balance of Supply (including headroom)	1.35	1.29	1.32	1.35	1.34	1.30	1.07

The balance of supply with target headroom ranges from 1.35 MI/d at the end of AMP6 to 1.30 MI/d at the end of the 25 year planning horizon to 1.07 MI/d at the end of the 40 year planning horizon.

Given the supply surplus, no supply or demand schemes will be required.

8.5 Suffolk Northern Central Resource Zone

Figure 8.4 below presents a baseline supply demand balance for the Northern Central WRZ.




Figure 8.4: Suffolk Northern Central WRZ baseline supply demand balance

WAFU decreases over the planning horizon due to the implications of climate change on the DO of the River Waveney abstraction. DI increases over the planning horizon. The balance of supply for in MI/d can be summarised as follows:

Table 8.4: Suffolk Northern Central balance of supply

Northern Central WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	23.93	24.03	23.95	23.62	22.91	22.13	19.97
Balance of Supply (including headroom)	19.16	18.66	18.93	18.93	18.42	17.76	15.99

The balance of supply with target headroom ranges from 19.16 MI/d at the end of AMP6 to 17.76 MI/d at the end of the 25 year planning horizon and 15.99 MI/d at the end of the 40year planning horizon.

Given the supply surplus, no supply or demand schemes will be required.

8.6 Impact of Climate Change on the Overall Supply Demand Balance

8.6.1 Background

The effect of climate change on both supply and demand forecasts has been described in section 6 of this report. Subsequent to the calculation of target headroom and the development of initial supply demand balances for each of our WRZs, the impact of climate change on the balance is summarised in this section.

A comparison has been made between the supply demand balance with and without climate change. This has been enabled by re-running the target headroom calculations through Monte Carlo simulation but with the relevant climate change components (on both supply and demand) having been removed.

The results of the assessment for each water resource zone are illustrated in the following sections. In each section a graph is presented which compares the supply demand balance in a particular zone for both with and without climate change scenarios. The “with climate change” scenarios are illustrated in orange and the “without climate change” scenarios are illustrated in blue.

8.6.2 Essex Resource Zone

The with and without climate change baseline dry year supply demand graph is illustrated below.




Figure 8.5: Essex WRZ baseline dry year supply demand with and without climate change

The difference in the Essex WRZ balance of supply (including target headroom) according to the two scenarios is summarised below.

Table 8.5: Essex WRZ balance of supply with and without climate change

Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
with climate change BoS (M/d)	12.73	16.33	21.43	24.52	42.95	39.02	21.13
without climate change BoS (M/d)	11.69	14.91	20.96	24.57	42.97	39.11	22.19

As there is a supply surplus under both scenarios, it can be concluded that climate change is not driving any investment in either supply or demand schemes.

8.6.3 Suffolk Blyth Resource Zone

The with and without climate change baseline dry year supply demand graph is illustrated below.




Figure 8.6: Suffolk Blyth WRZ baseline dry year supply demand with and without climate change

The difference in the Blyth WRZ balance of supply (including target headroom) according to the two scenarios is summarised below.

Table 8.6: Suffolk Blyth WRZ balance of supply with and without climate change

Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
with climate change BoS (MI/d)	2.74	2.69	2.93	3.09	3.10	3.10	2.91
without climate change BoS (MI/d)	2.78	2.75	2.99	3.13	3.17	3.19	3.00

As there is a supply surplus under both scenarios, it can be concluded that climate change is not driving any investment in either supply or demand schemes.

8.6.4 Suffolk Hartismere Resource Zone

The with and without climate change baseline dry year supply demand graph is illustrated below.




Figure 8.7: Suffolk Hartismere WRZ baseline dry year supply demand with and without climate change

The difference in the Hartismere WRZ balance of supply (including target headroom) according to the two scenarios is summarised below.

Table 8.7: Suffolk Hartismere WRZ balance of supply with and without climate change

Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
with climate change BoS (MI/d)	1.35	1.29	1.32	1.35	1.34	1.30	1.07
without climate change BoS (MI/d)	1.35	1.27	1.33	1.38	1.37	1.33	1.11

As there is a supply surplus under both scenarios, it can be concluded that climate change is not driving any investment in either supply or demand schemes.

8.6.5 Suffolk Northern Central Resource Zone

The with and without climate change baseline dry year supply demand graph is illustrated below.




Figure 8.8: Suffolk Northern Central WRZ baseline dry year supply demand with and without climate change

The difference in the Northern Central WRZ balance of supply (including target headroom) according to the two scenarios is summarised below.

Table 8.8: Suffolk Northern Central balance of supply with and without climate change

Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
with climate change BoS (MI/d)	19.16	18.66	18.93	18.93	18.42	17.76	15.99
without climate change BoS (MI/d)	19.71	19.01	19.47	19.47	19.07	18.49	16.90

As there is a supply surplus under both scenarios, it can be concluded that climate change is not driving any investment in either supply or demand schemes.

8.6.6 Summary

The baseline supply demand balance graphs, both with and without climate change, for each of the WRZs confirms that a supply surplus is maintained across the planning period.

9. OPTION APPRAISAL



For all four Water Resource Zones, the baseline scenario supply demand balance demonstrates a supply surplus over the full planning period from 2020/21 to 2059/60. Consequently, there is not a requirement to develop new water resources and so there are no resource schemes to appraise in this section. Additionally, there are no new demand actions beyond those described in the metering, leakage and water efficiency strategies described in section 5.

The options appraisal for our demand management schemes is presented in Appendix 5.

10. FINAL WATER RESOURCES STRATEGY



10.1 Final Planning Supply Demand Balance

10.1.1 Overview

We have carefully followed the Water Resource Planning Guidelines (WRPG) and believe it has prepared a robust draft Water Resources Management Plan (WRMP). The baseline supply demand balance in section 8 of this report has confirmed the nature of the balance of supply for each Water Resource Zone (WRZ). A final planning scenario supply demand balance calculation has been prepared for each of the WRZ's which includes a final plan Distribution Input (DI) forecast based on our leakage, metering and water efficiency strategies (see section 5) going forwards.

A final planning scenario supply demand balance graph and tabled summary data (with and without target headroom) is presented for each WRZ in the following sections.

10.1.2 Essex WRZ

The baseline supply demand balance graph for the Essex WRZ showed that a supply surplus was maintained across the full planning period.

The final planning supply demand balance graph below shows a greater supply surplus across the planning period from 2020 to 2060. This is because while household property and population increases, water demand is reduced as a result of our final planning water efficiency and leakage strategies. The graph also shows a 20 MI/d increase in Water Available for Use (WAFU) in 2035 which is a consequence of a bulk supply agreement with Thames Water coming to an end.




Figure 10.1: Essex WRZ draft WRMP final planning supply demand balance

Table 10.1: Essex WRZ draft WRMP final balance of supply

Essex WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	45.92	64.81	75.78	84.65	106.72	104.23	80.75
Balance of Supply (including headroom)	12.73	31.68	46.29	58.18	82.39	81.74	62.41

We are promoting a new scheme in our Periodic Review 2019 (PR19) Business Plan called the Abberton to Hanningfield Pipeline. It is being promoted in the Business Plan as it will not increase deployable output in the Essex WRZ and is being promoted under resilience and cost benefit of future water treatment requirement drivers. If supported by our economic regulator Ofwat, a new pipeline would be constructed that would allow water from Abberton Reservoir to be pumped to Hanningfield Reservoir. The scheme would also make use of an existing operational pipeline. The benefits of this option, including impacts on outage, deployable output and levels of service, and the consequences to the supply-demand balance of this investment, are outlined in Appendix 10.

We believe that the pipeline will provide greater water resources resilience as it will allow water from Abberton Reservoir to be pumped across to Hanningfield Reservoir should an imbalance in reservoir storage occur for reasons outside of our control. This PR19 WRMP has planned for higher unplanned outage in the Essex WRZ than was allowed for in the PR14 WRMP. This is in part due to the levels of algae observed in Abberton Reservoir in 2016/17, which constrained Layer Water Treatment Works (WTW) output. The increase in PR19 un-planned outage that has been allowed for in the Essex WRZ has not caused a supply deficit at any point across the planning period. However, since the enlargement of Abberton Reservoir as part of the Abberton Scheme, there still remains uncertainty regarding how water quality, particularly algae, will out-turn in future years. This may be a consequence of different reservoir dynamics (water depth, water temperature, mixing, leaching of nutrients from soil) due to the enlargement of Abberton Reservoir, or because of external climatic changes. The latter should not be ruled out as other water companies have noted similar challenges relating to algae. If constructed, the pipeline would reduce actual un-planned outage as we would then be able to plan to increase Hanningfield WTW output, which has spare capacity, when poor water quality in Abberton Reservoir constrains Layer WTW output. We could only plan to do this once the proposed pipeline has been installed. If it were to do it now, this would cause a storage imbalance between Abberton and Hanningfield Reservoirs.

A further driver for the pipeline is that it would defer or even negate the need for an upgrade of Layer WTW. Previous WRMPs have confirmed the need for Layer treatment works to be upgraded to increase its deployable output from 145 MI/d to 165 MI/d, and eventually 210 MI/d. However we have concluded that, rather than upgrade Layer WTW, Hanningfield WTW could be used to meet future increases in customer demand as it has spare capacity. However, this is only possible with the proposed pipeline. This makes sense from a cost benefit perspective as the pipeline is likely to be significantly cheaper than upgrading Layer WTW.

We have included the proposed pipeline scheme in our PR19 Business Plan. In support of this, we have completed a draft Habitats Regulation Assessment (HRA) and Water Framework Directive (WFD) “No Deterioration” assessments which will cover, among other aspects, the risk of transferring Invasive Non-native Species (INNS).

10.1.3 Blyth WRZ

The baseline supply demand balance graph for the Blyth WRZ showed that a supply surplus was maintained across the full planning period. The supply surplus in the final planning supply demand balance graph below is slightly higher reflecting our final planning water efficiency and leakage strategies.




Figure 10.2: Suffolk Blyth WRZ draft WRMP final planning supply demand balance

Table 10.2: Suffolk Blyth WRZ draft WRMP final balance of supply

Blyth WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	4.02	4.27	4.54	4.75	4.85	4.86	4.53
Balance of Supply (including headroom)	2.74	3.01	3.44	3.78	3.94	4.01	3.80

10.1.4 Hartismere WRZ

The baseline supply demand balance graph for the Hartismere WRZ showed that a supply surplus was maintained across the full planning period. The supply surplus in the final planning supply demand balance graph below is slightly higher reflecting our final planning water efficiency and leakage strategies.




Figure 10.3: Suffolk Hartismere WRZ draft WRMP final planning supply demand balance

Table 10.3: Suffolk Hartismere WRZ draft WRMP final balance of supply

Hartismere WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	2.16	2.30	2.40	2.49	2.52	2.49	2.15
Balance of Supply (including headroom)	1.35	1.51	1.67	1.83	1.91	1.93	1.69

10.1.5 Northern Central WRZ

The baseline supply demand balance graph for the Northern Central WRZ showed that a supply surplus was maintained across the full planning period. The supply surplus in the final planning supply demand balance graph below is slightly higher reflecting our final planning water efficiency and leakage strategies.




Figure 10.4: Suffolk Northern Central WRZ draft WRMP final planning supply demand balance

Table 10.4: Suffolk Northern Central WRZ draft WRMP final balance of supply

Northern Central WRZ	End of AMP6	End of AMP7	End of AMP8	End of AMP9	End of AMP10	End of Planning Horizon	End of 40 Year Planning Horizon
Year	2019/20	2024/25	2029/30	2034/35	2039/40	2044/45	2059/60
Balance of Supply (excluding headroom)	23.93	25.03	25.68	26.06	25.90	25.25	23.06
Balance of Supply (including headroom)	19.16	19.65	20.66	21.37	21.41	20.87	19.07

10.2 Water Framework Directive Water Body Deterioration Risk

10.2.1 Background

An objective of the Water Framework Directive is to prevent deterioration of the status of all surface water and groundwater bodies. The WRPG requires water companies to show in their WRMPs how they will manage the risk of deterioration due to the increased utilisation of abstraction licence annual licensed quantities.

The WRPG confirms that a planned increase in abstraction should be used as the trigger to assess whether increased abstraction poses a deterioration risk to the status of water bodies. The Environment Agency's approach allows full licensed quantities to be used to meet inter-annual fluctuations in demand that may arise between dry, normal and wet years. However, a sustained increase in abstraction to meet growth in demand could be considered to pose a deterioration risk where, for example, river flow falls consistently below an Environment Agency defined threshold called the Environmental Flow Indicator (EFI).

It is therefore possible to undertake a risk assessment to provide an indication of the level of deterioration risk in each of our WRZs in the first instance simply by reviewing the baseline distribution input forecast. This along with previous risk of deterioration assessments are considered for each of the WRZs below.

10.2.2 Essex WRZ

The Essex wells provide a constant base load into the WRZ and there are no plans to increase abstraction above recent actual in the near future. The Chigwell bulk supply licensed quantity is often fully utilised and so there is no scope to increase abstraction from the Lea Valley reservoirs. The remainder of the Essex WRZ is covered by the Essex System which covers abstractions from the Rivers Stour, Blackwater and Chelmer and from Abberton and Hanningfield reservoirs. As part of the Abberton Scheme, Black and Veatch consultants undertook a WFD assessment for us to ensure that there would be no deterioration on either the donor (Ely Ouse rivers) or receiving rivers (Essex System rivers). The assessment was based on full licensed quantities and concluded that there would be no deterioration of water body status.

Our dry year distribution input in 2020/21 is forecast to be 384.68 MI/d. However, due to demand management strategies (see section 5), distribution input will then be lower than this across the full planning period. Given the above points, we conclude that there is not a risk of WFD water bodies deteriorating as a result of abstraction from the Essex and Ely Ouse rivers over the statutory 25 year planning horizon from 2020 to 2045.

10.2.3 Suffolk Blyth WRZ

Our dry year distribution input in 2020/21 is forecast to be 9.02 MI/d. However, due to demand management strategies (see section 5), distribution input will then be lower than this across the full planning period. Consequently, we conclude that there is not a risk of WFD water bodies deteriorating as a result of abstraction from the

Chalk and Crag aquifers over the statutory 25 year planning horizon from 2020 to 2045.

10.2.4 Suffolk Hartismere WRZ

Our dry year distribution input in 2020/21 is forecast to be 7.46 Ml/d. However, due to demand management strategies (see section 5), distribution input will then be lower than this across the full planning period. Consequently, we conclude that there is not a risk of WFD water bodies deteriorating as a result of abstraction from the Chalk and Crag aquifers over the statutory 25 year planning horizon from 2020 to 2045.

10.2.5 Suffolk Northern Central WRZ

Our dry year distribution input in 2020/21 is forecast to be 46.48 Ml/d. However, due to demand management strategies (see section 5), distribution input is forecast to be lower than this until 2049/50. Consequently, we conclude that there is not a risk of WFD water bodies deteriorating as a result of abstraction until at least 2049/50.

The Northern Central WRZ is largely supplied by surface water abstracted from the River Bure and Ormesby Broad (Ormesby Licence), Fritton and Lound Lakes (Lound Licence) and the River Waveney. Groundwater is also abstracted from a series of boreholes near to Beccles in Suffolk.

Fritton and Lound Lakes

The Lound annual licensed quantity has previously been utilised and so it is not possible to increase abstraction.

Beccles Area Chalk Boreholes

We abstract from a series of Chalk boreholes near to Beccles in Suffolk. These boreholes are included in Water Industry National Environment Programme (WINEP) for investigation in AMP7. Once these investigations have been completed, the results can be used to repeat the no deterioration assessment for the Northern Central WRZ in time to feed into the PR24 WRMP.

River Waveney

The River Waveney is supported by a series of boreholes which collectively form the Environment Agency owned and operated Waveney Augmentation Groundwater Scheme (WAGS). It is currently thought that the reliable yield of the WAGS scheme can always provide a net gain in flow at our River Waveney intake so that:

- i. The full daily licensed quantity can always be met; and
- ii. A minimum flow is maintained downstream of the River Waveney intake to prevent the saline interface from moving upstream during low river flows.

The sustainability of the WAGS scheme along with an assessment of its net gain at our intake will be undertaken by the Environment Agency and ourselves in 2018 and if required as part of AMP7 groundwater sustainability investigations. Once

completed, a no deterioration assessment of the River Waveney abstraction can be repeated in time to feed into the PR24 WRMP.

River Bure and Ormesby Broad

Both the River Bure and Ormesby Broad abstractions have previously been investigated by ourselves (AMP National Environment Programme (NEP)) and the Environment Agency (Review of Consents (RoC)). The Environment Agency modelled the effect of abstracting the full licensed quantity (10,000 MI/annum) from the River Bure and concluded no likely significant effects. Historically, we abstract about 6,000 MI/annum from the River Bure although this might increase in the future to reduce abstraction from Ormesby Broad. This should not cause deterioration in water body status as abstraction would still be less than 10,000 MI/annum which was assessed not to cause significant likely effects.

For our Ormesby Broad abstraction, RoC was not able to conclude 'no likely significant effects' because a minimum water depth of 30 cm was not always maintained in drought years across the extent of the Broad. Consequently, the abstraction licence has now been modified to include a Broad abstraction cessation level of -0.44 mAOD and we have undertaken a programme of sediment removal to ensure that a minimum water depth is always maintained across the full extent of the Broad. This work means that the abstraction licence is now considered sustainable.

11. SENSITIVITY TESTING

11.1 Overview

In line with the Water Resources Planning Guideline (WRPG), this section assesses the sensitivity of our supply surplus to future uncertainties using scenario testing.

The resilience of our Plan to droughts is considered in our Supply Assessment in Section 3 while flood risk and freeze / thaw events are considered in Section 2.11. In these sections of the Water Resources Management Plan (WRMP), we conclude that we are resilient to drought, freeze / thaw events and to flooding and so these events are not considered further in this section.

The main uncertainties in our WRMP include:

- iii. Sustainability reductions to our abstraction licences; and
- iv. New non-household demand

11.2 Sensitivity to Sustainability Reductions

The WRPG states that water companies should work out the impact of possible sustainability changes identified in the Periodic Review 2019 (PR19) Water Industry National Environment Programme (WINEP) on Water Resource Zone (WRZ) deployable output through scenario testing.

Our part of the WINEP (Version 3) includes:

- 24 Water Framework Directive (WFD) groundwater abstraction investigations and options appraisals; and
- One sustainability change implementation scheme for a groundwater source that may affect flows in the River Brett.

No sustainability reductions have been defined for the 24 WFD schemes and so it was not possible to present a revised deployable output assessment for these sources in our draft WRMP.

However, in the Environment Agency's draft WRMP consultation response, it asked that we consider a scenario that assesses the impact of potential reductions to licences from groundwater sources from the chalk and crag aquifers towards historic patterns of use. We have therefore prepared a supply demand balance where our Water Available for Use (WAFU) forecast is based on all of our abstraction licence annual licensed quantities being capped at a recent actual (the maximum annual abstraction between 2005 and 2015) utilisation rate. The resulting final plan supply demand balance graphs for Blyth and Hartimere WRZs are presented below.




Figure 11.1: Blyth WRZ Final Plan supply demand balance – Recent Actual Scenario




Figure 11.2: Hartismere WRZ Final Plan supply demand balance – Recent Actual Scenario

The Blyth WRZ graph shows that a supply surplus would be maintained without allowing for target headroom. However, there would be a supply deficit when including target headroom. This would be -0.32 MI/d at the start of AMP7 reducing to -0.06 MI/d at the end of AMP7 primarily due to demand savings resulting from leakage reduction. Further reductions in leakage and per capita consumption (PCC) would mean that there would then be a small supply surplus across the remainder of the planning period.

The Hartismere WRZ graph shows that a supply surplus would be maintained across the planning period both with and without an allowance for target headroom.

In our draft WRMP, we included a sustainability reduction for an emergency use groundwater source that may affect the River Brett in the Essex WRZ. This effectively reduced the source's abstraction licence daily licensed quantity from 22.73 MI/d to 15.57 MI/d. However, we did not allow for this sustainability reduction in our draft WRMP final plan deployable output (DO) assessment. This was because there was insufficient evidence regarding what the total sustainability reduction for all abstraction licence holders should be in order for the River Brett to reach good status. Additionally, there was insufficient evidence to confirm what the apportionment of effect should be between ourselves, Anglian Water and Affinity Water. The Environment Agency has since undertaken further assessments and revised our sustainability reduction to 4.5 MI/d. This has now been allowed for in our Essex System Aquator model, which calculates our baseline and final plan DO. The inclusion of this sustainability reduction reduces the Essex System deployable output by 2 MI/d.

We will continue to work with the Environment Agency, Anglian Water and Affinity Water on a joint investigation and if required options appraisal in AMP7. Any required option would be implemented in AMP8.

11.3 Sensitivity to Unconfirmed Non-household Demand

11.3.1 Essex Water Resource Zone

EDF Energy is promoting a new nuclear power station at Bradwell-on-Sea in Essex. It is currently forecasting construction will commence in 2027 with a construction and operational water demand of 2 MI/d.

We do not believe that there is a sufficient level of certainty regarding the proposed construction start date. Consequently, the potential demand for Bradwell B power station has not been included in the Essex WRZ final plan Distribution Input forecast. Instead, we have presented it as a sensitivity scenario (see Figure 11.3 overleaf).




Figure 11.3: Essex WRZ Final Plan supply demand balance with proposed Bradwell C power station development

This shows that the final plan Essex WRZ has a supply surplus of 33.35 MI/d in 2025. Consequently, an additional power station demand of 2 MI/d can easily be met without the need for additional supply and / or demand schemes.

11.3.2 Blyth Water Resource Zone

EDF Energy is also promoting a new nuclear power station at Sizewell in Suffolk known as Sizewell C. It is currently forecasting construction will commence in 2022 with a maximum additional demand of 2 MI/d. While the proposed construction start date is in AMP7, planning applications (Development Order Consent) for the proposed development have not been submitted and so the demand from this proposed development has not been included in the baseline Distribution Input Forecast.

However, for scenario testing, we have prepared the supply demand balance graph below in which the Distribution Input forecast includes the potential demand of ~2 MI/d from the proposed development.




Figure 11.4: Suffolk Blyth WRZ Final Plan supply demand balance with proposed Sizewell C Power Station

This shows that a supply surplus is still maintained across the full 40 year statutory planning period.

Since submitting our draft WRMP in November 2017, we have met with EDF Energy on 14 May 2018 and again on 15 June 2018 with the Environment Agency to discuss Sizewell C water supply and demand. The EA has highlighted that including the 2 MI/d of additional demand from Sizewell C in our final plan distribution input forecast would mean that there would be a sustained increase in overall abstraction. As the aquifers from which we abstract in the Blyth Water Resource Zone do not have a “good” Water Framework Directive status, we then would not be able to demonstrate compliance with the Water Framework Directive “No deterioration” test. The EA has asked that we illustrate through a supply demand balance graph the effect of the additional Sizewell C demand but with the supply line (known as Water Available for Use or WAFU) being based on recent actual abstraction (i.e. the maximum annual abstraction between 2005 and 2015). This is illustrated in Figure 11.5 overleaf.




Figure 11.5: Suffolk Blyth WRZ Final Plan supply demand balance – Recent Actual plus proposed Sizewell C Power Station Scenario

The above supply demand balance graph shows a supply deficit which means a new supply would be required. We have confirmed with the Environment Agency and EDF that we will not supply Sizewell C power station with water using water abstracted under our existing abstraction licences.

Our view is that there is still significant uncertainty regarding the Sizewell C construction start date and as such it would be wrong to include it in our final plan. Once there is greater certainty regarding the Sizewell C construction start date, this would count as a material change to our WRMP. We would then include it in our final plan Distribution Input forecast. As the Environment Agency has said that for the purposes of the WFD no deterioration test we would have to cap our abstraction licences at recent actual volumes, we would not comply with the no deterioration test. Consequently, we would have to develop a new supply and/or demand scheme, albeit that the cost of this would have to be funded by EDF Energy. We have communicated our position to EDF Energy.

12. SUMMARY



12.1 Summary

A supply and demand forecast has been prepared for each of our Water Resource Zones (WRZ) for the following scenarios:

- Worst historic drought; and
- A drought with a return period of 1 in 200 Years.

Our final plan confirms that a supply surplus will be maintained under both scenarios in all four of our WRZs across both the statutory minimum planning period (25 years to 2045) and the full planning period (40 years to 2060) which have been considered in this plan. This is achieved without the need to develop new supply schemes or to implement Level 4 restrictions and demonstrates the resilience of the WRZs to future droughts.

We have concluded that the volume of water we forecast we will need to abstract over the planning period will not deteriorate the status of the water bodies from which we abstract. This is in part due to the demand savings and reductions in network losses that our water efficiency and leakage strategies will respectively bring.

12.2 Annual Review of this Water Resources Management Plan

Once published, this Water Resources Management Plan will be reviewed annually in line with the Environment Agency's Water Resources Planning Guidelines. All appropriate out turn data (for example, leakage, metering, abstraction and progress with implementing the Water Industry National Environment Programme) will be reported. We will consult with the Environment Agency should it wish to make any material changes to this plan.

13. REFERENCES



- Allen, S. (2012) Analysis of rolling dry periods for UK regions, National Climate Information Centre
- Amec Foster Wheeler (2013) Impact of Climate Change on Water Levels, Final Report
- Anglian Water Services (2012) Climate Change Yield Assessment of AWS Water Resources for the Water Resources Management Plan: Proposed Methodologies
- CCWater (2013) The Customer Impact of Universal Metering Programmes
- CCWater (2016a) Customers' Experiences of Universal Metering
- CCWater (2016b) Water Matters 2015
- CCWater (2017) Water Matters 2016
- DECC (2014) Public Awareness, Attitudes & Experiences of Smart Meters
- Defra (2012) MTP records
- Defra (2016) Guiding Principles for Water Resources Planning

Defra (2017) Water Resources Management Plan (England) Direction

Defra (2018) Green Future: Our 25 Year Plan to Improve the Environment

ECU (2015) Urban Infrastructure Insights Report

Edge Analytics (2017) Population, Household and Property forecast technical report

Environment Agency (2008) Water Resources Planning Guideline

Environment Agency (2012a) Water Efficiency Evidence Base - Review and Enhancement

Environment Agency (2012b) Water resources planning guideline – The technical methods and instructions

Environment Agency (2013) Water Resources Planning Guideline

Environment Agency (2016a) Water Resources Planning Guideline

Environment Agency (2016b) Water for life and livelihoods - Part 1: Anglian river basin district River basin management plan

Environment Agency (2017a) Water Resources Planning Guideline

Environment Agency (2017b) Drought response: our framework for England

Environment Agency (2017c) WRMP19 Supplementary Information- Estimating the impacts of climate change on water supply

Environment Agency (2017d) Sustainable Abstraction

Environment Agency (2017e) Managing the risk of spread of Invasive Non-Native Species through raw water transfers

Environment Agency (2018) Invasive Species Isolated Catchment Mapping Version 3

Essex & Suffolk Water (2009) River Waveney Water Resource Modelling & Deployable Output Calculation

Essex & Suffolk Water (2017a) ESW Groundwater Deployable Output Assessment Report

Essex & Suffolk Water (2017b) Study of Water Use Technical Report

Essex & Suffolk Water (2017c) Micro-components Technical Report

Essex & Suffolk Water (2017d) PR19 Headroom Calculations Report

Essex & Suffolk Water (2017e) Outage Allowance Report - Periodic Review 2019

Ewan Associates (2002) Review of Operational Use – Phase II

Herrington, P. (1996) Climate Change and the Demand for Water, HMSO

ICSconsulting (2010) Our Water Our Future: You Gov Survey

Northumbrian Water Group (2010) Metering research

Northumbrian Water Group (2016) Vulnerability research

Northumbrian Water Group (2017) Metering and WRMP research

Ofwat (2017) Delivering Water 2020: consultation on our methodology for the 2019 price review

Oudin, L., Hervieu, F., Michel, C., Perrin, C., Andreassian, V., Anctil, F., Loumagne, C. (2005) Which potential evapotranspiration input for a lumped rainfall-runoff model?: Part 2 – Towards a simple and efficient potential evapotranspiration model for rainfall-runoff modelling. *Journal of Hydrology*, 303(1-4), 290-306

Murphy, J., Sexton, D., Jenkins, G., Boorman, P., Booth, B., Brown, K., Clark, R., Collins, M., Harris, G., Kendon, L. (2009) UK Climate Projects Science Report

National Infrastructure Commission (2018) Preparing for a Drier Future

Strategic Management Consultants (2012) Review of the calculation of sustainable economic level of leakage and its integration with water resource management planning

Tabony, R. C. (1977) Variability of long-duration rainfall over Great Britain, Meteorological Office Scientific Paper No. 37

UKWIR (1995a) A Methodology for the Determination of Outputs for Groundwater Sources

UKWIR (1995b) Outage Allowances for Water Resource Planning

UKWIR (1995c) Methods of Estimating Population and Household Projections

UKWIR (1998) A Practical Method for Converting Uncertainty into Headroom

UKWIR (2002) Improved Methodology for Assessing Headroom

UKWIR (2007) Guidance for Water Resources Management Plans & Drought Plans

UKWIR (2012a) Water Resources Planning Tools (Report Reference Number 12/WR/27/6)

UKWIR (2012b) Links and Benefits of Water and Energy Efficiency Joint Working – Final Report (Report Reference Number 12/CL/11/6)

UKWIR (2013) Impact of climate change on Water demand – Main Report

UKWIR (2014) Understanding customer behaviour for water demand forecasting

UKWIR (2015) WRMP19 Methods – Household consumption forecasting – Supporting guidance

UKWIR (2016a) WRMP19 Methods-Risk based planning

UKWIR (2016b) WRMP19 Methods-Household Demand Forecasting (Report Reference Number 15/WR/02/9)

UKWIR (2016c) Integration of behavioural change into demand forecasting and water efficiency practices (Report reference number 16/WR/01/15)

UKWIR (2016d) Factors Affecting Minimum Achieved Leakage Levels

UKWIR (2017) Consistency of Reporting Performance Measures

UKWIR and Environment Agency (2002) The Economics of Balancing Supply and Demand

UKWIR and NRA (1995) Demand Forecasting Methodology - Main Report

WaterUK (2016) Water Resources Long Term Planning Framework 2015 - 2065

Waterwise (2008) Water consumption of components of domestic demand

Waterwise (2018) Assessing water efficiency services offered by water retailers

WRc (2009) Review of Meter Under-registration

APPENDICES

APPENDIX 1: FIGURES

For security reasons, detailed mapping is only available upon request to Department for Environment, Food & Rural Affairs (Defra) and its agencies.



Figure 1: Essex & Suffolk Water's Supply Areas and Transfer Scheme Infrastructure




Figure 2: Essex Water Resource Zone (WRZ) and associated infrastructure.



Figure 3: Suffolk* WRZs and Associated Infrastructure

* The Suffolk Northern Central Water Resource Zone includes parts of coastal Norfolk including the borough of Great Yarmouth.

APPENDIX 2: WATER RESOURCES PLANNING TABLES

Completed Tables

A series of Water Resources Planning (WRP) tables represent the supply demand balance of the plan for each of our WRZs and also provide information for organisations to understand and appraise the Water Resources Management Plan (WRMP).

A suite of tables is available in an individual workbook for each WRZ.

The fundamental basis of the tables is the dry year annual average scenario and both baseline and final planning data are presented within the same workbook for each resource zone.

No critical period scenarios were appropriate for any of our resource zones. The tables have been provided electronically to regulators in the first instance.

Copies of these tables are available on request.

APPENDIX 3: SECURITY INFORMATION

This draft WRMP has been independently security checked for us by our Security Certifier from Jacobs and will also be subject to final approval by Defra prior to release into the public domain. No information has been redacted from this draft WRMP.

APPENDIX 4: ACRONYMS AND ABBREVIATIONS

Active Leakage Control	ALC
Above Ordnance Datum	AOD
Anglian Water Service	AWS
Average Day Peak Week	ADPW
Deepest Advisable Pumping Water Level	DAPWL
Department of Environment, Food & Rural Affairs	Defra
Deployable Output	DO
Distribution Input	DI
District Meter Area	DMA
Environmental Flow Indicator	EFI
Ely Ouse to Essex Transfer Scheme	EOETS
Essex & Suffolk Water	ESW
Future Flows	FF
Great Ouse Groundwater Scheme	GOGS
Habitat Regulations Assessment	HRA
Internal Drainage Board	IDB
Invasive Non-Native Species	INNS
Latin Hypercube Sampling	LHS
Levels of Service	LoS
Local Authority	LA
Maximum Likelihood Estimation	MLE
Minimum Residual Flow	MRF
National Environment Programme	NEP
Per Capita Consumption	PCC
Periodic Review 2009	PR09
Periodic Review 2014	PR14
Periodic Review 2019	PR19
Rateable Value	RV
Recent Actual	RA
Regional Spatial Strategy	RSS
Review of Consents	RoC
Site of Special Scientific Interest	SSSI
Stour Augmentation Groundwater Scheme	SAGS
Strategic Environmental Assessment	SEA
Study of Water Use	SWU
Supply Demand Balance	SDB
Sustainable Economic Level of Leakage	SELL
Thames Water Utilities	TWU
Treatment Works Operational Use	TWOU
UK Climate Projections	UKCP09
Water Available for Use	WAFU
Waveney Augmentation Groundwater Scheme	WAGS
Water Closet	WC
Water Industry National Environment Programme	WINEP
Water Resource Management Plan	WRMP
Water Resource Zone	WRZ
Water Resources Planning Guideline	WRPG
Water Treatment Works	WTW

Appendix 5: DEMAND MANAGEMENT OPTIONS APPRAISAL

See separate document:

www.eswater.co.uk/wrmp

Appendix 6: DEFINING DRY YEAR FACTORS TECHNICAL REPORT

Available on request:

waterresources@nwl.co.uk

Appendix 7: MICRO-COMPONENTS TECHNICAL REPORT

Available on request:

waterresources@nwl.co.uk

Appendix 8: POPULATION, HOUSEHOLD & PROPERTY FORECASTS

Available on request:

waterresources@nwl.co.uk

Appendix 9: STUDY OF WATER USE

Available on request:

waterresources@nwl.co.uk

Appendix 10: ADDITIONAL INFORMATION ON RESILIENCE SCHEMES

Available on request:

waterresources@nwl.co.uk